

NOT YET COMMISSIONED

Date of form 13/10/14

NOT YET COMMISSIONED

Date of form 13/10/14

Date of form 13/10/14

Schedule 3 - Form Number: A3

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Air

Release Point: A2

Release for Quarter ending: **March 2020**

NIL RETURNED

Reporting Form A3			
Details of operation of by-pass stack			
Date	Time	Duration	Reason for Operation

Signed on behalf of the Operator

.....

Date

Schedule 3 - Form Number: W1**Operator: Kepak****Permit Number: AP3433ES**

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: [March2020](#)

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	* See note and S1	* See note and S1	* See note and S1
Suspended Solids mg/l	50	* See note and S1	* See note and S1	* See note and S1
Mineral oil and hydrocarbons mg/l	5	2.8	0.6	06/02/2020
Suspended Solids mg/l	50	16.0	5.0	06/02/2020
Mineral oil and hydrocarbons mg/l	5	2.1	0.6	05/03/2020
Suspended Solids mg/l	50	8.0	6.0	05/03/2020

Signed on behalf of the Operator
.....

Date

Note: Error with the taking of samples. Planned sampling is now included in daily work orders for ETP staff to ensure no reoccurrence.

Schedule 3 - Form Number: S1**Operator: Kepak****Permit Number: AP3433ES**


Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: [March 2020](#)

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95 th Percentile Value	Maximum
pH	6-11	6.6	7.3	9.12	9.6
Total suspended solids mg/l	600	39	64.3	352.8	732
Total chemical oxygen demand (COD) mg/l	3600	408	765.0	1906.6	3850
Free or emulsified grease or oil mg/l	100	4.91	33.2	139.08	15.8
Anionic synthetic detergent as manoxol OT mg/l	100				
Dissolved oxygen mg/l	-	0.5	1.0	3.3	7.5
Ammoniacal nitrogen as N mg/l	30	1.65	12.5	30.68	51.2
Daily flow m ³ /day	800	68.9	581.1	803.6	862.4
Maximum flow m ³ /h	34	2.9	24.2	33.5	35.9



Signed on behalf of the Operator ...

.....

Date