

Permit Reference Number: KP3135KV

Operator: The Royal Mint Ltd

Facility: The Royal Mint

Form Number: Sewer 1 27/04/20

Reporting of Emissions to Sewer for the period from: January to March 2020 (Quarter 1).

Emission Point:	Substance / Parameter:	Emission Limit Value:	Result: [1]	Test Method: [2]	Sample Date and Times [3]	Accreditation / Certification [4]
S1	Free cyanide	3 mg/l	0.13 mg/l	This is Royal Mint internal result obtained by ICP testing.	15.03.20. 07:30 hrs, spot sample.	This is Royal Mint internal result obtained by ICP testing. Uncertainty undetermined.
S1	Copper and its compounds	1.0 mg/l	0.189 mg/l	This is Royal Mint internal result obtained by ICP testing.	15.03.20. 07:30 hrs, spot sample.	This is Royal Mint internal result obtained by ICP testing. Uncertainty undetermined.
S1	pH	6 – 11	9.5 – 9.9	SX I pH EC Turbidity or NM I pH EC - pH, Conductivity, Turbidity - automated electrode probe	12.02.20. 08:00 hrs & 20.01.20 10:10 hrs spot samples.	UKAS = Methodology accredited to ISO/IEC 17025:2005

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the “minimum – maximum” measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases, the principal technique is stated, e.g. gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Where the Royal Mint results have been used these are the maximum value determined in the reporting period. The external laboratory, used by The Royal Mint, abandoned used testing due to Covid-19 restrictions during March 2020.

Signed  Date 27th April 2020
(Authorised to sign as representative of the Operator)