

# WATER SPOT CHECK SAMPLING

<b>Site Name:</b>	<b>Ffos-y-fran Land Reclamation Scheme</b>		
<b>Permit No:</b>	<b>EPR/DB3131AF</b>	<b>Month:</b>	<b>November 2020 (samples taken 10.11.20)</b>

## Reporting of emissions to water (other than to sewer)

Consent Number	Suspended Solids Consent limits	pH Consent limits	Date of Sample	Discharge Status	pH result	Susp solids result	Weather Conditions
<b>AN0264601 (WC1 Final Effluent)</b>	<b>50 mg/l</b>	<b>5-9</b>	<b>10.11.20</b>	<b>Discharging</b>	<b>8.1</b>	<b>12</b>	<b>Dry</b>
AN0264602 (WC1 Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
<b>NPSWQD000674 (WI Final Effluent)</b>	<b>50 mg/l</b>	<b>5-9</b>	<b>10.11.20</b>	<b>Discharging</b>	<b>8.1</b>	<b>10</b>	<b>Dry</b>
NPSWQD002105 (WI Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
<b>AN0264501 (WB Final Effluent)</b>	<b>50 mg/l</b>	<b>5-9</b>	<b>10.11.20</b>	<b>Discharging</b>	<b>7.9</b>	<b>18</b>	<b>Dry</b>
AN0264502 (WB Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
AN0264603 (WC Final Effluent)	50 mg/l	5-9	N/A	Not Discharging	N/A	N/A	
AN0274601 (WC Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
AN0265001 (WG Final Effluent)	50 mg/l	5-9	N/A	Not Discharging	N/A	N/A	
AN0265002 (WG Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
AN0264801 (WF Final Effluent)	50 mg/l	5-9	N/A	Not Discharging	N/A	N/A	
AN0264802 (WF Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
AN0264401 (WA Final Effluent)	50 mg/l	5-9	N/A	N/A	N/A	N/A	
AN0264402 (WA Storm)	N/A	N/A	N/A	N/A	N/A	N/A	

### Notes:

**WA has not yet been constructed.**

Name	S. Woolmington	Position:	Engineer	Date:	09.12.20
------	----------------	-----------	----------	-------	----------