

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	164.17	-0.72	250.47	67.4	13.09	1.73	-7.53	7.06	0	6.6	772.3	N/A	0
01:00 to 0	167.09	-1.07	254.58	78.79	12.97	1.61	-5.32	7.09	0	6.7	834.8	N/A	0
02:00 to 0	153.21	0.33	234.75	117.26	12.9	1.55	-5.06	7.09	0	6.8	587.1	N/A	0
03:00 to 0	156.56	-0.52	239.02	93.81	13.15	1.34	-6.78	6.98	0	6.5	743.8	N/A	0
04:00 to 0	172.13	-1.88	261.47	81	13.04	1.37	-4.28	6.95	0	6.7	814.3	N/A	0
05:00 to 0	150.75	-3.07	227.57	109.26	13.04	1.45	-5.16	6.95	0	6.6	560.2	N/A	0
06:00 to 0	149.37	-1.42	227.11	127.19	12.95	1.45	-4.6	7.07	0	6.8	724.7	N/A	0
07:00 to 0	146.78	-1.35	223.22	136.24	12.93	1.46	-5.1	7.17	0	6.8	804.4	N/A	0
08:00 to 0	147.91	-3.35	222.95	100.79	12.94	1.4	-6.28	7.16	0	6.8	569.4	N/A	0
09:00 to 0	142.93	-0.25	218.43	107.28	13.05	1.26	-5.4	7.09	0	6.7	769.4	N/A	0
10:00 to 1	141.1	0.59	216.47	103.23	13.21	1.14	-6.06	7.01	0	6.6	875.8	N/A	0
11:00 to 1	145.02	1.73	223.61	112.54	13.08	1.14	-6.48	7.02	0	6.6	657.8	N/A	0
12:00 to 1	158.91	-4.42	238.72	83.45	12.95	1.4	-5.08	7.13	0	6.8	817.4	N/A	0
13:00 to 1	143	-5.93	212.87	57.75	13.1	3.22	-7.8	7.13	0	6.6	876.6	N/A	0
14:00 to 1	160.78	0.1	246.1	77.42	13.23	1.22	-7.3	6.93	0	6.5	597.8	N/A	0
15:00 to 1	166.3	2.01	256.46	71.94	13.18	1.25	-5.22	6.95	0	6.6	751.6	N/A	0
16:00 to 1	159.89	0.48	245.11	97.26	13.04	1.39	-4.24	7.07	0	6.8	793.7	N/A	0
17:00 to 1	153.04	-1.18	232.97	100.54	13.04	1.38	-6.35	7.09	0	6.7	555.2	N/A	0
18:00 to 1	160.18	-1.86	243.21	76.24	13.16	1.38	-5.53	6.95	0	6.6	737.6	N/A	0
19:00 to 1	167.57	-2.35	254.04	64.77	13.17	1.37	-5.99	6.97	0	6.6	801.7	N/A	0
20:00 to 2	172.15	-2	261.39	62.9	13.06	1.39	-5.55	7.01	0	6.6	526.4	N/A	0
21:00 to 2	172.95	-0.42	264.19	64.59	13.07	1.41	-4.59	7.01	0	6.7	661.9	N/A	0
22:00 to 2	173.87	2.8	268.82	57.66	13.16	1.37	-3.79	6.86	0	6.6	779.7	N/A	0
23:00 to 2	158.75	1.3	244.18	58.88	12.96	1.92	-4.76	6.99	0	6.7	545.2	N/A	0
95 Percenti	172.95	2.01	264.19	127.19	13.21	1.92	-4.24	7.16	0	6.8	875.8	N/A	0
Daily Avera	157.68	-0.93	240.32	87.84	13.06	1.48	-5.59	7.03	0	6.7	715	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	153.37	-7.45	227.2	64.83	13.02	1.45	-6.54	7.06	0	6.6	645.3	N/A	0
01:00 to 0	168.39	-9.92	247.71	65.5	12.96	1.31	-4.7	6.95	0	6.6	706.2	N/A	0
02:00 to 0	159.76	-4.87	239.56	88.03	12.9	1.42	-4.91	7.06	0	6.8	495.2	N/A	0
03:00 to 0	153.02	-1.33	232.79	79.61	13.07	1.4	-6.05	7.06	0	6.7	654.6	N/A	0
04:00 to 0	161.51	1.8	248.91	81.19	12.99	1.51	-3.36	7.02	0	6.8	727.2	N/A	0
05:00 to 0	153.79	1.23	236.53	75.51	13.05	1.42	-4.81	6.95	0	6.6	558.7	N/A	0
06:00 to 0	154.82	-0.48	236.4	71.74	13.06	1.37	-4.15	6.98	0	6.7	758.5	N/A	0
07:00 to 0	151.64	-0.91	231.11	87.48	13	1.41	-3.42	7.06	0	6.8	833.7	N/A	0
08:00 to 0	144.23	0.15	220.82	77.2	13.08	1.28	-5.74	7	0	6.6	578.5	N/A	0
09:00 to 0	140.83	-2.37	213.1	89.16	13.18	1.25	-5.36	6.92	0	6.6	779.2	N/A	0
10:00 to 1	142.4	-2.33	215.55	93.56	13.19	1.22	-5.53	6.95	0	6.6	894.6	N/A	0
11:00 to 1	144.22	-0.1	220.56	101.87	12.92	1.27	-4.56	7.05	0	6.8	609.6	N/A	0
12:00 to 1	134.39	-2.04	203.58	80.03	12.97	2.83	-6.45	7.19	0	6.8	806.6	N/A	0
13:00 to 1	144.78	-1.32	220.2	106.75	13.03	1.27	-4.1	7.03	0	6.8	906.4	N/A	0
14:00 to 1	143.78	-1.91	218.08	97.65	13.04	1.24	-5.77	6.97	0	6.6	619.9	N/A	0
15:00 to 1	155.95	-1.86	236.75	98.89	13.02	1.3	-4.49	6.99	0	6.7	794.6	N/A	0
16:00 to 1	159.05	-0.94	242.4	117.79	12.94	1.37	-4.37	7.05	0	6.8	886.2	N/A	0
17:00 to 1	153.02	-2.6	231.52	122.78	12.89	1.43	-5.4	7.08	0	6.7	605.2	N/A	0
18:00 to 1	158.65	-2.46	240.28	103.07	13	1.41	-5.18	7.06	0	6.7	770	N/A	0
19:00 to 1	156.88	-0.8	239.22	106.62	13.04	1.46	-4.15	6.96	0	6.7	870.8	N/A	0
20:00 to 2	146.66	-4.06	220.33	108.84	13.03	1.37	-5.82	6.99	0	6.6	588.5	N/A	0
21:00 to 2	152.08	-4.01	228.67	104.93	12.96	1.41	-5.05	7.05	0	6.7	743.3	N/A	0
22:00 to 2	145.26	-3.75	218.5	145.8	12.9	1.52	-4.92	7.13	0	6.8	832.9	N/A	0
23:00 to 2	129.95	-10.12	188.71	98.59	12.8	2.17	-5.68	7.22	0	6.9	560	N/A	0
95 Percenti	161.51	1.23	247.71	122.78	13.18	2.17	-3.42	7.19	0	6.8	894.6	N/A	0
Daily Avera	150.35	-2.6	227.44	94.48	13	1.46	-5.02	7.03	0	6.7	717.7	N/A	0

CDAS 2004

Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	143.1	-6.3	212.63	107.94	12.89	1.38	-4.51	7.22	0	6.9	727.6	N/A	0
01:00 to 0	138.6	-5.66	206.4	92.13	13.02	1.29	-5.42	7.14	0	6.8	817.3	N/A	0
02:00 to 0	138.27	-0.1	211.45	118.1	12.85	1.32	-4.98	7.19	0	6.9	563.3	N/A	0
03:00 to 0	137.94	0.32	211.36	153.1	12.8	1.37	-4.1	7.29	0	7	706.1	N/A	0
04:00 to 0	138.58	1.15	213.19	113.24	12.98	1.31	-4.63	7.12	0	6.8	790.7	N/A	0
05:00 to 0	138.06	-2.5	208.73	117.86	12.97	1.32	-5.21	7.11	0	6.8	549.6	N/A	0
06:00 to 0	145	-2.2	219.65	108.72	12.98	1.31	-3.56	7.05	0	6.8	679.5	N/A	0
07:00 to 0	149.6	-8.76	220.13	110.01	12.98	1.32	-5.58	7.12	0	6.8	758	N/A	0
08:00 to 0	149.91	-0.52	228.84	112.58	12.97	1.34	-6.18	7.15	0	6.8	539.3	N/A	0
09:00 to 0	153	1.43	235.52	124.03	13.07	1.47	-4.49	7.02	0	6.7	697.2	N/A	0
10:00 to 1	156.84	4.35	244.31	107.92	13.15	1.48	-5.09	7.01	0	6.7	804.3	N/A	0
11:00 to 1	152.15	-1.26	231.52	122.88	12.96	1.46	-5.11	7.07	0	6.8	574.4	N/A	0
12:00 to 1	161.02	-2.1	244.26	117.25	12.77	1.95	-2.14	7.15	0	7	716	N/A	0
13:00 to 1	159.75	-2.39	242.04	113.85	12.74	3.08	-4.29	7.31	0	7	809	N/A	0
14:00 to 1	153.23	-4.79	229.65	119.44	12.88	1.51	-5.58	7.18	0	6.8	548.6	N/A	0
15:00 to 1	152.72	-6.24	227.43	111.83	12.82	1.63	-1.75	7.07	0	7	660.1	N/A	0
16:00 to 1	166.24	-6.73	247.63	114.84	12.87	1.52	-3.38	7.09	0	6.9	712.8	N/A	0
17:00 to 1	179.79	-6.68	268.4	102.66	12.83	1.61	-3.45	7.12	0	6.9	491.7	N/A	0
18:00 to 1	186.16	-9.29	275.54	88.27	12.8	1.73	-3.52	7.2	0	7	596.7	N/A	0
19:00 to 1	175.09	-12.44	255.45	79.61	12.96	1.69	-2.65	6.99	0	6.8	624.9	N/A	0
20:00 to 2	153.95	-3.73	231.81	102.28	12.95	1.72	-3.18	7.02	0	6.8	418.9	N/A	0
21:00 to 2	170.59	2.7	263.7	107.49	12.95	1.69	-2.31	7.02	0	6.9	551.6	N/A	0
22:00 to 2	183.86	3.31	284.61	107.67	12.93	1.75	-2.12	7.05	0	6.9	615.1	N/A	0
23:00 to 2	177.81	-1.73	270.32	102.21	12.87	1.92	-2.47	7.07	0	6.9	430.8	N/A	0
95 Percenti	183.86	3.31	275.54	124.03	13.07	1.95	-2.12	7.29	0	7	809	N/A	0
Daily Avera	156.72	-2.92	236.86	110.66	12.92	1.59	-3.99	7.12	0	6.9	641	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	167.38	-0.4	255.69	86.4	12.98	2.23	-3.98	7.12	0	6.9	568.3	N/A	0
01:00 to 0	170	0.38	260.48	102.01	13.11	1.66	-3.53	6.97	0	6.7	671.1	N/A	0
02:00 to 0	154.03	-1.35	234.31	111.51	12.94	1.71	-3.13	7.02	0	6.8	491.6	N/A	0
03:00 to 0	151.34	-2.6	228.95	132.86	12.92	1.67	-2.68	7.08	0	6.9	613.2	N/A	0
04:00 to 0	153.42	-5.14	229.59	124.95	12.95	1.75	-2.86	7.1	0	6.9	648.8	N/A	0
05:00 to 0	152.76	-6.2	227.52	121.56	12.98	1.7	-3.45	7.04	0	6.8	438.6	N/A	0
06:00 to 0	159.8	-4.26	240.24	109.07	13.06	1.69	-3.14	6.99	0	6.8	550.9	N/A	0
07:00 to 0	165.74	-3.15	250.43	108.12	13.06	1.7	-2.68	6.99	0	6.8	629	N/A	0
08:00 to 0	160.43	0.23	245.69	136.46	12.92	1.8	-3.45	7.09	0	6.9	458.8	N/A	0
09:00 to 0	158.85	5.65	248.68	118.36	13.08	1.63	-3.39	7.06	0	6.8	590	N/A	0
10:00 to 1	156.21	7.35	246.35	106.91	13.21	1.58	-3.4	6.94	0	6.7	700.4	N/A	0
11:00 to 1	162.8	-0.37	248.71	106.79	13.2	1.48	-5.93	6.94	0	6.6	498.4	N/A	0
12:00 to 1	184.39	2.77	284.89	100.45	13.08	1.59	-0.85	6.85	0	6.8	647.4	N/A	0
13:00 to 1	181.08	3.91	280.97	94.85	13.15	1.56	-2.46	6.93	0	6.8	778.4	N/A	0
14:00 to 1	169.82	0.14	259.96	73.69	12.92	3.69	-3.68	7.06	0	6.8	559.1	N/A	0
15:00 to 1	181.88	0.52	278.8	88.97	13.09	1.54	-2.42	6.9	0	6.7	723.1	N/A	0
16:00 to 1	175.77	-2.14	266.79	87.77	13.24	1.51	-4.6	6.84	0	6.6	770.8	N/A	0
17:00 to 1	158.35	-0.24	242.03	105.74	13.34	1.49	-3.07	6.59	0	6.4	526.3	N/A	0
18:00 to 1	151.41	2.92	234.58	131.51	13.31	1.52	-0.2	6.57	0	6.6	696.6	N/A	0
19:00 to 1	152.9	5.51	239.45	124.14	13.4	1.49	-0.58	6.52	0	6.5	801.8	N/A	0
20:00 to 2	150.09	-0.56	229.07	93.48	13.44	1.42	-2.42	6.45	0	6.3	555.8	N/A	0
21:00 to 2	160.12	-1.71	243.27	91.42	13.42	1.51	-0.45	6.42	0	6.4	706.2	N/A	0
22:00 to 2	151.17	-5	226.29	97.38	13.29	1.51	-0.25	6.56	0	6.5	759.1	N/A	0
23:00 to 2	163.55	-5.57	244.67	96.37	13.13	1.74	-0.55	6.67	0	6.6	483.7	N/A	0
95 Percenti	181.88	5.65	280.97	132.86	13.42	2.23	-0.25	7.1	0	6.9	778.4	N/A	0
Daily Avera	162.22	-0.39	247.81	106.28	13.13	1.72	-2.63	6.86	0	6.7	619.5	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	166.25	-9.04	245.32	75.84	13.18	2.05	0.2	6.6	0	6.6	578.3	N/A	0
01:00 to 0	169.39	-9.9	249.26	91.07	13.25	1.64	0.78	6.51	0	6.6	638.3	N/A	0
02:00 to 0	151.33	-3.26	228.27	90.07	13.34	1.58	-0.07	6.47	0	6.5	438.7	N/A	0
03:00 to 0	154.02	-3.19	232.46	101.07	13.18	1.61	0.49	6.64	0	6.7	563.3	N/A	0
04:00 to 0	151.5	-0.5	231.29	96.63	13.32	1.49	-2.93	6.74	0	6.6	647.8	N/A	0
05:00 to 0	151.94	-1.71	230.76	91.67	13.26	1.51	-3.23	6.77	0	6.6	462.5	N/A	0
06:00 to 0	140.96	-1.63	214.05	94.11	13.35	1.45	-4.01	6.78	0	6.5	606.9	N/A	0
07:00 to 0	148.73	-0.8	226.75	91.34	13.41	1.42	-4.04	6.74	0	6.5	687	N/A	0
08:00 to 0	148.62	-3.75	223.64	109.61	13.23	1.52	-3.27	6.78	0	6.6	451.2	N/A	0
09:00 to 0	158.69	2.91	245.71	103.54	13.27	1.48	-1.53	6.74	0	6.6	618.7	N/A	0
10:00 to 1	179.14	5.75	279.84	82.26	13.42	1.2	-0.81	6.61	0	6.6	917.4	N/A	0
11:00 to 1	179.2	3.27	277.45	77.71	13.45	1.2	-2.55	6.5	0	6.3	826.9	N/A	0
12:00 to 1	152.64	14.86	248.4	104.32	13.79	1.09	-3.1	6.3	0	6.1	1300	N/A	0
13:00 to 1	141.96	-6.51	210.69	116.27	13.31	2.87	-1.83	6.54	0	6.4	1106.2	N/A	0
14:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.56	0	N/A	N/A	N/A	0
15:00 to 1	169.28	5.85	264.86	90.86	13.51	1.37	-3.79	6.48	0	6.3	324.6	N/A	0
16:00 to 1	168.7	6.63	264.74	98.51	13.47	1.43	0.91	6.28	0	6.4	532.9	N/A	0
17:00 to 1	160.71	-3.97	241.93	128.38	13.37	1.44	-2.63	6.48	0	6.4	403.6	N/A	0
18:00 to 1	159.76	-10.49	233.95	112.29	13.29	1.55	0.28	6.39	0	6.4	527.9	N/A	0
19:00 to 1	165.73	-7.11	246.46	104.08	13.3	1.63	2.66	6.25	0	6.4	605.5	N/A	0
20:00 to 2	150.05	-4.3	225.28	150.62	13.24	1.73	3.84	6.23	0	6.5	416.5	N/A	0
21:00 to 2	143.95	-6.9	213.35	178.4	13.22	1.74	3.85	6.31	0	6.6	519.7	N/A	0
22:00 to 2	143.35	-10.77	208.56	131.45	13.21	2.36	1.75	6.42	0	6.5	557	N/A	0
23:00 to 2	156.34	-2.59	236.61	108.74	13.38	1.68	-0.42	6.41	0	6.4	394.1	N/A	0
95 Percent	179.14	6.63	277.45	150.62	13.51	2.36	3.84	6.78	0	6.6	1106.2	N/A	0
Daily Avera	157.05	-2.05	238.24	105.6	13.34	1.61	-0.84	6.52	0	6.5	614.1	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	153.48	-0.14	234.67	128.15	13.35	1.72	1.16	6.39	0	6.5	502.3	N/A	0
01:00 to 0	147.21	-0.84	224.39	127.99	13.34	1.72	-0.19	6.44	0	6.4	556.5	N/A	0
02:00 to 0	156.54	-4.07	235.43	102.35	13.36	1.75	0.47	6.33	0	6.4	394.3	N/A	0
03:00 to 0	151.2	-6.64	224.7	122.85	13.32	1.86	2.04	6.28	0	6.4	483.9	N/A	0
04:00 to 0	144.53	-6.19	214.94	157.37	13.27	1.74	-1.93	6.65	0	6.5	566	N/A	0
05:00 to 0	140.03	-4.43	209.82	160.03	13.29	1.66	-3.74	6.69	0	6.4	409.1	N/A	0
06:00 to 0	137.71	-4.05	206.64	137.47	13.3	1.67	-3.25	6.68	0	6.5	535.9	N/A	0
07:00 to 0	140.46	-3.72	211.18	159.41	13.29	1.66	-3.12	6.71	0	6.5	608.6	N/A	0
08:00 to 0	143.83	-2.2	217.86	212.99	12.98	1.69	-2.32	6.96	0	6.8	428.2	N/A	0
09:00 to 0	161.86	4.8	252.44	152.78	13.1	1.42	-3.55	7.04	0	6.8	641.2	N/A	0
10:00 to 1	162.88	3.87	253.07	127.27	13.42	1.27	-5.32	6.84	0	6.5	857.8	N/A	0
11:00 to 1	158.43	6.11	248.51	83.09	13.15	2.52	-4.41	6.9	0	6.6	607.7	N/A	0
12:00 to 1	158.83	11.11	254.13	96.65	13.43	2	-6.59	6.88	0	6.5	961.5	N/A	0
13:00 to 1	162.83	3.78	252.9	108.72	13.41	1.15	-5.13	6.72	0	6.4	950.8	N/A	0
14:00 to 1	163.74	-3.62	246.91	91.45	13.39	1.05	-6.87	6.7	0	6.3	631.5	N/A	0
15:00 to 1	159.11	-3.39	240.04	98.99	13.47	1.1	-5.73	6.57	0	6.2	804	N/A	0
16:00 to 1	160.9	-5.18	241	85.87	13.43	1.15	-5.75	6.59	0	6.2	861.1	N/A	0
17:00 to 1	163.06	-0.45	249.03	115.72	13.38	1.24	-4.26	6.6	0	6.4	529.4	N/A	0
18:00 to 1	158.48	0.56	243.03	196.41	13.22	1.3	-3.49	6.78	0	6.6	651	N/A	0
19:00 to 1	158.1	3.21	245.11	182.46	13.35	1.23	-5.32	6.78	0	6.4	747.5	N/A	0
20:00 to 2	156	0.92	239.59	104.97	13.46	1.15	-5.97	6.65	0	6.3	534.5	N/A	0
21:00 to 2	160.19	-3.39	241.7	104.34	13.37	1.28	-4.29	6.67	0	6.4	648.6	N/A	0
22:00 to 2	154.95	-6.31	230.76	152.34	13.28	1.36	-4.36	6.71	0	6.4	694.5	N/A	0
23:00 to 2	151.6	0.07	232.01	221.71	13.08	1.65	-2.62	6.83	0	6.7	460.1	N/A	0
95 Percent	163.06	6.11	253.07	212.99	13.46	2	1.16	6.96	0	6.8	950.8	N/A	0
Daily Avera	154.41	-0.84	235.41	134.64	13.31	1.51	-3.52	6.68	0	6.5	627.7	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	145.13	1.89	223.93	134.31	13.21	2.92	-5.18	6.93	0	6.6	584.8	N/A	0
01:00 to 0	148.74	-0.16	227.41	143.82	13.36	1.45	-5.3	6.74	0	6.4	631.7	N/A	0
02:00 to 0	151.38	-0.7	230.91	108.95	13.37	1.33	-5.97	6.71	0	6.3	452.6	N/A	0
03:00 to 0	154.59	0.27	236.78	132.36	13.28	1.42	-3.31	6.71	0	6.5	576.1	N/A	0
04:00 to 0	145.89	2.9	226.11	259.62	13.18	1.57	-4.39	6.86	0	6.6	661.4	N/A	0
05:00 to 0	144.4	-2.65	218.28	163.39	13.23	1.54	-4.9	6.78	0	6.5	449.5	N/A	0
06:00 to 0	142.6	0.82	218.99	161.52	13.3	1.54	-5.13	6.73	0	6.4	604.5	N/A	0
07:00 to 0	148.33	2.28	229.22	134.97	13.4	1.49	-5.79	6.72	0	6.4	684.7	N/A	0
08:00 to 0	151.39	-1.47	230.16	186.51	13.23	1.58	-4.8	6.75	0	6.5	466.8	N/A	0
09:00 to 0	155.41	2.62	240.39	183.86	13.25	1.32	-4.88	6.82	0	6.5	686.5	N/A	0
10:00 to 1	156.47	-0.86	238.53	121.28	13.48	1.23	-5.53	6.67	0	6.3	826.6	N/A	0
11:00 to 1	151.56	5.73	237.61	125.42	13.34	1.45	-4.26	6.66	0	6.4	604	N/A	0
12:00 to 1	145.03	8.33	230.22	118.74	13.54	2.36	-7.65	6.78	0	6.3	968.3	N/A	0
13:00 to 1	156.43	7.55	246.89	125.17	13.51	1.05	-4.87	6.61	0	6.3	1041.1	N/A	0
14:00 to 1	149.27	0.25	228.63	157.17	13.27	1.1	-5.68	6.66	0	6.3	612.3	N/A	0
15:00 to 1	161.61	1.75	249.02	105.36	13.34	1.14	-4.88	6.65	0	6.3	778.4	N/A	0
16:00 to 1	161.85	4.62	252.26	108.89	13.39	1.13	-4.86	6.58	0	6.3	879.3	N/A	0
17:00 to 1	160.21	-2.21	242.91	127.03	13.39	1.15	-6.28	6.56	0	6.2	577.8	N/A	0
18:00 to 1	167.85	-1.83	254.98	167.45	13.3	1.14	-4.63	6.67	0	6.4	801.5	N/A	0
19:00 to 1	164.86	-1.57	250.67	199.63	13.33	1.11	-3.71	6.64	0	6.4	925.2	N/A	0
20:00 to 2	159.7	-0.2	244.14	154.16	13.29	1.14	-5.17	6.6	0	6.3	643.5	N/A	0
21:00 to 2	162.41	-2.32	246.16	115.98	13.38	1.16	-5.52	6.55	0	6.2	791.7	N/A	0
22:00 to 2	166.3	0.01	254.44	110.16	13.42	1.18	-5.07	6.52	0	6.2	901.6	N/A	0
23:00 to 2	162.62	-0.55	248.26	208.8	13.15	1.91	-4.96	6.76	0	6.5	561.3	N/A	0
95 Percenti	166.3	7.55	254.44	208.8	13.51	2.36	-3.71	6.86	0	6.6	968.3	N/A	0
Daily Avera	154.75	1.02	237.79	148.11	13.33	1.43	-5.11	6.69	0	6.4	696.3	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	168.97	1.57	260.1	198.38	13.25	1.3	-2.77	6.57	0	6.4	717.2	N/A	0
01:00 to 0	175.75	-0.27	268.62	107.37	13.32	1.28	-4.52	6.66	0	6.4	778.7	N/A	0
02:00 to 0	149.51	-1.72	227.02	118.81	13.35	1.34	-3.86	6.58	0	6.3	522.3	N/A	0
03:00 to 0	139.35	-5.58	207.64	170.84	13.3	1.36	-3.39	6.65	0	6.4	620	N/A	0
04:00 to 0	142.56	-7.09	211.04	235.48	13.24	1.4	-3.72	6.77	0	6.5	685.6	N/A	0
05:00 to 0	141.31	0.24	216.45	259.42	13.15	1.41	-4.1	6.86	0	6.6	493	N/A	0
06:00 to 0	145.6	0.46	223.22	193.96	13.35	1.38	-5.6	6.78	0	6.4	620.2	N/A	0
07:00 to 0	157.53	3.35	244.37	144.22	13.32	1.49	-2.9	6.69	0	6.5	664.8	N/A	0
08:00 to 0	157.5	1.39	242.37	136.01	13.36	1.42	-3.15	6.55	0	6.3	492.7	N/A	0
09:00 to 0	159.2	2.21	245.79	196.25	13.38	1.32	-3.13	6.64	0	6.4	712.6	N/A	0
10:00 to 1	169.33	0.97	260.05	172.17	13.39	1.21	-3.52	6.75	0	6.5	904.8	N/A	0
11:00 to 1	172.25	8.55	272.09	104.68	13.51	1.01	-6.2	6.61	0	6.2	842.8	N/A	0
12:00 to 1	165.57	15.6	268.91	101.98	13.41	2.38	-3.52	6.64	0	6.4	1244.2	N/A	0
13:00 to 1	173.74	5.71	271.53	110.08	13.5	1.91	-5.45	6.48	0	6.2	1237.9	N/A	0
14:00 to 1	177.52	-3.14	268.47	134.7	13.34	1.14	-3.95	6.47	0	6.2	800.3	N/A	0
15:00 to 1	172.2	-0.51	262.95	140.87	13.38	1.13	-3.8	6.45	0	6.2	1064.7	N/A	0
16:00 to 1	166.48	-10.29	244.42	133.47	13.43	1.17	-6.64	6.52	0	6.1	1060.5	N/A	0
17:00 to 1	164.54	1.67	253.43	102.65	13.33	1.31	-4.57	6.54	0	6.3	646.2	N/A	0
18:00 to 1	157.64	4.23	245.42	198.49	13.45	1.26	-4.85	6.53	0	6.2	831.8	N/A	0
19:00 to 1	154.68	4.94	241.61	293.89	13.35	1.28	-4.19	6.63	0	6.4	913.9	N/A	0
20:00 to 2	156.49	-0.44	238.99	238.32	13.26	1.25	-5.86	6.73	0	6.4	630.2	N/A	0
21:00 to 2	166.95	-1.32	254.12	131.14	13.38	1.3	-5.4	6.6	0	6.3	759.9	N/A	0
22:00 to 2	170.8	-4.71	256.62	106.28	13.28	1.42	-4.79	6.6	0	6.3	768.8	N/A	0
23:00 to 2	169.74	-0.9	258.81	92.16	13.02	2.35	-3.66	6.84	0	6.7	548.2	N/A	0
95 Percenti	175.75	8.55	271.53	259.42	13.5	2.35	-2.9	6.84	0	6.6	1237.9	N/A	0
Daily Avera	161.47	0.62	247.67	159.23	13.34	1.41	-4.31	6.63	0	6.4	773.4	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	162.98	0.01	249.37	195.11	13.26	1.38	-4.2	6.73	0	6.5	695.4	N/A	0
01:00 to 0	159.94	-0.58	244.13	162.26	13.34	1.24	-4.82	6.68	0	6.4	878.9	N/A	0
02:00 to 0	154.55	2.76	239.22	166.08	13.43	1.2	-4.4	6.41	0	6.2	692.4	N/A	0
03:00 to 0	154.18	2.04	237.93	177.17	13.4	1.29	-4.75	6.47	0	6.2	848.4	N/A	0
04:00 to 0	153.19	1.77	236.15	224.08	13.32	1.27	-3.86	6.5	0	6.3	952.6	N/A	0
05:00 to 0	152.64	2.86	236.4	318.23	13.14	1.29	-3.73	6.65	0	6.4	727.8	N/A	0
06:00 to 0	163.57	5.29	255.55	189.07	13.2	1.23	-3.71	6.64	0	6.4	1024.8	N/A	0
07:00 to 0	178.1	6.63	279.12	109.91	13.26	1.26	-3.78	6.56	0	6.3	1163.4	N/A	0
08:00 to 0	153.79	-0.66	234.64	200.37	13.23	1.32	-3.73	6.52	0	6.3	803.9	N/A	0
09:00 to 0	150.93	-0.73	230.19	217.32	13.1	1.35	-2.65	6.62	0	6.5	1042.5	N/A	0
10:00 to 1	145.42	-9.26	213.23	337.96	12.96	1.44	-2.98	6.76	0	6.6	1012.5	N/A	0
11:00 to 1	154.37	1.88	238.07	263.28	13.02	1.4	-4.14	6.76	0	6.5	639.7	N/A	0
12:00 to 1	159.7	0.58	244.92	148.05	13.04	1.41	-4.13	6.75	0	6.5	784.6	N/A	0
13:00 to 1	168.26	-9.76	247.68	123.16	12.81	2.48	-3.5	6.9	0	6.7	840.7	N/A	0
14:00 to 1	172.91	7.79	272.35	119.7	13.06	1.49	-3.93	6.88	0	6.6	598	N/A	0
15:00 to 1	164.64	10.2	262.09	168.02	13.22	1.31	-5.37	6.85	0	6.5	798.9	N/A	0
16:00 to 1	151.56	9.35	241.24	181.8	13.18	1.42	-3.69	6.8	0	6.6	875.5	N/A	0
17:00 to 1	149.08	-3	225.09	166.87	13.17	1.39	-5.7	6.75	0	6.4	630	N/A	0
18:00 to 1	155.03	-4.39	232.81	155.16	13.26	1.35	-5.29	6.69	0	6.4	794.2	N/A	0
19:00 to 1	174.9	-8.06	259.53	136.93	13.13	1.42	-3.7	6.76	0	6.5	840.9	N/A	0
20:00 to 2	163.72	-2.15	248.34	174.05	13.18	1.35	-5.44	6.71	0	6.4	589.5	N/A	0
21:00 to 2	173.44	-1.96	263.41	125.27	13.14	1.36	-4.52	6.77	0	6.5	726.8	N/A	0
22:00 to 2	172.5	-11.69	252.24	107.88	13.15	1.44	-4.53	6.71	0	6.4	734.4	N/A	0
23:00 to 2	171.09	10.71	272.48	127.22	13	2.4	-4.54	7.03	0	6.8	571.8	N/A	0
95 Percenti	174.9	10.2	272.48	318.23	13.4	2.4	-2.98	6.9	0	6.7	1042.5	N/A	0
Daily Avera	160.85	0.4	246.51	178.96	13.17	1.44	-4.21	6.7	0	6.4	802.8	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	156.59	11.04	250.63	238.24	13.2	1.54	-3.86	6.84	0	6.6	660.9	N/A	0
01:00 to 0	174	5.81	272.03	233.12	13.2	1.56	-3.16	6.84	0	6.6	686.2	N/A	0
02:00 to 0	152.58	0.17	233.63	118.74	13.18	1.52	-4.81	6.81	0	6.5	501.9	N/A	0
03:00 to 0	142.68	-0.7	217.6	171.46	13.17	1.57	-4.73	6.84	0	6.6	613.7	N/A	0
04:00 to 0	153.99	-6.81	228.8	173.95	13.17	1.74	-2.94	6.79	0	6.6	593.3	N/A	0
05:00 to 0	181.87	1.81	280.07	122.8	13.03	1.61	-4.54	6.98	0	6.7	468.3	N/A	0
06:00 to 0	162.15	7.08	255.16	178.67	12.98	1.78	-3.38	7.01	0	6.8	610.4	N/A	0
07:00 to 0	172.06	11.04	274.28	134.07	13.15	1.6	-3.73	6.91	0	6.7	702.3	N/A	0
08:00 to 0	160.42	-0.99	244.45	124.23	13.17	1.59	-4.59	6.83	0	6.5	505.2	N/A	0
09:00 to 0	158.76	0.2	243.1	141.7	13.14	1.62	-3.56	6.84	0	6.6	630.4	N/A	0
10:00 to 1	139.45	2.38	215.74	239.71	13.09	1.64	-3.47	6.89	0	6.7	703.7	N/A	0
11:00 to 1	146.83	-5.19	219.46	259.34	12.79	1.79	-3.57	7.03	0	6.8	520.9	N/A	0
12:00 to 1	160.77	1.02	246.99	133.07	12.87	3.87	-5.57	7.16	0	6.8	755.6	N/A	0
13:00 to 1	175.3	-3.82	264.38	111.58	13.07	1.6	-3.49	6.83	0	6.6	822.7	N/A	0
14:00 to 1	151.69	-8.07	224.01	174.03	13.01	1.72	-3.94	6.84	0	6.6	483.8	N/A	0
15:00 to 1	149.59	-10.13	218.74	250.18	12.95	1.67	-3.61	6.97	0	6.7	585.1	N/A	0
16:00 to 1	159.05	-33.13	210.22	179.63	12.79	1.8	-2.74	7.05	0	6.9	493.3	N/A	0
17:00 to 1	157.84	6.09	247.59	150.33	13.12	1.68	-4.25	6.94	0	6.7	460.5	N/A	0
18:00 to 1	158.62	12.29	254.97	125.5	13.17	1.65	-3.19	6.89	0	6.7	606.6	N/A	0
19:00 to 1	165.84	14.3	268.03	138.41	13.26	1.63	-4.06	6.82	0	6.6	650.6	N/A	0
20:00 to 2	170.8	-1.5	259.82	141.34	13.04	1.67	-3.27	6.91	0	6.7	441.3	N/A	0
21:00 to 2	171.27	-2.51	259.52	116.18	13.07	1.64	-3.68	6.95	0	6.7	547.9	N/A	0
22:00 to 2	166.29	0.23	254.65	103.76	13.23	1.63	-4.36	6.84	0	6.6	603.5	N/A	0
23:00 to 2	168.73	-2.36	255.79	96.13	13.03	1.68	-3.07	6.82	0	6.6	435.6	N/A	0
95 Percenti	175.3	12.29	274.28	250.18	13.23	1.8	-2.94	7.05	0	6.8	755.6	N/A	0
Daily Avera	160.71	-0.07	245.82	160.67	13.08	1.74	-3.82	6.9	0	6.7	586.8	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	165.9	-2.28	251.55	91.59	13.04	2.51	-3.89	6.98	0	6.7	545.8	N/A	0
01:00 to 0	172.71	-1.23	263.02	130.65	13.06	1.66	-2.32	6.87	0	6.7	606.2	N/A	0
02:00 to 0	166.52	-5.64	249.14	105.58	13.12	1.61	-5.32	6.9	0	6.5	419.6	N/A	0
03:00 to 0	161.91	-4.89	242.83	95.48	13.27	1.58	-4.85	6.74	0	6.4	534.6	N/A	0
04:00 to 0	165.52	-4.08	249.17	86.31	13.21	1.67	-2.21	6.7	0	6.6	588.3	N/A	0
05:00 to 0	154.36	-5.6	230.57	102.95	13.22	1.57	-4.99	6.72	0	6.4	426.2	N/A	0
06:00 to 0	158.99	-4.65	238.6	116.07	12.97	1.69	-1.71	6.84	0	6.7	519.4	N/A	0
07:00 to 0	156.56	-3.73	235.81	101.48	13.06	1.64	-3.95	6.93	0	6.7	567.5	N/A	0
08:00 to 0	156.02	-2.7	236.01	96.02	13.07	1.66	-3.61	6.83	0	6.6	427.8	N/A	0
09:00 to 0	153.07	1.02	235.23	104.8	13.21	1.64	-3.65	6.77	0	6.5	545.8	N/A	0
10:00 to 1	156.75	3.7	243.53	128.9	13.16	1.63	-2.56	6.79	0	6.6	599.5	N/A	0
11:00 to 1	152.56	-2.4	231.01	182.72	12.96	1.67	-2.34	6.92	0	6.8	468.2	N/A	0
12:00 to 1	135.67	-1.36	206.21	192.12	13	3.82	-4.85	7.09	0	6.8	622.2	N/A	0
13:00 to 1	147.45	-7.22	218.38	197.53	13.07	1.69	-2.18	6.84	0	6.7	660.1	N/A	0
14:00 to 1	155.94	-1	237.6	138.4	13.27	1.53	-5.06	6.79	0	6.5	472.1	N/A	0
15:00 to 1	165.88	-1.06	252.73	102.27	13.16	1.64	-1.39	6.74	0	6.7	580.9	N/A	0
16:00 to 1	172.52	-2.78	261.17	123.75	13.11	1.66	-3.24	6.89	0	6.7	635	N/A	0
17:00 to 1	171.38	-2.25	259.96	103.59	13.09	1.69	-4.67	6.9	0	6.6	436	N/A	0
18:00 to 1	160.46	-8.96	236.54	132.74	13.06	1.82	-1.46	6.75	0	6.7	484.9	N/A	0
19:00 to 1	171.14	-11.39	250.46	94.26	13.06	1.74	-2.49	6.85	0	6.7	510.6	N/A	0
20:00 to 2	157.23	-0.25	240.31	144.13	13	1.84	-1.6	6.83	0	6.7	390.3	N/A	0
21:00 to 2	161.44	12.85	259.86	163.91	12.97	1.84	-2.04	7.01	0	6.9	539.2	N/A	0
22:00 to 2	159.67	14.26	258.55	140.31	13.11	1.79	-2.37	6.89	0	6.7	579.9	N/A	0
23:00 to 2	165.13	-5.14	247.51	106.48	13.04	2.02	-2.49	6.83	0	6.7	416.6	N/A	0
95 Percenti	172.52	12.85	261.17	192.12	13.27	2.51	-1.46	7.01	0	6.8	635	N/A	0
Daily Avera	160.2	-1.95	243.16	124.25	13.09	1.82	-3.13	6.85	0	6.7	524	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	163	-1.34	248.06	97.88	13.04	2.53	-3.32	6.94	0	6.7	525.1	N/A	0
01:00 to 0	161.67	-2.48	244.87	127.3	13.11	1.76	-1.97	6.8	0	6.7	578	N/A	0
02:00 to 0	154.93	-2.05	234.99	163.23	13.09	1.76	-2.67	6.78	0	6.6	392.5	N/A	0
03:00 to 0	159.56	1.94	246.07	145.87	13.03	1.78	-0.76	6.79	0	6.8	512	N/A	0
04:00 to 0	157.63	1.59	242.76	123.87	13.21	1.67	-2.71	6.73	0	6.6	569.4	N/A	0
05:00 to 0	148.13	-4.21	222.42	125.58	13.22	1.7	-3.48	6.71	0	6.5	412.3	N/A	0
06:00 to 0	159.49	-4.59	239.44	127.56	13.08	1.75	-1.66	6.77	0	6.7	530.3	N/A	0
07:00 to 0	155.68	-0.92	237.27	169.15	13.07	1.8	-2.11	6.85	0	6.7	599.7	N/A	0
08:00 to 0	154.65	-2	234.61	126	13.1	1.72	-3.24	6.84	0	6.6	431	N/A	0
09:00 to 0	150.52	2.44	232.73	121.83	13.32	1.4	-2.42	6.67	0	6.5	583.2	N/A	0
10:00 to 1	159.03	4.9	248.22	122.68	13.38	1.21	-2.65	6.66	0	6.5	726.3	N/A	0
11:00 to 1	161.07	2.21	248.64	136.67	13.34	1.24	-4.32	6.68	0	6.4	544.5	N/A	0
12:00 to 1	167.33	1.71	257.72	138.66	13.16	1.38	-2.02	6.76	0	6.6	714.3	N/A	0
13:00 to 1	155.42	-5.12	232.67	92.39	13.2	3.6	-4.37	6.82	0	6.6	716.9	N/A	0
14:00 to 1	203.34	6.46	317.57	190.34	9.89	1.93	9.9	8.86	0	10.2	505.6	N/A	0
15:00 to 1	175.38	7.16	275.49	111.25	12.82	1.27	-15.71	8.03	0	6.9	680.2	N/A	0
16:00 to 1	165.94	6.85	260.74	142.36	13.34	1.41	-2.74	6.55	0	6.4	780.8	N/A	0
17:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.49	0	N/A	N/A	N/A	0
18:00 to 1	151.99	-11.9	220.65	130.92	13.25	1.5	-4.59	6.62	0	6.3	252.8	N/A	0
19:00 to 1	153.27	-7.76	226.74	118.48	13.22	1.55	-1.25	6.49	0	6.4	403.1	N/A	0
20:00 to 2	152.64	1.65	235.19	124.39	13.33	1.45	-2.22	6.48	0	6.3	362.7	N/A	0
21:00 to 2	156.45	3.5	242.87	161.76	13.26	1.43	-1.83	6.59	0	6.5	560	N/A	0
22:00 to 2	152.48	3.17	236.46	139.84	13.13	2.13	-2.06	6.77	0	6.7	694.5	N/A	0
23:00 to 2	163.85	-3.35	247.33	137.66	13.01	1.44	-2.32	6.78	0	6.6	474.4	N/A	0
95 Percenti	175.38	6.85	275.49	169.15	13.34	2.53	-0.76	8.03	0	6.9	726.3	N/A	0
Daily Avera	160.15	-0.09	244.94	133.72	13.02	1.71	-2.63	6.85	0	6.7	545.6	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	163.75	1.15	251.69	120.8	13.09	1.45	-1.45	6.71	0	6.6	637.3	N/A	0
01:00 to 0	162.5	-0.79	247.84	121.85	13.2	1.37	-1.96	6.62	0	6.5	781.8	N/A	0
02:00 to 0	159.01	-5.77	237.51	152.91	12.98	1.65	-2.14	6.73	0	6.6	405.5	N/A	0
03:00 to 0	158.85	-0.66	242.38	143.84	12.92	1.71	0.74	6.64	0	6.7	533.3	N/A	0
04:00 to 0	127.41	6.1	201.04	84.38	12.94	1.3	-2.04	6.89	0	6.8	675.5	N/A	0
05:00 to 0	141.01	-5.01	210.74	96.1	13.08	1.43	-7.03	6.93	0	6.5	490.4	N/A	0
06:00 to 0	175.33	-3.91	264.34	124.92	13.06	1.63	-1.3	6.64	0	6.6	625.8	N/A	0
07:00 to 0	166.78	-2.48	252.7	145.66	12.97	1.56	-1.5	6.8	0	6.7	704.7	N/A	0
08:00 to 0	146.11	1.11	224.66	117.26	13	1.48	-3.56	6.86	0	6.6	509.2	N/A	0
09:00 to 0	152.13	3.21	235.96	103.31	13.17	1.41	-2.36	6.69	0	6.5	690.6	N/A	0
10:00 to 1	152.15	3.65	236.44	104.26	13.21	1.4	-2.49	6.7	0	6.5	807.4	N/A	0
11:00 to 1	154.66	-0.93	235.7	106.76	13.16	1.27	-2.71	6.65	0	6.5	606.3	N/A	0
12:00 to 1	153.81	-6.82	228.51	160.55	13.07	1.45	-0.87	6.7	0	6.6	695.2	N/A	0
13:00 to 1	136.19	-5.16	203.22	178.54	13	3.93	-2.82	6.9	0	6.7	795.3	N/A	0
14:00 to 1	149.33	-0.17	228.31	131.99	13.2	1.36	-3.95	6.71	0	6.5	570.6	N/A	0
15:00 to 1	152.96	-1.75	232.28	129.12	13.22	1.39	-2.61	6.68	0	6.5	718.1	N/A	0
16:00 to 1	165.42	-1.01	252.08	128.35	13.22	1.41	-1.16	6.67	0	6.6	778.1	N/A	0
17:00 to 1	164.04	-3.96	247.02	128.35	13.08	1.42	-3.33	6.76	0	6.5	528.1	N/A	0
18:00 to 1	176.33	-5.24	264.54	85.83	13.18	1.48	-2.41	6.7	0	6.5	667.7	N/A	0
19:00 to 1	181.55	-2.87	274.89	78.26	13.28	1.5	-0.37	6.52	0	6.5	700.1	N/A	0
20:00 to 2	183.58	-2.61	278.26	68.36	13.24	1.48	-1.46	6.5	0	6.4	477.3	N/A	0
21:00 to 2	185.2	-6.7	276.64	72.74	13.13	1.5	-1.48	6.64	0	6.6	588.3	N/A	0
22:00 to 2	171.58	-9.83	252.69	89.7	12.99	2.23	-0.72	6.78	0	6.8	649.3	N/A	0
23:00 to 2	146.03	-4.38	219.05	93.16	13.06	1.49	0.06	6.64	0	6.7	454	N/A	0
95 Percent	183.58	3.65	276.64	160.55	13.24	2.23	0.06	6.9	0	6.8	795.3	N/A	0
Daily Avera	159.4	-2.28	241.6	115.29	13.1	1.6	-2.04	6.71	0	6.6	628.7	N/A	0

CDAS 2004

Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	150.6	-1.11	229.3	95.12	13.28	1.41	0.52	6.49	0	6.5	593.8	N/A	0
01:00 to 0	156.07	-0.75	238.03	89.67	13.31	1.41	0.18	6.49	0	6.5	663.8	N/A	0
02:00 to 0	166.75	-1.2	253.93	78.81	13.11	1.44	-0.18	6.52	0	6.5	461.8	N/A	0
03:00 to 0	190.21	2.21	293.23	116.83	10.95	1.89	3.62	8.4	0	9.1	615.8	N/A	0
04:00 to 0	153.89	1.02	236.47	70.43	13.26	1.35	-4.52	6.77	0	6.5	702	N/A	0
05:00 to 0	143.74	-2.43	217.49	85.88	13.25	1.31	-4.27	6.71	0	6.4	498.4	N/A	0
06:00 to 0	151.04	-0.77	230.32	94.46	13.35	1.31	-4.13	6.73	0	6.5	668.9	N/A	0
07:00 to 0	155.3	0.96	238.58	103.99	13.24	1.37	0.79	6.6	0	6.6	770.8	N/A	0
08:00 to 0	148.83	-0.71	227	130.32	13.21	1.29	-3.42	6.74	0	6.5	547.2	N/A	0
09:00 to 0	161.45	-2.71	244.3	79.44	13.22	1.25	-3.35	6.77	0	6.6	736.9	N/A	0
10:00 to 1	168.68	-5.18	252.9	70.43	13.32	1.21	-4.86	6.73	0	6.4	862.8	N/A	0
11:00 to 1	168.39	-0.1	257.55	68.27	13.33	1.11	-5.72	6.68	0	6.3	631.3	N/A	0
12:00 to 1	166.58	-1.44	253.43	84.51	13.28	1.13	-4.16	6.7	0	6.4	794.7	N/A	0
13:00 to 1	157.73	-2.11	239.21	98.85	12.99	2.33	-2.26	6.88	0	6.7	834.4	N/A	0
14:00 to 1	158.95	0.69	243.89	82.36	13.31	1.15	-5.16	6.69	0	6.4	602.8	N/A	0
15:00 to 1	164.57	-4.25	247.54	85.53	13.32	1.19	-4.37	6.65	0	6.4	709.2	N/A	0
16:00 to 1	166.72	-4.89	250.2	83.19	13.31	1.22	-3.36	6.6	0	6.4	771.6	N/A	0
17:00 to 1	166.15	-2.27	251.95	91.73	13.28	1.2	-3.26	6.59	0	6.4	537.5	N/A	0
18:00 to 1	163.65	-1.58	248.81	106.25	13.27	1.23	-2.37	6.61	0	6.5	707.2	N/A	0
19:00 to 1	167.84	-1.74	255.05	89.82	13.29	1.24	-3.65	6.67	0	6.4	792.5	N/A	0
20:00 to 2	166.68	0.07	255.09	78.85	13.29	1.25	-3.14	6.56	0	6.4	553.3	N/A	0
21:00 to 2	167.15	-1.75	254	80.01	13.36	1.27	-2.54	6.51	0	6.4	728.8	N/A	0
22:00 to 2	169.16	-0.79	258.02	95.93	13.29	1.23	-1.34	6.49	0	6.4	857.2	N/A	0
23:00 to 2	170.47	2.1	262.92	98.45	13.15	1.43	0.06	6.47	0	6.5	625	N/A	0
95 Percenti	170.47	2.1	262.92	116.83	13.35	1.89	0.79	6.88	0	6.7	857.2	N/A	0
Daily Avera	162.53	-1.2	247.47	89.96	13.17	1.34	-2.54	6.71	0	6.6	677.8	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	167.12	-0.72	254.97	85.82	13.23	1.73	-2.92	6.62	0	6.4	831.2	N/A	0
01:00 to 0	172.33	-1.84	261.82	92.85	13.39	1.26	-4.07	6.5	0	6.2	906.7	N/A	0
02:00 to 0	162.66	0.9	249.77	100.69	13.53	1.28	-5.62	6.36	0	6	597.7	N/A	0
03:00 to 0	166.99	0.89	256.38	105.29	13.42	1.33	-4.08	6.43	0	6.2	741.2	N/A	0
04:00 to 0	163.62	2.67	253.01	109.88	13.39	1.34	-3.27	6.48	0	6.3	838.1	N/A	0
05:00 to 0	166.62	-2.04	252.89	83.15	13.4	1.24	-4.93	6.48	0	6.2	626.6	N/A	0
06:00 to 0	171.78	-6.34	256.48	72.49	13.43	1.21	-4.67	6.48	0	6.2	828.1	N/A	0
07:00 to 0	166.3	-6.28	248.17	77.97	13.4	1.22	-5.27	6.51	0	6.2	864.2	N/A	0
08:00 to 0	168.45	1.33	259.06	117.52	13.2	1.33	-4.39	6.63	0	6.4	608.6	N/A	0
09:00 to 0	172.49	1.1	265.02	108.1	13.25	1.33	-4.23	6.63	0	6.4	770.1	N/A	0
10:00 to 1	181.57	2.32	280.13	77.34	13.3	1.32	-4.72	6.62	0	6.3	864.2	N/A	0
11:00 to 1	169.81	-1.27	258.54	64.77	13.39	1.25	-6.33	6.53	0	6.1	595.2	N/A	0
12:00 to 1	170.34	-3.17	257.46	84.82	13.4	1.23	-2.76	6.36	0	6.2	833.9	N/A	0
13:00 to 1	158.69	-3.24	239.57	186.84	13.14	3.06	-4.82	6.75	0	6.5	912.5	N/A	0
14:00 to 1	173.1	0.6	265.43	98.85	13.28	1.25	-5.43	6.57	0	6.2	606.4	N/A	0
15:00 to 1	177.24	1.55	272.73	83.9	13.31	1.21	-4.14	6.53	0	6.3	803.1	N/A	0
16:00 to 1	168.35	2.48	260.06	69.19	13.37	1.2	-3.83	6.44	0	6.2	902.3	N/A	0
17:00 to 1	148.34	-0.56	226.41	96.13	13.36	1.08	-3.78	6.38	0	6.2	707.3	N/A	0
18:00 to 1	137.74	-0.31	210.43	336.2	13.22	1.13	-2.89	6.51	0	6.3	896.8	N/A	0
19:00 to 1	150.24	-4.53	225.33	132.74	12.98	1.18	-4.23	6.89	0	6.6	964	N/A	0
20:00 to 2	146.68	0.79	225.21	96.07	13.12	1.15	-4.45	6.71	0	6.4	675.5	N/A	0
21:00 to 2	147.52	2.58	228.29	81.39	13.16	1.14	-4.43	6.71	0	6.4	871.5	N/A	0
22:00 to 2	135.19	-1.92	204.92	93.37	13.13	1.21	-3.55	6.68	0	6.4	923.7	N/A	0
23:00 to 2	148.93	0.18	228.05	200.98	12.83	1.88	-3.78	6.95	0	6.7	662	N/A	0
95 Percenti	177.24	2.58	272.73	200.98	13.43	1.88	-2.89	6.89	0	6.6	923.7	N/A	0
Daily Avera	162.17	-0.62	247.51	110.68	13.28	1.36	-4.27	6.57	0	6.3	784.6	N/A	0

CDAS 2004

Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	166.71	1.46	256.52	100.18	13.01	1.17	-2.36	6.75	0	6.6	880.2	N/A	0
01:00 to 0	154.66	0.4	237.04	104.19	13.11	1.2	-4.15	6.72	0	6.5	962.1	N/A	0
02:00 to 0	165.52	-12.32	240.92	93.71	12.96	1.37	-4.61	6.75	0	6.5	569.6	N/A	0
03:00 to 0	168.07	-19.16	237.98	88.25	12.94	1.41	-4.93	6.8	0	6.5	685	N/A	0
04:00 to 0	171.03	-20.84	240.83	111.98	12.74	1.5	-2.04	6.9	0	6.8	736	N/A	0
05:00 to 0	144.85	-4.19	217.43	144.65	12.89	1.54	-3.63	6.97	0	6.7	500.6	N/A	0
06:00 to 0	151.56	-3.45	228.44	119.77	12.95	1.54	-3.12	6.95	0	6.7	579.5	N/A	0
07:00 to 0	148.31	3.32	230.22	132.21	13.09	1.56	-1.44	6.79	0	6.7	709.6	N/A	0
08:00 to 0	150.17	2.27	232.03	140.06	13.09	1.54	-3.61	6.75	0	6.5	551.7	N/A	0
09:00 to 0	156.15	-1	237.9	129.1	13.07	1.56	-2.39	6.79	0	6.6	790.6	N/A	0
10:00 to 1	136.25	-7.09	201.36	248.48	12.86	1.79	-3.11	7.02	0	6.8	779.3	N/A	0
11:00 to 1	139.67	-0.14	213.56	212.8	12.84	1.75	-4.66	7.09	0	6.8	527.4	N/A	0
12:00 to 1	144.46	-17.4	203.63	175.04	12.76	1.84	-2.95	7.07	0	6.9	597.2	N/A	0
13:00 to 1	137.51	-14.29	196.1	136.66	12.67	3.48	-2.48	7.19	0	7	661.1	N/A	0
14:00 to 1	149	4.29	232.27	130.62	13.02	1.45	-3.28	6.93	0	6.7	526.6	N/A	0
15:00 to 1	146.18	5.78	229.44	188.69	13.03	1.4	-2.54	6.99	0	6.8	690.6	N/A	0
16:00 to 1	143.22	5.73	224.85	201.38	13	1.42	-3.21	7.09	0	6.9	766.1	N/A	0
17:00 to 1	146.1	-5.86	217.66	156.48	12.79	1.42	-4.85	7.13	0	6.8	520.9	N/A	0
18:00 to 1	150.98	-26.66	204.35	154.85	12.73	1.6	-3.42	7.13	0	6.9	542.3	N/A	0
19:00 to 1	167.06	-18.97	236.63	109.01	12.87	1.51	-3.31	7.03	0	6.8	650.2	N/A	0
20:00 to 2	161.32	2.5	249.32	102.82	13.05	1.46	-4.02	6.92	0	6.6	470.9	N/A	0
21:00 to 2	164.97	0.78	253.17	125.96	12.89	1.51	-2.26	7.05	0	6.9	583.4	N/A	0
22:00 to 2	160.93	7.69	253.91	166.49	13.04	1.39	-3.7	7.04	0	6.8	679.8	N/A	0
23:00 to 2	162.19	-0.34	247.82	92.84	12.87	2.11	-3.37	7.09	0	6.9	499.2	N/A	0
95 Percent	168.07	5.78	253.91	212.8	13.09	2.11	-2.04	7.13	0	6.9	880.2	N/A	0
Daily Avera	153.62	-4.9	230.14	140.26	12.93	1.6	-3.31	6.95	0	6.7	644.2	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	162.2	-0.27	247.9	104.17	13.24	1.32	-4.68	6.89	0	6.6	630.9	N/A	0
01:00 to 0	155.04	-1.79	235.43	118.67	13.17	1.39	-4.02	6.91	0	6.7	690.4	N/A	0
02:00 to 0	159.65	-1.06	243.2	124.97	12.97	1.41	-3.7	6.95	0	6.7	498.3	N/A	0
03:00 to 0	156.54	-15.34	224.16	174.5	12.73	1.54	-3.1	7.14	0	6.9	531	N/A	0
04:00 to 0	155.62	-7.06	231.04	161.9	12.81	1.52	-2.17	7.1	0	6.9	649.2	N/A	0
05:00 to 0	164.23	-0.53	250.74	113.53	13.06	1.39	-4.57	6.98	0	6.7	466	N/A	0
06:00 to 0	161.51	-1.85	245.26	110.96	13.09	1.47	-3.83	6.93	0	6.7	599.5	N/A	0
07:00 to 0	143.53	-4.68	214.92	157.58	13.06	1.55	-2.65	6.9	0	6.7	679	N/A	0
08:00 to 0	147.17	-3.1	222.07	138.27	13.11	1.45	-4.4	6.89	0	6.6	463.2	N/A	0
09:00 to 0	154.68	-1.11	235.55	148.12	13.06	1.47	-2.82	6.94	0	6.8	647.6	N/A	0
10:00 to 1	162.11	2.01	250.05	116.88	13.24	1.33	-3.46	6.87	0	6.6	811.3	N/A	0
11:00 to 1	146.85	-0.19	224.49	124.44	13.28	1.21	-5.42	6.8	0	6.4	635.2	N/A	0
12:00 to 1	148.91	-3.74	224.08	112.27	13.05	3.07	-3.22	7.03	0	6.8	835.1	N/A	0
13:00 to 1	155.13	-8.88	228.47	119.04	13.2	1.38	-4.86	6.95	0	6.6	821.9	N/A	0
14:00 to 1	165.67	6.48	259.96	131.59	13.12	1.29	-3.93	6.89	0	6.6	566.7	N/A	0
15:00 to 1	161.96	8.74	256.53	133	13.09	1.38	-3.41	7.02	0	6.8	687.2	N/A	0
16:00 to 1	158.57	5.75	248.37	126.35	13.09	1.47	-3.72	7.03	0	6.8	730.3	N/A	0
17:00 to 1	148.6	-5.02	222.34	131.23	13.1	1.5	-3.94	6.9	0	6.6	473.4	N/A	0
18:00 to 1	149.81	-1.94	227.27	107.75	13.27	1.43	-4.3	6.84	0	6.6	580.7	N/A	0
19:00 to 1	170.43	-1.17	259.58	90.74	13.15	1.45	-2.18	6.85	0	6.7	633.5	N/A	0
20:00 to 2	163.49	-14.56	235.58	134.08	12.83	1.55	-2.52	7.03	0	6.9	400	N/A	0
21:00 to 2	173.14	-8.85	256.07	116.43	12.91	1.6	-2.47	7.07	0	6.9	566.6	N/A	0
22:00 to 2	169.63	-2.18	257.35	86.71	13.07	1.52	-3.67	7	0	6.8	647.4	N/A	0
23:00 to 2	157.99	-2.65	239.08	77.8	12.95	2.37	-3.83	7.04	0	6.8	483.2	N/A	0
95 Percenti	170.43	6.48	259.58	161.9	13.27	2.37	-2.18	7.1	0	6.9	821.9	N/A	0
Daily Avera	158.02	-2.62	239.15	123.37	13.07	1.55	-3.62	6.96	0	6.7	613.6	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	153.85	-2.12	233.27	95.96	13.22	1.42	-3.71	6.87	0	6.6	608.7	N/A	0
01:00 to 0	156.29	-11.84	227.28	117.92	13.04	1.49	-2.56	6.99	0	6.8	616.3	N/A	0
02:00 to 0	150.98	-2.87	228.13	170.11	12.84	1.54	-3.83	7.2	0	6.9	434.7	N/A	0
03:00 to 0	162.55	0.98	249.68	105.43	12.93	1.47	-2.85	7.13	0	6.9	597.3	N/A	0
04:00 to 0	161.98	3.89	251.73	83.84	13.19	1.43	-4.42	6.98	0	6.7	665.2	N/A	0
05:00 to 0	143.91	-1.75	218.43	127.61	13.07	1.51	-4.56	6.97	0	6.7	487.1	N/A	0
06:00 to 0	140.74	-1.34	213.98	147.12	13.12	1.52	-2.76	6.9	0	6.7	586.5	N/A	0
07:00 to 0	145.2	0.82	222.97	178.01	13.02	1.52	-2.56	7.03	0	6.9	662	N/A	0
08:00 to 0	143.56	2.82	222.47	237.12	12.85	1.53	-3.27	7.2	0	7	493.4	N/A	0
09:00 to 0	148.97	0.89	228.82	155.65	12.84	1.52	-3.32	7.27	0	7	645.5	N/A	0
10:00 to 1	148.53	4.2	231.46	144.47	12.95	1.5	-3.5	7.17	0	6.9	764.6	N/A	0
11:00 to 1	155.17	-4.35	233.06	120.96	12.93	1.47	-3.96	7.12	0	6.8	492.5	N/A	0
12:00 to 1	164.67	0.33	252.29	116.14	12.93	1.44	-2.87	7.12	0	6.9	709.9	N/A	0
13:00 to 1	167.54	0.46	256.79	109.98	12.75	3.67	-2.81	7.32	0	7.1	787.2	N/A	0
14:00 to 1	178.04	-0.09	272.31	109.42	12.93	1.33	-5.02	7.17	0	6.8	549.4	N/A	0
15:00 to 1	179.63	-9.56	265.28	96.51	12.94	1.42	-4.45	7.08	0	6.8	655.6	N/A	0
16:00 to 1	164.72	-8.4	243.62	105.5	13.11	1.42	-3.97	6.91	0	6.7	754.5	N/A	0
17:00 to 1	156.44	1.11	240.46	120.17	13.17	1.39	-5.06	6.88	0	6.6	543.1	N/A	0
18:00 to 1	169.59	-3.53	255.94	119.69	12.91	1.55	-1.02	6.98	0	6.9	608	N/A	0
19:00 to 1	162.73	-0.21	248.77	139.37	12.74	1.61	-1.73	7.24	0	7.1	666.7	N/A	0
20:00 to 2	156.15	-4.5	234.4	118.85	12.89	1.51	-3.61	7.13	0	6.9	466.1	N/A	0
21:00 to 2	146.56	-9.76	214.48	110.1	13.09	1.5	-4.34	6.99	0	6.7	565.1	N/A	0
22:00 to 2	160.75	-11.76	234.19	101.54	13.07	1.58	-1.48	6.87	0	6.8	587.3	N/A	0
23:00 to 2	155.4	-5.49	232.26	86.98	12.85	2.42	-2.36	7.06	0	6.9	414.5	N/A	0
95 Percenti	178.04	3.89	265.28	178.01	13.19	2.42	-1.48	7.27	0	7.1	764.6	N/A	0
Daily Avera	157.25	-2.59	238	125.77	12.97	1.62	-3.33	7.07	0	6.8	598.4	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	172.18	-2.88	260.56	112.69	12.91	1.49	-2.02	7.07	0	6.9	519.3	N/A	0
01:00 to 0	157.67	-2.31	238.92	144.93	12.91	1.5	-2.4	7.09	0	6.9	591.9	N/A	0
02:00 to 0	148.73	-1.29	226.27	127.55	13.03	1.44	-4.08	7.04	0	6.8	433.6	N/A	0
03:00 to 0	147.89	-1.52	224.75	117.02	13.27	1.41	-3.84	6.81	0	6.6	553.1	N/A	0
04:00 to 0	150.44	-1.27	228.9	118.49	13.25	1.44	-2.89	6.79	0	6.6	619.7	N/A	0
05:00 to 0	156.35	3.31	242.53	113.01	13.19	1.42	-3.04	6.82	0	6.6	441.3	N/A	0
06:00 to 0	157.27	6.49	247.11	163.36	13	1.52	-0.97	6.97	0	6.9	590.9	N/A	0
07:00 to 0	151.92	5.3	237.75	182.83	12.92	1.52	-2.29	7.15	0	7	679	N/A	0
08:00 to 0	150.91	-3.28	227.61	123.52	13.06	1.43	-4.73	7.05	0	6.7	449.4	N/A	0
09:00 to 0	146.01	-2.55	220.84	133.42	13.1	1.48	-2.23	6.91	0	6.8	530.5	N/A	0
10:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.74	0	N/A	N/A	N/A	0
11:00 to 1	148.89	-3.23	224.57	118.56	12.96	1.37	-1.43	6.88	0	6.8	290.7	N/A	0
12:00 to 1	171.31	-7.45	254.66	109.23	12.61	2.34	0.01	7.22	0	7.2	468	N/A	0
13:00 to 1	176.23	-7.46	262.18	95.52	12.73	2.63	-2.48	7.22	0	7.1	611.5	N/A	0
14:00 to 1	178.47	-1.42	271.64	93.06	12.97	1.33	-3.59	7.03	0	6.8	429.9	N/A	0
15:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
16:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
17:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
18:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
19:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
20:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
21:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
22:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
23:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
95 Percenti	178.47	6.49	271.64	182.83	13.27	2.63	0.01	7.22	0	7.2	679	N/A	0
Daily Avera	158.16	-1.4	240.59	125.23	12.99	1.59	-2.57	6.99	0	6.8	514.9	N/A	0

CDAS 2004

Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
01:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
02:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
03:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
04:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
05:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
06:00 to 0	110.48	-8.48	160.56	7.72	4.72	15.02	-30.62	18.78	0	14.4	755	N/A	0
07:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
08:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
09:00 to 0	123.41	-25.73	163.09	37.84	4.72	2.07	-32.4	18.87	0	14.4	639.9	N/A	0
10:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	14.19	0	N/A	N/A	N/A	0
11:00 to 1	136.62	-18.29	190.73	102.14	11.89	1.16	-24.91	9.82	0	7.9	250.3	N/A	0
12:00 to 1	140.37	-6.44	208.33	42.5	11.94	1.21	-5.82	8.42	0	8	421.6	N/A	0
13:00 to 1	151.61	3.08	235.04	61.49	12.56	1.44	-10.53	8.12	0	7.4	639.7	N/A	0
14:00 to 1	163.12	-0.37	249.21	80.91	13.19	1.93	-4.39	7	0	6.7	719.4	N/A	0
15:00 to 1	168.96	-2.87	255.65	87.79	13.13	1.72	-3	7.03	0	6.8	740.2	N/A	0
16:00 to 1	167.69	-6.27	250.3	81.28	13.23	1.67	-2.92	6.92	0	6.7	704.7	N/A	0
17:00 to 1	172.27	-8.5	255.07	86.51	13.11	1.71	-1.85	7.01	0	6.9	713.8	N/A	0
18:00 to 1	170.77	-11.55	249.73	82.29	13.04	1.71	-1.75	7.09	0	7	704.6	N/A	0
19:00 to 1	170.86	-10.48	250.93	80.92	13.08	1.63	-2.45	7.1	0	6.9	705.9	N/A	0
20:00 to 2	160.18	-7.43	237.64	115.32	12.95	1.71	-1.86	7.22	0	7.1	729.8	N/A	0
21:00 to 2	158.17	-4.63	237.37	89.05	13.19	1.54	-3.67	7.1	0	6.9	747.5	N/A	0
22:00 to 2	167.8	-4.3	252.44	87.4	13.21	1.6	-1.99	7	0	6.9	740.5	N/A	0
23:00 to 2	166.2	-2.59	251.7	82.18	13.3	1.55	-3.29	6.98	0	6.8	760.3	N/A	0
95 Percenti	172.27	3.08	255.65	115.32	13.3	15.02	-1.75	18.87	0	14.4	760.3	N/A	0
Daily Avera	155.23	-7.66	229.85	75.02	11.82	2.51	-8.76	9.29	0	8	664.9	N/A	0

CDAS 2004

Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	164.71	-2.9	249.11	99.13	13.27	1.62	-3.28	7.01	0	6.8	763.5	N/A	0
01:00 to 0	160.63	0.51	246.27	99.55	13.21	1.57	-2.53	7.01	0	6.8	780	N/A	0
02:00 to 0	163.59	-0.08	250.22	96.54	13.21	1.54	-3.28	7.04	0	6.8	780.3	N/A	0
03:00 to 0	168.01	0.16	257.21	83.84	13.21	1.51	-3.83	7.06	0	6.8	776.6	N/A	0
04:00 to 0	147.71	0.1	226.1	120.09	13.28	1.64	-4.09	7	0	6.7	776.8	N/A	0
05:00 to 0	146.13	-0.95	222.63	127.81	13.28	1.64	-3.58	6.97	0	6.7	770.3	N/A	0
06:00 to 0	145.81	0.52	223.62	124.06	13.33	1.63	-2.97	6.92	0	6.7	812.4	N/A	0
07:00 to 0	152.54	-1.28	232.11	103.88	13.29	1.59	-4.05	6.99	0	6.7	838.8	N/A	0
08:00 to 0	174.66	-3.01	264.22	84.94	13.26	1.7	-2.9	6.93	0	6.7	809.2	N/A	0
09:00 to 0	184.29	0.2	282.16	70.49	13.23	1.67	-3.74	7	0	6.8	841.1	N/A	0
10:00 to 1	180.57	0.21	276.49	58.7	13.44	1.57	-4.72	6.82	0	6.5	881	N/A	0
11:00 to 1	172.09	8.86	272.15	63.07	13.53	1.53	-5.81	6.59	0	6.2	593.4	N/A	0
12:00 to 1	159.16	11.47	254.98	91.1	13.48	1.68	-4.19	6.63	0	6.4	752.1	N/A	0
13:00 to 1	180.42	11.34	287.39	71.86	13.41	1.75	-2.96	6.62	0	6.4	856.4	N/A	0
14:00 to 1	165.29	-0.28	252.62	53.22	13.17	2.86	-4.09	6.74	0	6.5	592.5	N/A	0
15:00 to 1	157.68	0.01	241.27	69.95	13.3	3.05	-6.22	6.77	0	6.4	759.1	N/A	0
16:00 to 1	142.51	0.42	218.46	151.32	13.35	1.41	-4.49	6.68	0	6.4	842.1	N/A	0
17:00 to 1	138.41	-3.08	208.69	141.63	13.11	1.39	-3.18	6.81	0	6.6	573.7	N/A	0
18:00 to 1	152.34	-2.51	230.57	113.73	13.2	1.4	-4.64	6.82	0	6.5	737.7	N/A	0
19:00 to 1	168.26	-3.7	253.75	75.36	13.13	1.48	-4.39	6.85	0	6.6	799.5	N/A	0
20:00 to 2	163.77	-1.61	248.96	75.13	13.06	1.44	-5.71	6.85	0	6.5	575.6	N/A	0
21:00 to 2	152.59	-3.58	229.88	92.33	12.98	1.46	-4.23	6.93	0	6.7	740.3	N/A	0
22:00 to 2	130.63	-3.5	196.36	89.97	12.78	2.13	-3.36	7.15	0	6.9	831.9	N/A	0
23:00 to 2	155.78	-1.25	237.1	96.58	12.94	1.33	-5.31	6.98	0	6.6	579.3	N/A	0
95 Percenti	180.57	11.34	282.16	141.63	13.48	2.86	-2.9	7.06	0	6.8	856.4	N/A	0
Daily Avera	159.48	0.25	244.26	93.93	13.23	1.69	-4.06	6.88	0	6.6	752.6	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	160.26	-1.67	243.54	81.79	12.99	1.39	-5.25	6.95	0	6.6	721.1	N/A	0
01:00 to 0	155.41	-6.41	231.37	83.31	12.91	1.43	-3.83	6.89	0	6.6	742.4	N/A	0
02:00 to 0	147.18	-1.68	223.51	97.26	13.05	1.43	-5.48	6.92	0	6.6	514.4	N/A	0
03:00 to 0	157.33	-3.19	237.52	94.84	12.95	1.5	-4.48	6.99	0	6.7	652.2	N/A	0
04:00 to 0	155.03	-1.89	235.31	97.43	12.85	1.48	-3.59	7.09	0	6.8	724.5	N/A	0
05:00 to 0	143.8	-0.77	219.25	112.68	12.87	1.46	-4.55	7.04	0	6.7	532.2	N/A	0
06:00 to 0	160.01	-0.29	244.52	88.08	12.82	1.47	-4.25	7.13	0	6.8	700.5	N/A	0
07:00 to 0	154.15	0.06	235.91	96.94	12.99	1.46	-4.91	7.02	0	6.7	804.4	N/A	0
08:00 to 0	147.99	-0.16	226.28	111.79	12.97	1.47	-4.85	6.96	0	6.6	580.9	N/A	0
09:00 to 0	149.93	-1.11	228.29	101.64	12.87	1.4	-4.04	7.08	0	6.8	738.8	N/A	0
10:00 to 1	148.46	-0.17	226.97	111.35	12.91	1.43	-3.83	7.09	0	6.8	848	N/A	0
11:00 to 1	125.73	-1.93	190.44	126.92	12.75	3.59	-5.67	7.25	0	6.9	685.8	N/A	0
12:00 to 1	142	-7.37	209.89	124.33	12.85	1.56	-5.15	7.14	0	6.8	813.8	N/A	0
13:00 to 1	141.81	-6.44	210.53	127.03	12.92	1.58	-4.62	7.02	0	6.7	836.7	N/A	0
14:00 to 1	149.43	-1.04	227.58	122.33	12.87	1.51	-4.27	7.08	0	6.8	576.4	N/A	0
15:00 to 1	151.59	1.78	233.72	120.61	12.9	1.44	-3.93	7.11	0	6.8	721.4	N/A	0
16:00 to 1	155.96	-5.35	233.27	115.34	12.86	1.44	-4.37	7.14	0	6.8	765.1	N/A	0
17:00 to 1	158.57	-4.8	237.81	105.73	12.93	1.45	-5.41	7.07	0	6.7	498	N/A	0
18:00 to 1	145.32	-0.07	222.27	143.12	13.05	1.47	-4.19	6.9	0	6.6	654.2	N/A	0
19:00 to 1	141.4	1.56	217.91	120.28	13.13	1.41	-5.4	6.9	0	6.6	745.5	N/A	0
20:00 to 2	144.84	-1.08	220.51	164.09	13.01	1.51	-3.2	6.8	0	6.6	530.7	N/A	0
21:00 to 2	152.84	-0.45	233.4	161.53	12.93	1.5	-3.75	7.01	0	6.8	618.4	N/A	0
22:00 to 2	159.06	-3.26	240.1	157.9	12.91	1.48	-3.63	7.05	0	6.8	675.3	N/A	0
23:00 to 2	137.24	-1.3	208.68	141.72	12.96	2.34	-5.93	7.09	0	6.7	504.4	N/A	0
95 Percenti	160.01	1.56	243.54	161.53	13.05	2.34	-3.59	7.14	0	6.8	836.7	N/A	0
Daily Avera	149.39	-1.96	226.61	117	12.93	1.59	-4.52	7.03	0	6.7	674.4	N/A	0

CDAS 2004

Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	135.49	-2.6	204.7	179.35	12.89	1.48	-3.24	6.99	0	6.8	626	N/A	0
01:00 to 0	135.37	0.67	207.79	203.54	13.01	1.46	-4.2	6.88	0	6.6	713	N/A	0
02:00 to 0	153.39	-0.16	234.54	150.49	12.96	1.41	-4.06	6.95	0	6.7	563.2	N/A	0
03:00 to 0	165	-1.92	250.54	143.86	12.88	1.42	-4.63	7.08	0	6.8	751.2	N/A	0
04:00 to 0	166.17	-2.27	251.98	120.41	12.92	1.39	-4.39	7.02	0	6.7	831.1	N/A	0
05:00 to 0	157.37	-2.17	238.61	125.09	13.01	1.35	-5.66	6.96	0	6.6	580.3	N/A	0
06:00 to 0	154.05	-3.08	232.61	124.67	12.97	1.44	-4.02	6.93	0	6.7	760.4	N/A	0
07:00 to 0	156.69	-3.09	236.65	134.68	13	1.45	-3.86	6.94	0	6.7	827.1	N/A	0
08:00 to 0	155.92	-2.96	235.6	141.33	12.9	1.46	-5.32	7.06	0	6.7	600.1	N/A	0
09:00 to 0	158.53	-6.16	236.39	137.51	12.89	1.46	-4.29	7.06	0	6.8	790.9	N/A	0
10:00 to 1	149.74	-5.19	223.9	134.19	12.87	1.74	-3.07	7.08	0	6.9	859.6	N/A	0
11:00 to 1	138.23	-1.26	210.24	137.96	13.04	3.12	-6.74	7.08	0	6.6	645.6	N/A	0
12:00 to 1	143.42	-3.68	215.76	140.57	13.07	1.4	-4.02	6.91	0	6.7	851.6	N/A	0
13:00 to 1	139.61	-5.41	208.19	156.11	13.06	1.35	-3.48	6.92	0	6.7	887.2	N/A	0
14:00 to 1	149.53	-3.3	225.47	134.29	12.81	1.31	-2.39	6.93	0	6.8	612.6	N/A	0
15:00 to 1	157.05	-7.43	232.85	124.12	12.81	1.37	-1.6	6.9	0	6.8	747.1	N/A	0
16:00 to 1	153.2	-5.73	228.67	118.64	12.89	1.37	-2.62	6.9	0	6.7	797	N/A	0
17:00 to 1	157.08	1.62	241.94	117.13	12.98	1.37	-2.64	6.78	0	6.6	553	N/A	0
18:00 to 1	155.4	3.85	241.61	123.32	13.13	1.37	-3.95	6.81	0	6.6	698.8	N/A	0
19:00 to 1	155.76	3.06	241.36	125.83	13.09	1.43	-3.42	6.83	0	6.6	768.4	N/A	0
20:00 to 2	159.77	-2.24	242.21	121.04	12.93	1.42	-4.15	6.96	0	6.7	531	N/A	0
21:00 to 2	161.58	-4.06	243.16	104.55	12.89	1.42	-3.13	6.98	0	6.8	664.5	N/A	0
22:00 to 2	138.85	-6.41	206.04	147.66	12.83	1.59	-2.98	7.01	0	6.8	711.6	N/A	0
23:00 to 2	137.35	-0.94	209.21	156.31	12.75	1.81	-3.24	7.11	0	6.9	511.9	N/A	0
95 Percent	165	3.06	250.54	179.35	13.09	1.81	-2.39	7.08	0	6.9	859.6	N/A	0
Daily Avera	151.44	-2.54	229.17	137.61	12.94	1.52	-3.8	6.96	0	6.7	703.5	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	126.19	2.99	196.07	193.5	12.95	2.18	-5.02	7.12	0	6.8	675.3	N/A	0
01:00 to 0	138.49	-2.59	209.3	180.15	12.84	1.51	-4.16	7.12	0	6.8	705.8	N/A	0
02:00 to 0	149.65	-2.44	226.53	195.52	12.77	1.43	-4.88	7.15	0	6.8	482.3	N/A	0
03:00 to 0	174.93	0.56	268.2	112.2	12.85	1.44	-3.76	7.08	0	6.8	631.9	N/A	0
04:00 to 0	164	5.67	256.6	109.03	13.08	1.31	-2.13	6.75	0	6.6	796.4	N/A	0
05:00 to 0	158.31	1.09	243.29	110.11	13.03	1.29	-3.73	6.77	0	6.5	592.3	N/A	0
06:00 to 0	157.38	-1.09	239.7	120.83	13.15	1.26	-4.09	6.75	0	6.5	790.5	N/A	0
07:00 to 0	163.28	-4.61	245.21	106.26	13.03	1.3	-4.48	6.84	0	6.5	777.8	N/A	0
08:00 to 0	165.2	1.14	253.9	109.4	12.98	1.34	-4.61	6.91	0	6.6	538.3	N/A	0
09:00 to 0	178.85	3.02	276.66	95.02	12.91	1.43	-3.8	6.98	0	6.7	680.5	N/A	0
10:00 to 1	172.93	0.67	265.25	94.12	12.95	1.41	-3.65	6.94	0	6.7	762.5	N/A	0
11:00 to 1	155.59	-1.44	236.61	113.96	13	1.36	-5.12	6.87	0	6.5	548.4	N/A	0
12:00 to 1	150	-2.56	226.94	164.89	12.84	1.42	-2.43	6.95	0	6.8	729.4	N/A	0
13:00 to 1	144.01	-5.37	214.96	140.87	12.6	4.14	-4.44	7.28	0	7	798.4	N/A	0
14:00 to 1	156.43	0.95	240.29	152	12.76	1.39	-2.99	7.01	0	6.8	561.8	N/A	0
15:00 to 1	150.79	2.56	233.27	148.22	12.99	1.34	-4.41	6.98	0	6.7	756	N/A	0
16:00 to 1	151.92	-5.25	227.2	142.62	13.01	1.37	-4.61	6.92	0	6.6	821.2	N/A	0
17:00 to 1	161.79	-1.49	246.05	124.59	13.05	1.4	-4.88	6.86	0	6.5	563.4	N/A	0
18:00 to 1	171.49	-1.88	260.51	122.17	12.81	1.53	-2.89	7.03	0	6.8	668.3	N/A	0
19:00 to 1	176.14	-3.78	265.7	119.13	12.75	1.58	-2.72	7.07	0	6.9	718.4	N/A	0
20:00 to 2	179.89	-6.65	268.58	98.12	12.75	1.58	-4.26	7.09	0	6.8	541.5	N/A	0
21:00 to 2	168.13	-9.28	247.97	86.32	12.98	1.5	-4.98	6.92	0	6.6	632.4	N/A	0
22:00 to 2	180.94	-18.12	258.71	94.93	12.78	1.72	-1.88	6.92	0	6.8	641.7	N/A	0
23:00 to 2	159.62	1.28	245.5	98.22	12.81	2.66	-3.01	7.07	0	6.9	461.1	N/A	0
95 Percenti	179.89	3.02	268.58	193.5	13.08	2.66	-2.13	7.15	0	6.9	798.4	N/A	0
Daily Avera	160.67	-1.94	243.87	126.34	12.9	1.62	-3.87	6.97	0	6.7	661.5	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	164.6	0.98	252.82	135.24	12.82	1.63	-1.34	7.01	0	6.9	564.5	N/A	0
01:00 to 0	151.46	3.65	235.37	165.67	13.09	1.56	-4.1	6.9	0	6.7	589.6	N/A	0
02:00 to 0	147.24	2.32	227.6	131.06	12.94	1.55	-2.71	6.81	0	6.6	434.7	N/A	0
03:00 to 0	151.83	-1.44	230.87	140.07	13.04	1.51	-3.83	6.74	0	6.5	586.1	N/A	0
04:00 to 0	160.2	0.44	245.54	112.42	12.95	1.56	-4.26	6.87	0	6.6	653.6	N/A	0
05:00 to 0	148.24	1.65	228.45	137.36	12.88	1.66	-3.56	6.88	0	6.7	483.1	N/A	0
06:00 to 0	150.93	6.53	237.45	133.73	12.86	1.66	-2.74	6.96	0	6.8	563.7	N/A	0
07:00 to 0	149.48	9.23	237.93	165.46	12.84	1.71	-2.22	6.97	0	6.8	593.7	N/A	0
08:00 to 0	142.89	2.06	220.67	168.12	12.89	1.61	-3.94	6.95	0	6.7	452.2	N/A	0
09:00 to 0	139.64	-4.75	208.9	158.86	12.83	1.69	-2.82	6.91	0	6.8	539.2	N/A	0
10:00 to 1	147.61	-14.66	211.19	150.4	12.71	1.74	-3.01	7.03	0	6.9	592.7	N/A	0
11:00 to 1	160.25	1.21	246.39	112.11	12.78	1.51	-5.13	7.12	0	6.8	538.1	N/A	0
12:00 to 1	176.84	-11.99	258.57	85.46	12.6	2.55	-2.53	7.13	0	7	591.3	N/A	0
13:00 to 1	179.93	-30.46	244.84	80.95	12.48	3.75	-3.98	7.26	0	7	497.6	N/A	0
14:00 to 1	176.95	-14.71	256.02	86.92	12.87	1.76	-5.09	6.98	0	6.6	370.1	N/A	0
15:00 to 1	190.11	-7.51	283.37	89.71	12.79	1.77	-2.47	6.96	0	6.8	573.4	N/A	0
16:00 to 1	171.72	-5.42	257.32	104.13	12.73	1.88	-1.96	7.02	0	6.9	619.4	N/A	0
17:00 to 1	150.73	-2.65	227.97	128.86	12.64	1.98	-3.01	7.15	0	6.9	395.8	N/A	0
18:00 to 1	164.42	-4.76	246.8	124.45	12.63	2.05	-3.03	7.19	0	7	462.9	N/A	0
19:00 to 1	188.28	-9.44	278.62	87.45	12.76	1.93	-3.42	7.06	0	6.9	509	N/A	0
20:00 to 2	174.14	-3.01	263.41	92.26	12.9	2	-2.93	6.87	0	6.7	374.2	N/A	0
21:00 to 2	178.4	-3.39	269.57	82.78	12.9	1.95	-2.65	6.92	0	6.7	462.9	N/A	0
22:00 to 2	182.15	-1.05	277.64	87.67	12.93	1.95	-2.01	6.89	0	6.7	492.8	N/A	0
23:00 to 2	174.95	-1.73	265.95	94.35	12.47	3.28	-1.17	7.23	0	7.2	344	N/A	0
95 Percenti	188.28	6.53	278.62	165.67	13.04	3.28	-1.34	7.23	0	7	619.4	N/A	0
Daily Avera	163.46	-3.7	246.39	118.98	12.8	1.93	-3.08	6.99	0	6.8	511.9	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	165.97	4.93	258.86	116.14	12.65	2.02	-1.02	7.11	0	7	395.6	N/A	0
01:00 to 0	154.39	6.05	242.28	120.38	12.72	2.02	-0.75	7.03	0	7	434.4	N/A	0
02:00 to 0	146.11	-4.97	218.57	133.2	12.77	1.94	-2.21	6.93	0	6.8	330.3	N/A	0
03:00 to 0	155.58	-7.42	230.62	110.92	12.85	1.94	-1.89	6.88	0	6.8	418	N/A	0
04:00 to 0	166.42	-0.62	253.99	96.17	12.83	1.93	-0.72	6.88	0	6.8	467.1	N/A	0
05:00 to 0	157.03	-3.73	236.52	122.37	12.66	2.02	-1.6	7.05	0	6.9	354.2	N/A	0
06:00 to 0	154.58	-1.86	234.64	129.18	12.67	2.03	-1.94	7.14	0	7	469.8	N/A	0
07:00 to 0	150.47	-1.61	228.62	136.75	12.73	2.01	-2.55	7.13	0	7	534.4	N/A	0
08:00 to 0	149.65	0.34	229.3	126.46	12.77	1.93	-3.2	7.11	0	6.9	407	N/A	0
09:00 to 0	152	6.91	239.47	127.82	12.79	1.9	-1.77	7.06	0	6.9	565	N/A	0
10:00 to 1	153.62	5.05	240.08	121.55	12.78	1.82	-2.82	7.1	0	6.9	618.5	N/A	0
11:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.14	0	N/A	N/A	N/A	0
12:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.15	0	N/A	N/A	N/A	0
13:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.01	0	N/A	N/A	N/A	0
14:00 to 1	152.26	-1.3	231.66	103.16	12.62	4.86	-3.07	7.21	0	7	78.7	N/A	0
15:00 to 1	157.58	-2.12	238.99	120.13	12.77	1.75	-3	7.14	0	6.9	192	N/A	0
16:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.22	0	N/A	N/A	N/A	0
17:00 to 1	166.25	-7.77	246.6	121.5	12.68	1.64	-4.94	7.27	0	6.9	175.6	N/A	0
18:00 to 1	162.43	-2.31	246.2	127.78	12.63	1.77	-2.12	7.26	0	7.1	314.9	N/A	0
19:00 to 1	170.09	6.4	266.64	101.26	12.84	1.65	-2.16	7.1	0	7	418.3	N/A	0
20:00 to 2	184.45	2.68	284.89	92.75	12.78	1.68	-2.48	6.98	0	6.8	363.4	N/A	0
21:00 to 2	176.09	1.9	271.31	103.48	12.83	1.72	-1.38	6.9	0	6.8	490.3	N/A	0
22:00 to 2	158.87	2.08	245.16	148.29	12.67	1.85	0.34	6.97	0	7	588.4	N/A	0
23:00 to 2	168.12	0.71	257.93	119.01	12.53	2.53	-2.64	7.23	0	7.1	455.6	N/A	0
95 Percent	184.45	6.91	284.89	148.29	12.85	4.86	0.34	7.26	0	7.1	618.5	N/A	0
Daily Avera	160.1	0.17	245.12	118.91	12.73	2.05	-2.1	7.08	0	6.9	403.6	N/A	0

CDAS 2004

Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	165.2	-5.17	247.59	115.89	12.67	1.76	-1.52	7.03	0	6.9	522.3	N/A	0
01:00 to 0	163.94	-17.25	233.58	117.54	12.65	1.8	-1.35	6.95	0	6.9	536.3	N/A	0
02:00 to 0	151.01	-5.75	225.3	152.09	12.77	1.84	-1.85	6.93	0	6.8	368.6	N/A	0
03:00 to 0	156.75	-6.32	233.51	152.15	12.63	1.88	-1.88	7.11	0	7	449.4	N/A	0
04:00 to 0	153.2	-6.16	228.24	188.36	12.53	1.97	-1.12	7.14	0	7.1	478.9	N/A	0
05:00 to 0	149.53	-2.76	226.02	178.52	12.54	1.96	-1.32	7.13	0	7	345.4	N/A	0
06:00 to 0	150.13	-5.78	223.91	165.22	12.63	1.99	-0.83	7.06	0	7	417.3	N/A	0
07:00 to 0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.04	0	N/A	N/A	N/A	0
08:00 to 0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.98	0	N/A	N/A	N/A	0
09:00 to 0	149.53	8.7	237.48	155.05	12.87	1.46	-2.16	6.93	0	6.8	230.6	N/A	0
10:00 to 1	147.61	14.09	239.94	198.22	12.96	1.35	-1.35	6.89	0	6.8	455.8	N/A	0
11:00 to 1	185.68	6.23	290.32	174.21	12.69	2.03	-0.84	7.01	0	7.1	473.4	N/A	0
12:00 to 1	153.91	0.85	236.33	144.02	12.77	4.47	-1.46	7.03	0	6.9	738.1	N/A	0
13:00 to 1	169.25	-5.72	253.22	118	12.94	1.54	-2.21	6.83	0	6.7	729.8	N/A	0
14:00 to 1	164.8	2.08	254.23	114.13	12.91	1.48	-2.13	6.81	0	6.7	493.2	N/A	0
15:00 to 1	163.34	5.11	255.01	127	12.82	1.54	-0.62	6.9	0	6.9	651.6	N/A	0
16:00 to 1	150.68	3.61	234.16	141.62	12.85	1.59	-1.24	6.92	0	6.8	691.6	N/A	0
17:00 to 1	150.18	-1.69	228.08	113.16	12.81	1.56	-3.02	6.98	0	6.8	466.7	N/A	0
18:00 to 1	163.04	-5.14	244.3	109.25	12.86	1.69	-0.57	6.87	0	6.8	534	N/A	0
19:00 to 1	164.73	-1.46	250.57	100.22	12.97	1.74	1.21	6.67	0	6.7	579.7	N/A	0
20:00 to 2	167.94	-3.87	253.07	112.48	12.74	1.77	-0.25	6.86	0	6.9	408.5	N/A	0
21:00 to 2	168.2	1.39	258.75	117.05	12.78	1.76	1.29	6.82	0	6.9	540.9	N/A	0
22:00 to 2	178.43	5.67	278.67	123.26	12.66	1.97	4.19	6.77	0	7	634.6	N/A	0
23:00 to 2	163.74	0.28	250.79	89.77	12.79	2.49	1	6.75	0	6.8	460.4	N/A	0
95 Percent	178.43	8.7	278.67	188.36	12.96	2.49	1.29	7.13	0	7.1	729.8	N/A	0
Daily Avera	160.49	-0.87	244.68	136.69	12.76	1.89	-0.82	6.93	0	6.9	509.4	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	154.11	-0.42	235.37	116.38	12.94	1.65	-0.01	6.68	0	6.7	601.7	N/A	0
01:00 to 0	153.94	-3.17	232.35	114.98	12.96	1.59	-1.66	6.8	0	6.7	662.4	N/A	0
02:00 to 0	169.54	-2.88	256.53	110.58	12.78	1.65	-3.09	7.01	0	6.8	435.8	N/A	0
03:00 to 0	159.66	-3.03	241.24	142.42	12.85	1.67	-2.87	6.97	0	6.8	550.8	N/A	0
04:00 to 0	155.42	-3.35	234.43	145.86	12.81	1.67	-2.2	6.98	0	6.8	600.3	N/A	0
05:00 to 0	151.16	-4.77	226.5	123.88	12.84	1.64	-2.97	6.94	0	6.7	422.8	N/A	0
06:00 to 0	147.32	-3.18	222.21	153.19	12.92	1.7	-2.6	6.89	0	6.7	560.4	N/A	0
07:00 to 0	147.32	1.32	226.72	150.36	12.95	1.67	-1.73	6.84	0	6.7	654.1	N/A	0
08:00 to 0	147.58	-7.18	218.63	137.77	12.89	1.7	-2.3	6.87	0	6.7	447.7	N/A	0
09:00 to 0	151.23	-8.77	222.61	136.09	12.74	1.75	-2.24	7	0	6.9	561	N/A	0
10:00 to 1	151.97	-2.1	230.41	117.43	12.81	1.61	-3	6.99	0	6.8	648.1	N/A	0
11:00 to 1	141.85	1.03	218.06	136.73	12.89	1.53	-2.86	6.88	0	6.7	520.3	N/A	0
12:00 to 1	146.71	-1.05	223.41	136.53	12.96	1.46	-3.06	6.84	0	6.6	705	N/A	0
13:00 to 1	155.67	-1.72	236.46	138.78	12.71	1.79	0.11	6.92	0	6.9	788.3	N/A	0
14:00 to 1	159.4	-0.67	243.22	138.62	12.72	3.66	-1.87	6.97	0	6.8	568.2	N/A	0
15:00 to 1	177.6	-1.08	270.65	110.45	12.73	1.61	-1.41	6.96	0	6.9	728.9	N/A	0
16:00 to 1	174.91	-0.5	267.11	104.17	12.8	1.54	-2.22	6.94	0	6.8	798.2	N/A	0
17:00 to 1	160.59	7.24	252.94	133.87	12.88	1.48	-2.52	6.88	0	6.7	542	N/A	0
18:00 to 1	151.26	8.34	239.76	159.83	12.97	1.48	-1.43	6.77	0	6.7	701.7	N/A	0
19:00 to 1	153.61	10.15	245.18	167.92	12.88	1.54	-0.73	6.83	0	6.8	810	N/A	0
20:00 to 2	153.4	0.34	235.05	152.16	12.66	1.48	-0.62	6.83	0	6.8	606.7	N/A	0
21:00 to 2	154.98	-4.83	232.28	146.22	12.59	1.54	-0.92	6.96	0	6.9	749.1	N/A	0
22:00 to 2	155.69	-4.21	234	138.77	12.71	1.49	-2.18	6.95	0	6.8	811.3	N/A	0
23:00 to 2	151.72	-0.34	231.8	174.94	12.62	1.89	-1.58	6.96	0	6.8	571.3	N/A	0
95 Percenti	174.91	8.34	267.11	167.92	12.96	1.89	-0.01	7	0	6.9	810	N/A	0
Daily Avera	155.28	-1.04	236.54	137	12.82	1.7	-1.91	6.9	0	6.8	626.9	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	154.93	-0.33	236.71	150.86	12.68	2.14	-3.23	7.03	0	6.8	734	N/A	0
01:00 to 0	171.14	2.33	264.17	151.51	12.72	1.43	-1.94	6.9	0	6.8	810.4	N/A	0
02:00 to 0	168.66	-15.79	242.26	175.93	12.43	1.59	-2.98	7.04	0	6.9	501.4	N/A	0
03:00 to 0	159.98	-29.87	214.89	168.47	12.43	1.75	-1.89	7	0	6.9	589.3	N/A	0
04:00 to 0	156.59	-24.47	215.11	171.97	12.44	1.72	-3.01	7.06	0	6.9	601.1	N/A	0
05:00 to 0	156.42	-11.38	227.94	144.22	12.74	1.64	-3.76	6.91	0	6.7	457.8	N/A	0
06:00 to 0	149.63	-6.96	221.97	191.01	12.7	1.87	-1.08	6.92	0	6.9	603.5	N/A	0
07:00 to 0	151.01	-13.33	217.72	209.69	12.51	1.93	-1.36	7.13	0	7	679.4	N/A	0
08:00 to 0	146.06	3.04	226.52	273.33	12.44	2.01	-1.26	7.17	0	7.1	419.3	N/A	0
09:00 to 0	142	11.36	228.62	213.13	12.71	1.68	-2.92	7.1	0	6.9	599.3	N/A	0
10:00 to 1	142.2	12.19	229.75	182.3	12.75	1.68	-1.98	7.04	0	6.9	577.7	N/A	0
11:00 to 1	147.12	4.26	229.36	131.15	12.89	1.55	-4.5	6.89	0	6.6	499.7	N/A	0
12:00 to 1	157.47	2.27	243.2	119.85	12.86	1.62	-2.42	6.85	0	6.7	621	N/A	0
13:00 to 1	175.16	-8.54	259.45	113.05	12.58	1.81	-1.36	7.02	0	6.9	561.2	N/A	0
14:00 to 1	159.58	-8.14	236.02	105.99	12.34	4.83	-1.31	7.2	0	7.1	421.3	N/A	0
15:00 to 1	164.9	-17.44	234.86	108.57	12.63	1.74	-3.52	7.02	0	6.8	529.3	N/A	0
16:00 to 1	157.12	-8.4	231.99	122.62	12.69	1.66	-2.48	6.92	0	6.8	623.9	N/A	0
17:00 to 1	144.59	-2.15	219.07	171.2	12.79	1.69	-2.15	6.81	0	6.7	444.6	N/A	0
18:00 to 1	155.84	-2.14	236.3	155.93	12.7	1.72	-2.72	7.03	0	6.9	607.5	N/A	0
19:00 to 1	156.47	-7.99	231.41	161.05	12.62	1.72	-1.98	7.07	0	6.9	641.2	N/A	0
20:00 to 2	148.83	9.3	237.01	163.89	12.59	1.7	-2.43	7.14	0	7	479.9	N/A	0
21:00 to 2	147.16	15	240.17	154.81	12.67	1.66	-2.57	7.16	0	7	594.7	N/A	0
22:00 to 2	167.71	5.83	262.42	123.99	12.66	1.71	-1.61	7.07	0	7	619.1	N/A	0
23:00 to 2	165.15	-0.17	252.51	116.04	12.52	2.71	-2.23	7.14	0	7	487.3	N/A	0
95 Percenti	171.14	12.19	262.42	213.13	12.86	2.71	-1.26	7.17	0	7.1	734	N/A	0
Daily Avera	156.07	-3.81	234.98	157.52	12.63	1.9	-2.36	7.03	0	6.9	571	N/A	0

CDAS 2004
Report prin

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta	O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio
00:00 to 0	170.87	-1.39	260.05	129.95	12.68	1.7	-3.2	7.09	0	6.9	625	N/A	0
01:00 to 0	160.39	-11.72	233.67	164.88	12.52	1.78	-0.76	7.13	0	7.1	615.5	N/A	0
02:00 to 0	156.41	1.39	240.7	158.63	12.52	1.73	-2.37	7.22	0	7.1	476.5	N/A	0
03:00 to 0	159.81	-2.72	241.8	155.79	12.59	1.74	-2.9	7.15	0	7	547.3	N/A	0
04:00 to 0	163.42	-12.59	237.44	143.69	12.63	1.82	-2.76	7.04	0	6.9	554.2	N/A	0
05:00 to 0	159.39	2.93	246.79	164.91	12.56	1.79	-1.63	7.04	0	7	447.6	N/A	0
06:00 to 0	145.7	1.63	224.56	204.69	12.47	1.9	-2.01	7.27	0	7.1	502.1	N/A	0
07:00 to 0	149.48	5.07	233.77	179.23	12.56	1.74	-2.4	7.2	0	7	553.9	N/A	0
08:00 to 0	153.84	-3.84	231.54	167.78	12.61	1.7	-2.57	7.12	0	7	442	N/A	0
09:00 to 0	156.21	0.79	239.79	196.15	12.68	1.66	-1.87	7.07	0	7	594.6	N/A	0
10:00 to 1	155.14	-5.3	232.06	153.35	12.84	1.61	-4.11	6.99	0	6.7	617.2	N/A	0
11:00 to 1	152.42	2.27	235.47	150.32	12.84	1.47	-3.47	6.91	0	6.7	569.3	N/A	0
12:00 to 1	138.25	-4	207.52	179.58	12.64	4.3	-3.74	7.19	0	6.9	671.5	N/A	0
13:00 to 1	145.36	-5.72	216.68	199.26	12.63	1.71	-2.02	7.07	0	6.9	710.3	N/A	0
14:00 to 1	149.48	8.86	237.57	165.66	12.73	1.63	-3.03	7.08	0	6.9	459.6	N/A	0
15:00 to 1	159.75	15.57	259.99	158.05	13.04	1.47	-4.41	6.87	0	6.6	638.8	N/A	0
16:00 to 1	163.61	10.46	260.78	169.19	12.97	1.64	-1.4	6.76	0	6.7	626.5	N/A	0
17:00 to 1	153.8	2.21	237.53	203.88	12.7	1.72	-1.45	6.94	0	6.9	429.6	N/A	0
18:00 to 1	150.3	-8.34	221.62	182.5	12.62	1.83	-0.1	6.94	0	6.9	480.7	N/A	0
19:00 to 1	145.28	2.16	224.43	183.72	12.78	1.75	-0.31	6.77	0	6.8	590.4	N/A	0
20:00 to 2	157.85	6.05	247.56	152.8	12.83	1.72	2	6.56	0	6.7	473.8	N/A	0
21:00 to 2	159.69	9.22	253.55	168.42	12.86	1.69	-0.58	6.75	0	6.7	619.3	N/A	0
22:00 to 2	156.27	6.6	245.69	172.92	12.78	1.74	-0.67	6.87	0	6.8	667.4	N/A	0
23:00 to 2	147.49	-5.84	219.83	141.6	12.44	3.03	-2.54	7.15	0	7	402.9	N/A	0
95 Percenti	163.61	10.46	260.05	203.88	12.97	3.03	-0.1	7.22	0	7.1	671.5	N/A	0
Daily Avera	154.59	0.57	237.1	168.62	12.69	1.87	-2.01	7.01	0	6.9	554.8	N/A	0

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	81.78	140.02	1001.32	17.29
0	85.06	147.33	1000.96	18.31
0	85.54	150.24	1000.94	18.54
0	83.77	149.32	1000.84	18.12
0	83.32	147.65	1000.47	17.96
0	85.21	148.75	1000.26	18.42
0	85.14	149.79	1000.3	18.45
0	85.91	150.37	1000.86	18.63
0	85.68	150.12	1001.84	18.55
0	84.03	149.33	1002.72	18.14
0	82.5	148.4	1004.24	17.75
0	82.83	147.58	1005.14	17.77
0	81.47	146.89	1005.34	17.44
0	80.42	145.42	1005.22	17.16
0	79.99	143.76	1005.92	16.99
0	81.43	143.8	1006.85	17.28
0	82.48	144.91	1007.45	17.54
0	82.83	146.25	1008.22	17.66
0	82.15	145.89	1008.2	17.5
0	81.58	145.09	1008.17	17.34
0	81.13	144.64	1007.99	17.23
0	80.84	144.51	1007.97	17.17
0	80.96	144.57	1008.18	17.19
0	82.22	144.75	1007.1	17.48
0	85.68	150.24	1008.2	18.55
0	82.84	146.64	1004.44	17.75

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	81.19	144.12	1005.27	17.27
0	78.97	143.59	1003.02	16.82
0	82.44	144.73	1000.57	17.64
0	82.05	145.95	999.96	17.62
0	82.11	146.35	1000.5	17.64
0	82.03	146.92	1001.06	17.64
0	82.68	146.5	1002.22	17.74
0	82.97	146.73	1003.14	17.8
0	81.77	147.05	1004.62	17.53
0	81.43	146.42	1005.8	17.41
0	81.86	146.56	1006.93	17.49
0	82	147.06	1007.46	17.53
0	83.36	146.8	1008.1	17.8
0	82.68	144.91	1008.14	17.57
0	81.31	145.22	1008.05	17.29
0	81.76	145.27	1008.13	17.39
0	83.36	146.3	1008.29	17.77
0	83.58	147.63	1008.14	17.88
0	81.84	147.13	1008.2	17.48
0	81.44	146.47	1008.22	17.37
0	82.26	146.44	1008.1	17.55
0	81.84	146.12	1008.18	17.44
0	81.91	146.38	1008.36	17.46
0	83.19	147	1008.46	17.76
0	83.36	147.13	1008.36	17.8
0	82.08	146.15	1005.79	17.54

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	83.18	146.41	1009.47	17.72
0	82.01	147.3	1010.02	17.5
0	85.28	147.98	1010.98	18.21
0	84.51	149.17	1011.35	18.08
0	84.33	148.73	1011.68	18.02
0	84.2	148.75	1011.94	17.99
0	81.58	147.81	1011.96	17.39
0	81.75	147.15	1011.96	17.4
0	83.38	147.65	1012.66	17.76
0	86.53	150.46	1013.21	18.54
0	86.77	151.01	1013.58	18.61
0	87.65	151.74	1013.48	18.83
0	90.79	152.56	1013.08	19.55
0	91.77	152.78	1012.74	19.78
0	91.76	152.58	1012.06	19.78
0	92.68	152.84	1012.06	19.99
0	90.53	152.25	1011.86	19.5
0	89.55	151.2	1011.71	19.25
0	88.95	150.38	1012.04	19.08
0	87.1	149.52	1012.35	18.64
0	90.45	151.79	1013.08	19.44
0	88.56	151.09	1013.68	18.99
0	89.43	150.97	1014.18	19.16
0	89.59	150.71	1014.61	19.18
0	91.77	152.78	1014.18	19.78
0	87.18	150.12	1012.32	18.68

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	87.76	149.78	1014.84	18.74
0	88.74	149.59	1015.24	18.94
0	90.86	151.77	1015.35	19.49
0	90.44	152.06	1015.68	19.4
0	91.24	152.18	1016.56	19.56
0	89.48	151.74	1017.98	19.14
0	89.04	150.75	1018.66	18.99
0	88.59	150.27	1019.55	18.85
0	90.61	151.47	1020.34	19.32
0	90.11	151.67	1021.87	19.2
0	87.83	151.17	1023.03	18.67
0	88.78	150.61	1023.98	18.83
0	87.96	150.2	1025.37	18.61
0	90.02	151.71	1026.34	19.1
0	92.78	152.45	1026.87	19.71
0	90.64	150.08	1027.41	19.13
0	89.6	150.17	1027.82	18.91
0	89.43	149.42	1029.39	18.81
0	90.45	150.23	1030.94	19.04
0	90.72	150.99	1031.87	19.11
0	89.23	150.44	1032.95	18.75
0	88.93	150.07	1033.03	18.67
0	89.43	150.17	1033.36	18.77
0	89.59	150.16	1033.36	18.81
0	91.24	152.18	1033.36	19.56
0	89.68	150.8	1024.24	19.02

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	88.46	148.98	1034.06	18.51
0	87.89	148.55	1034.76	18.36
0	88.35	149.18	1034.93	18.48
0	88.97	149.47	1034.89	18.62
0	88.06	149.4	1034.92	18.42
0	88.6	149.05	1034.81	18.52
0	87.98	149.25	1034.78	18.4
0	86.96	148.95	1034.81	18.18
0	88.37	149.85	1035.01	18.51
0	88.55	149.55	1036.43	18.51
0	88.24	149.48	1038.07	18.41
0	88.74	150.04	1038.93	18.52
0	88.19	150.43	1039.24	18.42
0	89.3	150.34	1036.92	18.69
0	N/A	N/A	N/A	N/A
0	88.51	148.76	1034.23	18.51
0	87.8	148.94	1033.71	18.37
0	88.65	149.25	1033.33	18.57
0	87.47	148.81	1032.96	18.31
0	86.63	148.42	1032.85	18.12
0	88.1	148.73	1032.48	18.45
0	87.39	148.98	1032.13	18.32
0	87.83	148.27	1031.82	18.38
0	87.7	148.01	1031.6	18.35
0	88.97	150.34	1038.93	18.62
0	88.12	149.16	1034.68	18.43

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	86.84	148.19	1031.07	18.19
0	87.05	148.43	1030.41	18.25
0	85.39	148.07	1030.04	17.89
0	86.06	148.33	1029.4	18.06
0	86.85	148.92	1029.01	18.25
0	86.66	149.31	1028.58	18.24
0	86.85	149.25	1028.38	18.28
0	87.24	149.27	1028.35	18.36
0	87.88	150.44	1027.96	18.56
0	87.99	150.54	1028.65	18.57
0	87.36	150.58	1029.61	18.42
0	88	150.09	1029.12	18.55
0	86.07	147.6	1029.18	18.03
0	85.08	147.11	1027.67	17.83
0	85.42	147.51	1026.63	17.94
0	84.75	147.58	1026.24	17.8
0	84.51	147.85	1025.34	17.78
0	84	147.82	1024.57	17.69
0	84.99	148.27	1024.02	17.93
0	85.49	148.11	1023.94	18.03
0	83.17	147.69	1023.98	17.52
0	83.49	147.58	1023.21	17.59
0	84.94	148.57	1022.65	17.95
0	86.45	149.8	1021.77	18.34
0	87.99	150.54	1030.41	18.56
0	85.94	148.62	1027.07	18.09

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	85.15	148.47	1020.88	18.02
0	84.64	146.55	1019.26	17.86
0	82.55	145.68	1018.11	17.4
0	81.71	145.49	1017.54	17.23
0	86.97	147.87	1017.23	18.45
0	84.2	148.79	1015.86	17.92
0	84.52	148.75	1015.53	17.99
0	83.19	147.87	1015.46	17.67
0	83.21	147.74	1013.72	17.7
0	83.13	148.38	1013.5	17.72
0	82.92	148.34	1013.91	17.67
0	83.56	148.72	1012.98	17.83
0	83.8	147.56	1013.31	17.83
0	83.3	146.01	1012.24	17.68
0	82.18	146.55	1010.58	17.49
0	82.85	146.84	1010.04	17.65
0	82.8	146.93	1009.01	17.67
0	82.31	147.49	1008.22	17.6
0	83.58	147.97	1008.57	17.88
0	82.75	148.41	1008.98	17.72
0	83.23	149.09	1008.34	17.86
0	82.71	149.11	1007.97	17.76
0	82.57	149.15	1007.94	17.73
0	84.95	148.7	1008.28	18.21
0	85.15	149.11	1019.26	18.21
0	83.45	147.77	1012.81	17.77

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	82.92	148.68	1008.84	17.77
0	83.53	149.07	1009.73	17.9
0	83.44	149.1	1009.96	17.88
0	83.44	149.17	1009.85	17.88
0	83.52	149.71	1010.11	17.92
0	85.32	150.35	1010.44	18.32
0	83.95	150.34	1011.07	18.02
0	84.16	150.11	1011.87	18.04
0	84.31	150.55	1012.73	18.08
0	84.38	151.04	1013.44	18.1
0	84.38	151.18	1014.67	18.08
0	84.44	151.31	1015.65	18.08
0	86.51	151.63	1015.83	18.54
0	83.87	148.76	1014.43	17.88
0	85.24	148.97	1013.69	18.19
0	85.3	149.31	1012.94	18.23
0	84.32	149.41	1011.71	18.05
0	85.51	149.99	1010.55	18.35
0	85.03	149.89	1009.9	18.25
0	85.4	150.32	1009.17	18.37
0	85.48	150.76	1008.32	18.42
0	84.39	150.33	1006.93	18.19
0	85.11	150.69	1004.45	18.4
0	85.81	150.92	1002.68	18.6
0	85.81	151.31	1015.65	18.54
0	84.57	150.07	1010.79	18.15

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	85.07	150.46	1000.85	18.45
0	85.4	151.28	1000.58	18.56
0	84.56	151.73	1000.42	18.41
0	85.19	152.13	998.79	18.59
0	84.8	152.14	996.96	18.54
0	85.87	153.56	995.68	18.86
0	85.78	153.91	994.37	18.88
0	86.27	153.9	993.74	19
0	87.65	154.95	991.58	19.39
0	88.96	156.2	991.03	19.75
0	89.56	156.92	989.85	19.94
0	87.94	156.62	987.6	19.61
0	86.81	155.78	986.02	19.35
0	89.03	155.19	985.24	19.84
0	86.15	151.36	984.81	19.03
0	86.13	150.74	985.11	18.99
0	89.11	152.45	985.08	19.73
0	87.92	152.92	985.33	19.48
0	86.33	152.25	986.08	19.09
0	84.4	150.53	986.87	18.57
0	83.48	149.94	987.58	18.33
0	83.48	149.77	988.32	18.31
0	83.21	149.56	988.48	18.23
0	86.63	150.58	988.55	19.03
0	89.11	156.62	1000.58	19.84
0	86.24	152.7	990.79	19

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	87.37	151.13	990.11	19.19
0	85.57	151.67	992.01	18.78
0	83.31	149.59	994	18.16
0	84.2	149.71	995.25	18.33
0	88.71	152.25	996.17	19.41
0	86.17	152.22	997.29	18.83
0	89.66	153.76	998.11	19.65
0	87.17	153.83	998.22	19.11
0	87.57	153.55	998.61	19.17
0	88.5	153.9	998.69	19.39
0	90.26	155.88	998.06	19.89
0	92.43	157.69	996.56	20.48
0	90.98	155.61	996.14	20.07
0	87.66	151.83	995.15	19.18
0	90.48	152.44	994.35	19.84
0	89.29	153.19	994.32	19.62
0	87.34	151.73	995.07	19.11
0	85.91	150.54	996.4	18.72
0	85.55	150.28	997.43	18.61
0	86.4	150.74	998.15	18.8
0	87.42	151.06	998.69	19.03
0	86.55	150.62	999.11	18.81
0	86.43	150.78	999.77	18.78
0	85.91	150.65	1000.3	18.65
0	90.98	155.88	999.77	20.07
0	87.54	152.28	996.58	19.15

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	86.84	149.85	1001.4	18.8
0	86.65	149.66	1002.22	18.73
0	86.41	150.36	1002.52	18.71
0	85.25	149.88	1002.55	18.43
0	86.02	149.65	1003.33	18.58
0	84.86	149.46	1003.71	18.31
0	85.21	150.05	1004.08	18.4
0	87.76	150.83	1004.25	18.99
0	88.67	151.43	1004.75	19.2
0	89.68	152.98	1005.59	19.48
0	90.92	153.82	1006.51	19.77
0	91.93	154.28	1007.66	19.99
0	92.05	154.43	1008.33	20
0	90.16	152.03	1008.37	19.48
0	86.86	150.34	1008.37	18.7
0	87.59	149.47	1009	18.8
0	88.92	150.47	1009.27	19.13
0	89.51	151.49	1009.37	19.3
0	88.96	151.76	1009.37	19.19
0	89.62	151.45	1009.33	19.32
0	89.05	151.36	1009.14	19.2
0	90.65	153.06	1009.95	19.6
0	89.28	152.29	1010.27	19.27
0	88.51	152.02	1010.44	19.09
0	91.93	154.28	1010.27	19.99
0	88.39	151.35	1006.66	19.1

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	88.63	151.15	1010.95	19.06
0	88.07	151.14	1010.99	18.94
0	89.44	152.49	1010.75	19.3
0	89.45	152.27	1010.97	19.29
0	86.9	151.21	1011.23	18.69
0	86.87	150.82	1011.79	18.65
0	86.76	150.65	1011.95	18.62
0	87.72	150.89	1012.35	18.83
0	88.02	151.73	1013.05	18.92
0	85.98	150.89	1014.02	18.42
0	86.4	151.13	1014.66	18.51
0	85.56	150.55	1014.7	18.31
0	84.95	150.3	1014.23	18.17
0	85.91	149.09	1013.51	18.35
0	83.14	145.25	1013.04	17.6
0	84.99	146.36	1012.75	18.04
0	87.56	149.66	1012.01	18.75
0	N/A	N/A	N/A	N/A
0	86.35	150.38	1009.42	18.57
0	85.22	149.4	1008.29	18.3
0	84.4	149.33	1006.66	18.15
0	84.85	149.7	1005.02	18.29
0	86.4	149.89	1002.99	18.68
0	86.55	150.13	999.62	18.78
0	89.44	152.27	1014.66	19.29
0	86.53	150.19	1010.65	18.58

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	84.91	150.01	996.5	18.48
0	85.38	149.86	993.6	18.63
0	85.18	150.49	992.21	18.64
0	86.07	150.99	991.22	18.87
0	66.48	144.53	989.92	14.39
0	74.34	138.28	989.11	15.86
0	85.04	148.31	987.81	18.6
0	85.45	150.9	987.34	18.81
0	85.38	152.13	987.25	18.85
0	85.28	152.65	987.83	18.84
0	86	152.61	989.01	18.97
0	86.05	152.8	991.34	18.95
0	86.59	152.8	992.3	19.05
0	88.99	153.08	993.98	19.56
0	87.51	150.6	996.58	19.07
0	86.99	150.65	997.94	18.93
0	87.17	150.29	999.98	18.92
0	85.67	150.35	1002.3	18.55
0	84.98	149.87	1004.25	18.34
0	84.98	149.38	1006.21	18.29
0	84.84	149.04	1008.06	18.21
0	84.71	148.81	1008.44	18.16
0	85.98	148.45	1010.11	18.39
0	88.85	150.81	1011.08	19.09
0	88.85	152.8	1010.11	19.09
0	84.7	149.9	996.43	18.43

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	87.35	151.25	1012.06	18.77
0	86.39	150.85	1012.38	18.54
0	85.61	149.7	1012.89	18.32
0	81.72	147.69	1013.24	17.39
0	85.65	149.4	1013.4	18.3
0	85.15	149.88	1013.03	18.22
0	86.33	150.77	1013.3	18.51
0	85.92	151.03	1014.15	18.42
0	85	151.38	1013.89	18.24
0	86.47	151.29	1013.97	18.55
0	85.5	151.61	1013.87	18.36
0	84.88	151.26	1013.64	18.21
0	83.29	150.11	1012.98	17.83
0	85.97	150.55	1012.13	18.44
0	83.34	147.27	1012.2	17.74
0	83.36	146.75	1011.93	17.73
0	83.7	147.42	1011.82	17.83
0	82.69	147.6	1011.97	17.62
0	82.81	147.89	1012.43	17.65
0	83.8	148.06	1012.24	17.87
0	83.09	148.44	1012.09	17.74
0	83.54	148.46	1011.99	17.84
0	84.31	148.85	1011.92	18.02
0	83.99	148.88	1012	17.95
0	86.47	151.38	1013.97	18.55
0	84.58	149.43	1012.73	18.09

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	85.54	148.38	1011.67	18.26
0	83.72	149.01	1010.78	17.92
0	84.78	149.55	1009.04	18.2
0	84.44	149.88	1007.64	18.17
0	85.04	150.4	1006.38	18.34
0	84.3	150.43	1005.76	18.19
0	82.73	149.19	1004.44	17.83
0	83.25	149.02	1003.24	17.95
0	85.48	150.34	1002.69	18.5
0	84.87	150.45	1001.92	18.39
0	86.12	150.84	1001.02	18.69
0	83.06	150.7	999.28	18.05
0	82.67	149.5	998.44	17.93
0	84.79	149.56	996.66	18.43
0	83.31	147.59	994.3	18.07
0	84.28	148.01	993.07	18.32
0	83.27	148.06	992.37	18.11
0	81.99	147.99	993.43	17.81
0	83.37	148.18	994.56	18.1
0	84.83	149.11	994.76	18.45
0	84.83	149.39	994.34	18.47
0	84.77	149.37	992.52	18.49
0	83.61	148.88	990.87	18.25
0	87.51	150.52	990.26	19.19
0	86.12	150.7	1010.78	18.69
0	84.27	149.35	999.56	18.26

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	86.06	150.33	990.07	18.86
0	87.26	151.19	989.2	19.18
0	86.9	151.51	987.52	19.15
0	85.6	150.47	986.9	18.83
0	85.39	150.33	987.57	18.76
0	87.77	151.49	988.82	19.32
0	86.53	152.21	988.99	19.07
0	87.15	151.52	990.09	19.16
0	86.31	152.43	990.43	19.01
0	86.44	151.52	990.88	18.98
0	89.12	153.3	990.67	19.66
0	89.62	154.16	991	19.8
0	89.22	153.65	990.48	19.7
0	90.97	153.88	990.89	20.09
0	87.27	149.66	991.92	19.06
0	89.08	150.53	993.34	19.47
0	89.62	151.92	993.86	19.64
0	89.04	152.12	994.7	19.51
0	88.78	151.27	995.35	19.4
0	85.29	149.78	996.3	18.56
0	84.74	148.54	997.96	18.35
0	85.51	148.76	998.72	18.51
0	85.48	148.8	1000.22	18.48
0	86.17	148.95	1001.21	18.62
0	89.62	153.88	1000.22	19.8
0	87.3	151.18	992.38	19.13

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	83.61	147.38	1002.42	17.97
0	85.79	149.36	1002.41	18.53
0	86.71	149.91	1002.37	18.75
0	86.81	150.94	1000.97	18.85
0	88	151.28	1001.8	19.11
0	85.5	150.69	1001.64	18.54
0	85.61	149.46	1001.49	18.51
0	88.41	151.49	1002	19.2
0	85.96	151.46	1002.43	18.66
0	86.43	151.7	1003.51	18.75
0	85.53	150.75	1005.08	18.49
0	84.82	150.61	1007.19	18.29
0	88.53	151.34	1008.35	19.1
0	84.89	148.37	1008.4	18.19
0	85.31	147.34	1009.06	18.22
0	87.04	148.21	1010.19	18.6
0	89.09	149.92	1010.53	19.12
0	87.56	149.73	1011.43	18.76
0	86.11	149.16	1012.51	18.41
0	84.21	147.86	1013.69	17.92
0	86.73	148.92	1013.71	18.51
0	87.11	149.87	1014.5	18.61
0	86.23	149.91	1015.33	18.41
0	87.07	148.93	1015.49	18.55
0	88.53	151.49	1015.33	19.12
0	86.38	149.77	1007.35	18.59

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	85.76	148.27	1015.81	18.23
0	85.57	148.79	1015.6	18.22
0	87.91	150.24	1015.68	18.78
0	86.07	149.76	1015.65	18.37
0	85.35	149.2	1015.69	18.19
0	86.08	149.69	1016.06	18.36
0	85.28	150.13	1016.39	18.2
0	86.32	150.67	1016.45	18.44
0	87.46	151.69	1016.53	18.73
0	88.68	152.69	1016.81	19.03
0	89.23	153.57	1016.96	19.19
0	88.52	153.57	1016.6	19.04
0	89.23	153.62	1016.57	19.2
0	89.54	152.55	1015.36	19.24
0	86.59	149.32	1014.26	18.48
0	84.88	148.5	1012.67	18.11
0	85.52	148.14	1012.8	18.23
0	85.02	148.26	1012.58	18.13
0	86.49	148.53	1012.47	18.46
0	89.06	150.47	1013.6	19.07
0	86.47	150.33	1014.25	18.5
0	85.69	150.09	1015.22	18.31
0	84.59	148.48	1015.47	18
0	86.97	148.38	1015.9	18.49
0	89.23	153.57	1016.81	19.2
0	86.76	150.21	1015.22	18.54

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

	0	85.62	147.83	1016.81	18.17
	0	87.55	148.9	1017	18.62
	0	86.5	149.98	1017.08	18.44
	0	84.51	149	1016.96	17.98
	0	83.76	148.15	1017.44	17.77
	0	84.34	148.61	1017.9	17.91
	0	86.34	150.03	1017.93	18.39
	0	87.33	151.64	1018	18.67
	0	87.4	151.36	1018.03	18.68
	0	86.08	151.3	1017.93	18.39
	0	N/A	N/A	N/A	N/A
	0	87.83	152.45	1017.69	18.82
	0	89.39	152.9	1016.82	19.19
	0	88.07	150.29	1015.84	18.81
	0	87.89	149.53	1015.04	18.76
Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off
	0	89.39	152.9	1018.03	19.19
	0	86.61	150.14	1017.18	18.47

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

Off	Off	Off	Off	Off
Off	Off	Off	Off	Off
Off	Off	Off	Off	Off
Off	Off	Off	Off	Off
Off	Off	Off	Off	Off
Off	Off	Off	Off	Off
0	41.85	107.32	1004.98	8.12
Off	Off	Off	Off	Off
Off	Off	Off	Off	Off
0	44.23	117.84	1002.99	8.83
0	N/A	N/A	N/A	N/A
0	58.54	131.83	1005.19	12.09
0	54.84	126.56	1006.45	11.16
0	65.62	127.61	1008.44	13.38
0	89.32	142.17	1009.92	18.82
0	88.35	147.13	1011.21	18.82
0	85.57	147.36	1012.49	18.21
0	86.08	147.21	1013.98	18.29
0	87.18	147.53	1015.48	18.51
0	86.46	147.85	1016.13	18.36
0	89.72	149.12	1016.41	19.1
0	88.76	149.81	1017.75	18.9
0	87.56	148.96	1018.51	18.6
0	86.44	148.72	1019.04	18.34
0	89.72	149.81	1019.04	19.1
0	76.04	139.13	1011.93	15.97

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	87.86	148.78	1019.59	18.63
0	87.87	149.22	1020.16	18.64
0	86.82	149.56	1020.03	18.44
0	87.61	148.98	1020.3	18.58
0	88.89	150.44	1019.83	18.92
0	89.01	150.65	1019.59	18.96
0	87.34	150.29	1019.82	18.58
0	88.63	150.59	1020.37	18.86
0	86.97	149.02	1020.3	18.44
0	86.35	148.52	1021	18.28
0	83.61	147.69	1020.99	17.66
0	84.36	146.89	1021.23	17.78
0	84.31	146.59	1020.53	17.77
0	83.31	146.48	1020.36	17.56
0	85.66	147.24	1020.08	18.09
0	86.14	145.64	1020.07	18.12
0	87.36	146.25	1019.8	18.41
0	87.73	148.82	1019.45	18.61
0	88.26	149.11	1018.88	18.75
0	88.3	148.18	1018.66	18.72
0	86.53	147.68	1017.94	18.33
0	90.54	148.38	1017.78	19.22
0	92.48	149.97	1017.12	19.71
0	89.08	150.08	1016.3	19.01
0	90.54	150.59	1021	19.22
0	87.29	148.54	1019.59	18.5

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	89.72	149.34	1015.43	19.13
0	87.96	149.14	1013.98	18.77
0	87.87	149.57	1012.86	18.79
0	88.81	149.9	1012.7	19.01
0	89.95	150.38	1012.3	19.29
0	90.29	150.93	1013.24	19.37
0	89.32	150.92	1013.24	19.16
0	88.07	150.31	1014.11	18.85
0	89.23	150.93	1015.62	19.09
0	89.49	150.89	1016.7	19.13
0	90.26	150.99	1017.81	19.28
0	91.7	151.95	1018.89	19.61
0	89.95	149.24	1018.49	19.12
0	88.48	149.41	1018.38	18.82
0	91.76	149.89	1018.82	19.52
0	90.09	150.33	1019.36	19.18
0	90.06	149.68	1018.68	19.16
0	87.47	148.92	1018.62	18.57
0	87.79	148.77	1019.39	18.62
0	87.7	149.2	1019.64	18.62
0	87.74	149.26	1019.51	18.63
0	89.53	150.34	1019.07	19.07
0	87.35	150.01	1018.14	18.61
0	88.8	149.97	1017.3	18.93
0	91.7	150.99	1019.51	19.52
0	89.14	150.01	1016.76	19.01

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	88.44	150.72	1015.16	18.92
0	87.27	151.3	1013.09	18.74
0	89.17	151.65	1011.74	19.19
0	87.85	151.48	1011.16	18.91
0	87.62	151.19	1010.59	18.85
0	87	151.27	1010.29	18.73
0	88.19	151.4	1010.23	18.99
0	87.6	152.28	1010.5	18.9
0	89.64	153.38	1011.19	19.38
0	88.86	153.18	1012.37	19.18
0	91.68	153.63	1013.85	19.78
0	89.81	151.12	1015.61	19.23
0	89.74	150.13	1016.38	19.15
0	89.57	150.65	1017.43	19.12
0	88.53	150.82	1018.68	18.88
0	89.64	150.63	1019.27	19.1
0	88.91	151.28	1020.28	18.95
0	87.55	149.9	1021.13	18.59
0	87.23	149.29	1021.74	18.48
0	87.97	149.32	1021.85	18.64
0	88.16	150.08	1021.72	18.71
0	87.4	149.83	1021.47	18.55
0	91.58	152.45	1020.43	19.57
0	91	152.89	1018.52	19.51
0	91.58	153.38	1021.74	19.57
0	88.77	151.24	1016.03	19

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	89.95	151.77	1016.98	19.26
0	89.49	151.83	1015.42	19.19
0	87.82	151.64	1013.27	18.87
0	86.68	150.56	1012.44	18.59
0	84.66	150.24	1011.8	18.15
0	84.3	149.59	1010.48	18.07
0	83.75	149.01	1009.38	17.95
0	82.3	148.14	1007.75	17.63
0	83.83	148.94	1006.78	18.01
0	85.99	150.53	1006.22	18.55
0	86.64	150.96	1005.74	18.72
0	87.8	151.3	1005.34	19
0	86.93	152.13	1004.82	18.86
0	89.83	152.2	1004.47	19.49
0	87.49	148.03	1004.44	18.8
0	86.62	148.31	1004.76	18.62
0	85.57	148.11	1004.59	18.39
0	86.78	148.61	1004.93	18.66
0	88.05	149.26	1005.48	18.96
0	87.84	150.05	1005.77	18.94
0	88.36	150.61	1005.22	19.09
0	86.7	149.66	1004.88	18.69
0	87.83	149.31	1004.51	18.93
0	88.29	149.44	1004.55	19.03
0	89.83	152.13	1015.42	19.26
0	86.81	150.01	1007.5	18.69

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	88.63	149.14	1004.5	19.09
0	87.37	149.85	1004.11	18.86
0	86.65	149.89	1003.42	18.72
0	86.15	149.53	1002.54	18.61
0	87.17	149.57	1001.76	18.85
0	87.82	150.04	1000.76	19.03
0	88.39	150.45	1000.41	19.18
0	88.47	150.81	1000.33	19.22
0	87.8	151.44	1000.03	19.1
0	86.47	150.41	999.03	18.79
0	88.47	150.88	998.44	19.25
0	88.91	151.93	998.79	19.39
0	88.17	151.08	998.09	19.2
0	87.29	148.53	996.31	18.93
0	87.76	148.01	995.01	19.04
0	87.37	147.88	995.1	18.94
0	90.81	149.15	995.13	19.75
0	92.97	152.6	995.43	20.38
0	92.91	153.48	995.52	20.4
0	88.94	150.52	995.85	19.39
0	87.9	149.76	995.93	19.13
0	86.52	149.33	996.23	18.8
0	87.16	148.5	996.6	18.9
0	92.03	150.41	996.85	20.04
0	92.91	152.6	1004.11	20.38
0	88.42	150.13	998.59	19.21

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	92.53	151.62	997.62	20.19
0	92.58	153.05	998.2	20.26
0	91.5	152.83	998.42	20.01
0	88.51	151.28	998.73	19.28
0	88.05	150.17	999.52	19.11
0	91.71	151.32	1000.35	19.94
0	90.65	152.01	1001.11	19.73
0	90.36	152.39	1002.17	19.66
0	90.13	152.03	1003.43	19.57
0	91.27	152.15	1004.84	19.8
0	90.39	152.72	1005.64	19.62
0	N/A	N/A	N/A	N/A
0	N/A	N/A	N/A	N/A
0	N/A	N/A	N/A	N/A
0	90.38	152	1006.49	19.57
0	88.19	148.69	1006.75	18.94
0	N/A	N/A	N/A	N/A
0	87.79	149.61	1005.84	18.92
0	91.14	150.59	1006.08	19.67
0	89.33	150.69	1005.7	19.29
0	88.55	150.27	1004.71	19.12
0	88.71	150.44	1003.83	19.18
0	91.63	152	1002.62	19.91
0	91.16	151.72	1000.73	19.84
0	92.58	153.05	1006.75	20.26
0	90.23	151.38	1002.64	19.58

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	90.28	151.32	998.89	19.66
0	88.05	150.91	996.75	19.2
0	88.98	151.69	994.58	19.48
0	89.54	151.64	993.24	19.62
0	90.36	152.02	992.96	19.83
0	89.4	152.81	993.36	19.65
0	89	152.22	994.06	19.52
0	N/A	N/A	N/A	N/A
0	N/A	N/A	N/A	N/A
0	87.57	151.31	999.75	19.05
0	86.64	151.1	1002.15	18.8
0	86.82	151.15	1003.98	18.8
0	88.65	150.66	1005.68	19.14
0	85.15	146.99	1005.81	18.23
0	84.19	146.82	1006.85	18
0	86.16	147.68	1008.08	18.43
0	88.87	149.84	1008.58	19.1
0	87.07	150.48	1009.49	18.72
0	86.23	149.54	1010.3	18.49
0	87.43	149.37	1011.65	18.71
0	86.2	149.98	1011.81	18.47
0	88.12	150.5	1012.13	18.9
0	89.34	150.77	1012.11	19.18
0	89.43	150.3	1011.94	19.18
0	90.28	152.22	1012.11	19.66
0	87.89	150.41	1003.82	19.01

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	87.47	149.86	1011.92	18.74
0	87.33	149.39	1011.48	18.7
0	86.8	149.93	1009.95	18.63
0	87.27	149.84	1008.46	18.76
0	88.7	150.25	1007.36	19.11
0	87.26	150.16	1005.6	18.83
0	87.14	150.09	1003.83	18.83
0	87.46	150.1	1001.82	18.93
0	85.72	150.23	1000.4	18.59
0	88.46	150.95	998.83	19.25
0	86.58	151.43	998.24	18.87
0	87.21	151.65	998.08	19.02
0	87.18	151.8	997.32	19.04
0	88.65	152.01	996.51	19.38
0	88.69	150.74	995.98	19.34
0	90.23	151.17	995.1	19.72
0	89.72	152.37	994.19	19.68
0	89.1	152.25	993.28	19.55
0	88.51	151.95	993.33	19.41
0	89.86	153.1	992.92	19.77
0	89.45	153.5	991.82	19.72
0	90.01	153.54	990.21	19.88
0	89.41	153.29	988.73	19.76
0	88.59	153.42	986.37	19.63
0	90.01	153.5	1011.48	19.77
0	88.2	151.38	998.82	19.21

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	87	152.38	984.8	19.26
0	86.18	151.34	983.22	19.07
0	85.99	151.26	981.77	19.05
0	87.68	151.97	981.32	19.47
0	88.08	152.75	980.65	19.6
0	85.86	151.23	980.15	19.05
0	87.33	152.01	980.69	19.4
0	89.37	152.86	980.55	19.9
0	89.48	153.63	981.32	19.94
0	88.41	153.42	981.81	19.68
0	86.08	152.53	982.22	19.12
0	86.46	151.94	982.91	19.16
0	85.92	151.39	983.12	19.01
0	88	151.8	982.07	19.52
0	90.03	152.68	982.15	20
0	85.96	149.27	981.76	18.96
0	86.9	149.11	982.21	19.15
0	87.77	149.93	982.54	19.37
0	88.53	151.2	983.11	19.58
0	89.54	151.24	983.1	19.81
0	89.93	151.84	983.25	19.92
0	88.6	152.64	983.36	19.66
0	87.43	151.24	983.32	19.34
0	89.29	151.3	983.64	19.74
0	89.93	153.42	983.64	19.94
0	87.74	151.71	982.29	19.45

Live Stream Flow Nm3/ Temperatu Static Press Velocity m/s

0	87.25	150.24	984.3	19.23
0	87.79	150.91	984.44	19.38
0	88.9	152.4	984.22	19.7
0	87.85	151.73	984.05	19.44
0	86.44	150.6	983.75	19.08
0	88.41	150.76	984.5	19.51
0	90.08	152.97	984.41	19.98
0	88.58	152.47	984.83	19.62
0	88.09	152.36	985.28	19.5
0	86.67	151.99	985.74	19.15
0	86.23	151.11	985.72	19.02
0	84.63	150.19	987.54	18.59
0	87.66	150.18	987.59	19.26
0	87.73	148.92	987.12	19.22
0	88.65	150.16	986.69	19.49
0	84.06	148.76	986.77	18.42
0	84.84	148.3	986.08	18.58
0	86.79	150.04	986	19.09
0	86.69	150.53	985.66	19.1
0	87.04	151.08	985.52	19.2
0	85.93	150.98	985.25	18.96
0	85.36	150.81	984.93	18.83
0	86.28	150.75	984.42	19.04
0	89.25	151.39	982.85	19.76
0	89.25	152.47	987.54	19.76
0	87.13	150.82	985.32	19.21