

Schedule 1 - Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	BU8002 / Dawn Meats.
Name of Operator	Dunbia Cross Hands
Location of installation	Cross Hands, Llanelli
Location of the emission	WS sample point
Time and date of the emission	14/01/2021 at 10:00

Results received 27/1/2021

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
	eg air		
Surface Water	eg groundwater	0.3 mg/l Ammoniacal Nitrogen	

Measures taken, or intended to be taken, to stop the emission	A full clean of the roof gutters will be undertaken as soon as it is safe to access the roof
---	--

Part B

Any more accurate information on the matters for notification under Part A.	Believed to be build up of leaves from roof and decaying the cause of excedance
Measures taken, or intended to be taken, to prevent a recurrence of the incident.	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	
The dates of any unauthorised emissions from the installation in the preceding 24 months.	

Name*	Katy Rogers
Post	HSE Manager
Signature	K Rogers
Date	27/1/2021

* authorised to sign on behalf of Dawn Meats (UK) Ltd