



Release Point S1			
<b>Week</b>	<b>Total suspended solids (limit = 500mg/l) [mg/l]</b>	<b>Total Petroleum Hydrocarbons (Limit = 100mg/l)</b>	<b>Total sulphate (Limit = 1g/l) [mg/l]</b>
04/03/2021	<14mg/l	< 4mg/l	15.8 mg/l
<b>Week</b>	<b>COD (limit = 1000mg/l) @ daily flow of 20m3</b>	<b>Total sulphite (expressed as SO3) (Limit = 50 mg/l)</b>	<b>Total sulphide (Limit = 3mg/l)</b>
04/03/2021	28mg/l	13 mg/l	<1mg/l

Week ending	pH [ Range = 6.0 to 10.0]		Temp. [C] [Limit = 40C]		Flow Rate [l/s] [Limit = 1.5]		Daily Flow [m3] [Daily Limit = 20m3]
	Max	Min	max	min	Max	Min	
07/03/2021	7.46	6.71	11.50	10.60	1.5	1	5
14/03/2021	7.24	6.56	11.10	10.01	1.5	1	5
21/03/2021	7.79	6.89	11.06	11.00	1.5	1	5
28/03/2021	7.00	6.64	12.04	11.02	1.5	1	5
					1.6	1	5

Signed on behalf of the operator:

R.Cirillo

Date: