

Compliance Report

Company:Harsco Environmental Contact:Paul Roberts

Authorisation number (s):Lancing Booth Stack Monitor Q1 2021

No exceedances

From:01 Jan 21 00:49:23 To:31 Mar 21 00:49:23

Device 1 : Stack1 Dust Cal Factor: 0.52 (constant) Average:0.169 Averaging Period:1 hrs

Emission Limit: 20.00 INDmg/m3

Date	Max Value (INDmg/m3)	Number of failures	95% Compliance	Max < 150% Limit
01 Jan 21	0.02	0	pass	pass
02 Jan 21	0.08	0	pass	pass
03 Jan 21	0.02	0	pass	pass
04 Jan 21	0.08	0	pass	pass
05 Jan 21	1.96	0	pass	pass
06 Jan 21	1.53	0	pass	pass
07 Jan 21	2.07	0	pass	pass
08 Jan 21	2.23	0	pass	pass
09 Jan 21	0.05	0	pass	pass
10 Jan 21	0.02	0	pass	pass
11 Jan 21	2.48	0	pass	pass
12 Jan 21	1.18	0	pass	pass
13 Jan 21	0.44	0	pass	pass
14 Jan 21	1.24	0	pass	pass
15 Jan 21	5.07	0	pass	pass
16 Jan 21	0.31	0	pass	pass
17 Jan 21	0.08	0	pass	pass
18 Jan 21	1.80	0	pass	pass
19 Jan 21	1.07	0	pass	pass
20 Jan 21	0.95	0	pass	pass
21 Jan 21	1.70	0	pass	pass
22 Jan 21	0.14	0	pass	pass
23 Jan 21	0.02	0	pass	pass
24 Jan 21	0.71	0	pass	pass
25 Jan 21	2.16	0	pass	pass
26 Jan 21	1.90	0	pass	pass
27 Jan 21	0.66	0	pass	pass
28 Jan 21	0.25	0	pass	pass
29 Jan 21	0.07	0	pass	pass
30 Jan 21	0.04	0	pass	pass
31 Jan 21	0.10	0	pass	pass
01 Feb 21	0.06	0	pass	pass
02 Feb 21	1.17	0	pass	pass
03 Feb 21	1.10	0	pass	pass
04 Feb 21	0.67	0	pass	pass
05 Feb 21	1.10	0	pass	pass
06 Feb 21	1.62	0	pass	pass
07 Feb 21	0.07	0	pass	pass
08 Feb 21	2.38	0	pass	pass
09 Feb 21	0.09	0	pass	pass
10 Feb 21	0.05	0	pass	pass
11 Feb 21	0.03	0	pass	pass
12 Feb 21	0.02	0	pass	pass
13 Feb 21	0.06	0	pass	pass
14 Feb 21	0.06	0	pass	pass
15 Feb 21	0.04	0	pass	pass
16 Feb 21	0.48	0	pass	pass
17 Feb 21	0.10	0	pass	pass
18 Feb 21	1.36	0	pass	pass
19 Feb 21	0.31	0	pass	pass
20 Feb 21	0.09	0	pass	pass
21 Feb 21	0.25	0	pass	pass
22 Feb 21	0.24	0	pass	pass
23 Feb 21	0.08	0	pass	pass
24 Feb 21	2.53	0	pass	pass
25 Feb 21	2.03	0	pass	pass
26 Feb 21	1.25	0	pass	pass
27 Feb 21	0.03	0	pass	pass
28 Feb 21	0.02	0	pass	pass
01 Mar 21	1.54	0	pass	pass
02 Mar 21	2.59	0	pass	pass
03 Mar 21	1.79	0	pass	pass
04 Mar 21	1.49	0	pass	pass
05 Mar 21	1.97	0	pass	pass
06 Mar 21	0.01	0	pass	pass
07 Mar 21	0.01	0	pass	pass
08 Mar 21	1.42	0	pass	pass
09 Mar 21	0.04	0	pass	pass
10 Mar 21	1.41	0	pass	pass
11 Mar 21	0.49	0	pass	pass

Date	Max Value (INDmg/m3)	Number of failures	95% Compliance	Max < 150% Limit
12 Mar 21	0.36	0	pass	pass
13 Mar 21	0.17	0	pass	pass
14 Mar 21	0.04	0	pass	pass
15 Mar 21	0.08	0	pass	pass
16 Mar 21	0.75	0	pass	pass
17 Mar 21	0.03	0	pass	pass
18 Mar 21	0.01	0	pass	pass
19 Mar 21	0.01	0	pass	pass
20 Mar 21	0.01	0	pass	pass
21 Mar 21	0.01	0	pass	pass
22 Mar 21	1.38	0	pass	pass
23 Mar 21	1.57	0	pass	pass
24 Mar 21	2.00	0	pass	pass
25 Mar 21	1.21	0	pass	pass
26 Mar 21	1.68	0	pass	pass
27 Mar 21	0.06	0	pass	pass
28 Mar 21	0.04	0	pass	pass
29 Mar 21	1.95	0	pass	pass
30 Mar 21	0.99	0	pass	pass
31 Mar 21	3.79	0	pass	pass