

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/BJ9681IX
Name of operator	Essity UK Ltd
Location of Facility	Chester Road, Oakenholt, Flintshire, CH6 5PU
Time and date of the detection	16:15 25-MAR-2021

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution

To be notified within 24 hours of detection

Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

(b) Notification requirements for the breach of a limit

To be notified within 24 hours of detection unless otherwise specified below


Emission point reference/ source	W1 Final Effluent Point of Discharge
Parameter(s)	Flow
Limit	2200 m³/day
Measured value and uncertainty	2230 m³ Uncertainty $\pm$ 2.25%
Date and time of monitoring	12:00 24-MAR-2021 to 12:00 25-MAR-2021
Measures taken, or intended to be taken, to stop the emission	Ongoing monitoring (issue mitigated)

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	None known / anticipated
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	Measured value and uncertainty (some data was missed) 2230 m³ (+1.36% of total daily volume) Uncertainty of measurement $\pm 2.25\%$
Measures taken, or intended to be taken, to prevent a recurrence of the incident	New Effluent Controls Strategy to be introduced to give a series of warnings to Operators, with consideration for Automatic Recirculation if a breach is imminent to the Maximum Daily Discharge Limit specified in Environmental Permit EPR/BJ9681IX: 2200 m ³ /day by the end of July
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	N/A
The dates of any unauthorised emissions from the facility in the preceding 24 months.	24-Apr-2019; 25-Jun-2019; 24-Jul-2020; 13-Aug-2020

Name*	Mark Turner
Post	Quality & Environment Engineer
Signature	
Date	22-Apr-2021

* authorised to sign on behalf of the operator