

Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	PAN-005329
Name of operator	UK Power Reserve
Location of Facility	SC Trading Estate, Porthcawl Road, Bridgend CF33 4RE
Time and date of the detection	08:45 on 28/12/2020

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution	
To be notified within 24 hours of detection	
Date and time of the event	Morning of 28/12/2020
Reference or description of the location of the event	Transformer onsite lost containment of oil, investigation pending.
Description of where any release into the environment took place	Concrete transformer bund caught majority of the oil, with slight seepage through the bund resulting in oily sheen on the tarmac, no pooling of oil, oil interceptor onsite.
Substances(s) potentially released	Transformer Oil
Best estimate of the quantity or rate of release of substances	Very small quantity released, no pooling of oil observed, only oily sheen on the tarmac. Site is equipped with an oil interceptor to catch any oil that may have gotten into the drains
Measures taken, or intended to be taken, to stop any emission	The remaining oil that was captured in the bund has been pumped out to secure IBCs, to stop any further seepage. Spill mats put down to absorb any remaining surface oil. Interceptor will be checked and cleaned, as needed
Description of the failure or accident.	Transformer failure. Cause unknown, pending investigation. Bund was successful in capturing majority of the oil however small amount seeped through the concrete - bund integrity review pending

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	n/a
Parameter(s)	

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	


Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	n/a - any risk of impact to environment mitigated by oil interceptor on the drainage system
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	Heather Turner
Post	Senior Environmental Compliance Officer

Signature	
Date	28/12/2020

* authorised to sign on behalf of the operator