

Operator: **AB Connectors Ltd**Permit Reference Number: **BV74431P**Installation: **Abercynon Inorganics**Reporting of Emissions to Sewer for the period from **October 2020** to **December 2020**Form Number: **S1**

Emission Point	Substance or Parameter	Emission Limit Value	Result ¹	Test Method ²	Sample Date and Times ³	Accreditation/Certification ⁴	Uncertainty ⁵
T13	Cadmium	10 µg/l	—	DISCHARGE POINT MONITORING	16/11/2020	DISPOSAL	SEE SITE
T1	Maximum pH	3.0	1.98	CONTINUOUS MONITORING	16/11/2020		
T1	Redox Potential	300 mV	235	CONTINUOUS MONITORING	16/11/2020		
T2	Minimum pH	10.5	10.20	CONTINUOUS MONITORING	16/11/2020		
T2	Redox Potential	300 mV	324	CONTINUOUS MONITORING	12/10/2020		
T5	Minimum pH	9	9.35	CONTINUOUS MONITORING	30/11/2020		
T5	Maximum pH	11	10.16	CONTINUOUS MONITORING	14/12/2020		
S1	Flow	-					
S1	Cadmium	0.05 mg/l	0.005	NITRIC ACID DILUT	13/11/2020		
S1	Cadmium	150 g/year	3.57				
S1	Chromium (VI)	0.1 mg/l	0.091	COLORIMETRY	7/10/2020		
S1	Chromium	2 mg/l	0.50	NITRIC ACID DILUT	13/11/2020		
S1	Copper	2 mg/l	0.92	AAS	27/10/2020		
S1	Nickel	2 mg/l	0.60	NITRIC ACID DILUT	13/11/2020		
S1	Zinc	2 mg/l	0.23	AAS	22/11/2020		
S1	Free cyanide	1.0 mg/l	0.84	COLORIMETRY	16/12/2020		

¹ The result given is the maximum value (or minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value.

² Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. colorimetry.

³ For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

⁴ The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

⁵ The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed 
(Authorised to sign as representative of the Operator)

Date: **20/1/2021**