

Permit Number: EPR/XP3830UR
Facility: Haverfordwest Creamery

Operator:
Form Number:

The First Milk Cheese Company Limited
Air1 / 01/07/2020

Reporting of emissions to air for the period from 01/01/2020 to 31/12/2020

Emission Point	Emission		Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
	Substance / Parameter	Limit Value					
A1	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	No limit set	Periodic	88.3 mg/m ³ Measured and uncertainty not applied	MCERTS BS EN 14792	20/01/2021 11:20 – 12:20 hrs	+/- 16.7
A2	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	No limit set	Periodic	83.2 mg/m ³ Measured and uncertainty not applied	MCERTS BS EN 14792	20/01/2021 11:20 – 12:20 hrs	+/- 5.1
A3	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	No limit set	Periodic	116 mg/m ³ Measured and uncertainty not applied	MCERTS BS EN 14792	21/01/2021 09:39 – 10:39hrs	+/- 8.8
A4	Carbon monoxide	No limit set	Periodic	280 mg/m ³ Measured and uncertainty not applied	MCERTS BS EN 15058	21/01/2021 11:20 – 12:20hrs	+/- 11.4
	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	95 mg/Nm ³ ^[5]	Periodic	98.3 mg/m ³ Measured and uncertainty not applied	MCERTS BS EN 14792	21/01/2021 11:20 – 12:20hrs	+/- 4.1

Notes:

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

[5] At reference conditions of a temperature of 273.15 K, a pressure of 101.3 kPa and after correction for the water vapour content of the waste gases at a standardised O₂ content of 6 % for solid fuels, 15 % for engines and gas turbines and 3 % for all other MCPs

Signed
(Authorised to sign as representative of Operator)

Date: 15 Feb 2021