

Permit Number: EPR/BX72821S  
Facility: Magor Brewery  
Date of form 19/07/11

Operator: Inbev UK Ltd  
Form Number: Gas1

**Reporting of biogas quality for the year 1<sup>st</sup> July 2019 to 31<sup>st</sup> December 2019**

| Parameter                                                         | Result (ppm) |
|-------------------------------------------------------------------|--------------|
| Hydrogen sulphide content at outlet of hydrogen sulphide scrubber | 50           |
| Hydrogen sulphide content at entry to gas engine                  | 50           |
|                                                                   |              |
|                                                                   |              |
|                                                                   |              |
|                                                                   |              |
|                                                                   |              |
|                                                                   |              |
|                                                                   |              |

The result given is the maximum result over the reporting period

Operator's comments :Significant number of engine stoppages throughout 2019.  
Gas Scrubber media replaced

Signed .....Carl Rogers.....  
(Authorised to sign as representative of Inbev UK Ltd)

Date.....19/2/2020.....