

 Navigator	Draining of Lagoon	Document Number NTW-OPS-PROC-0027
Document Owner Adam Gibson	Applies to: Navigator Terminals Windmill	Issue Number 5

Appendix 1

Site Name: Navigator Terminals Windmill Ltd

Permit Number: KP3734SH

Parameter	Analytical method	Value recorded	Permit limits	Within permit limits? (Y/N)
pH	Standard glass probe [Dow procedure CTM 0007]	9.28	6 > pH > 10	Y
Visible oil/grease (Appearance)	Visual examination [CTM 0176]	N/A	Must be Y / pass on appearance	Y
Total Organic Carbon	GC and FID [Dow procedure CTM 1144]	1.79 mg/l	10ppm	Y

Date: 23-6-20

Results reviewed and acceptable to discharge? (Y/N):

(if not please follow step 6 onwards in procedure NTW-OPS-PROC-0027)

Quantity to discharge (approx.): 1000 CBM

Name: D WEAVER

Signature: DWEAVER

LAGOONWTR - Navigator Lagoon Run Off Water	
	Hazard.....: Non-Hazardous
	LoginDate...: 22-JUN-2020 15:38
	Size.....: 1 x 500ml
	Notes.....:
	0007#A - pH (as received) 0176#OIL - No Visible Oil 1144#B - TOC ONLY
2095689 W212	