

**Sewage treatment plant management system**

**After installation**      Issue caravan owners with notice immediately to report any water drain away failures and warning not to use chemicals detrimental to plant operation

**Continuous**              Remote reporting by text to mobile phone

**Daily**                      Monitor caravan occupancy  
Unoccupied units, check water stop cocks off

**No occupation**              No inflow

**Caravans occupied**              Check manhole covers, plant, and soakaway area for surface water and odour

**Monthly**                      Lift manhole covers and check for build up of solid material  
Run water into highest point and check for free flow into plant.

**Annually**                      Test water quality      After period of high occupation in warm weather  
eg busy weekend in July.

Desludge plant      Annually or bi annually in June according to manufacturers specification.

Service air pumps      During closed period, January/February

[illegible]