

Permit Number: EPR/EP3830GH

Operator: Liberty Steel UK Ltd

Facility: Liberty Steel Newport

Form Number: Water1 / 15/08/2016

Reporting of emissions to water (other than to sewer) and land for the period from 01/01/2020 to 31/03/2020

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
W1	Total suspended solids	20 mg/l	Spot Sample	7	BS EN 872:1996 or other ISO, BS or SCA blue book method as approved by Natural Resources Wales	19/03/2020 14:00	3.64
W1	Total Hydrocarbons	5 mg/l	Spot Sample	1.530	SCA blue book 77 ISBN 0117517283 2002 or other ISO, BS or SCA blue book method as approved by Natural Resources Wales	20/02/2020 14:00	0.439
W1	pH	6-10	Spot Sample	10.1	BS 6068-2.50:1995 (ISO 10523:1994)	09/01/2020 14:00	10.1
W1	Lead	0.1 mg/l	Spot Sample	0.012	BS 6068-2.60:1998, BS EN ISO 11885 1998	09/01/2020 14:00	0.007
W1	Arsenic	0.1 mg/l	Spot Sample	0.005	BS 6068-2.60:1998, BS EN ISO 11885 1998	20/02/2020 14:00	0.003
W1	Cadmium	0.05 mg/l	Spot Sample	0.0032	BS 6068-2.60:1998, BS EN ISO 11885 1998	19/03/2020 14:00	0.001

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
W1	Chromium	0.2 mg/l	Spot Sample	0.051	BS 6068-2.60:1998, BS EN ISO 11885 1998	20/02/2020 14:00	0.028
W1	Nickel	0.1 mg/l	Spot Sample	0.007	BS 6068-2.60:1998, BS EN ISO 11885 1998	19/03/2020 14:00	0.003
W1	Copper	0.1 mg/l	Spot Sample	0.010	BS 6068-2.60:1998, BS EN ISO 11885 1998	19/03/2020 14:00	0.009
W1	Mercury	-	Spot Sample	0.00002	BS 6068-2.60:1998, BS EN ISO 11885 1998	19/03/2020 14:00	0.00001
W1	Iron	5 mg/l	Spot Sample	0.23	BS 6068-2.74:2002, BS EN ISO 13506:2002	19/03/2020 14:00	0.22
W1	Zinc	0.5 mg/l	Spot Sample	0.136	BS 6068-2.60:1998, BS EN ISO 11885 1998	19/03/2020 14:00	0.056


[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

[5] Metal include elements and compounds of Pb, As, Cd, Cr, Ni, Cu, Hg and Zn expressed as the metal and shall be individually reported

Signed 

Date: 28th April 2020