

CONTINUOUS MEASUREMENT SYSTEMS INVALIDATION LOG

QUARTERLY RETURN

Operator: Baglan Operations Limited

Monitor positioned on release point/LCP No: A2 & A4 / LCP15

Permit/Variation Number: EPR/BJ7891IT

Date	Period of invalidation (hours)	Invalidated days in month
No invalid data recorded		

NOTES:

(a) Compliance in Chapter III of the IED is on the basis of validated hourly averages, measured by continuous monitors (exemption applies). And confidence intervals are incorporated to convert the measured hourly value into a validated measure of compliance assessment. However, any day in which more than 3 hourly average values are invalid (due to malfunction of continuous measurement system) shall be invalidated for the purpose of compliance assessment. If more than 10 days are the operator shall, within 28 days of becoming aware of this fact, review the causes of the invalidations and submit to the ENEC approval, proposals for measures to improve the reliability of the continuous measurement systems, including a timetable for those measures; and implement the approved proposals.

Signed on behalf of the Operator by:Paul Churchill.....

Date of return:19/4/2021.....

Year: 2021

Form: IED CEM1

Version/Date: V 3.1 31 Dec 2016

LM2500

Comments

except where discontinuous
urement for the purpose
or maintenance of the
invalid over a year
Environment Agency for
for the implementation of

.....

.....