

IQE Silicon Compounds Ltd

RELEASE TO SEWERS

Release Summary for 6 months ending 30/06/2020

Operator: IQE Silicon Compounds Ltd

Permit Number: BJ69681Y

Location: St. Mellons

Release Points **S1**

Release points shall be sampled once per month, and results submitted on a six-month basis.

Parameter		
	Suspended Solids mg/l	pH
Maximum	5.0	8.0
Minimum	5.0	8.0
Average	5.0	8.0

Limits: Suspended Solids 400mg/l

pH: between 6 and 11

Signed on behalf of Operator:



Dated: 29/06/2020

Form S1(Version date 30/04/01)