

Schedule 6 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-commercial information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provision of the PPC Regulations.

Part A

Permit Number	FP3238SL
Name of Operator	Novera Energy No 2 Ltd
Location of Installation	Lamby Way Generation Plant
Time and date of the detection	24/08/20

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution

To be notified within 24 hours of detection

Time and date of the event	24/08/20
Reference or description of the location of the event	Suspected transformer failure tripped the engine and flare
Description of where any release into the environment took place	Lamby Way GUP
Substance(s) potentially released	Smoke
Best estimate of the quantity or rate of release of substances	Unquantifiable
Measures taken or intended to be taken, to stop the emission	Landfill gas technician attended to conduct initial appraisal of the site. Electrical Engineers now attending site and arrangements have will be made for a back-up generator.
Description of the failure or accident	Site tripped. Transformer failure suspected

(b) notification requirements for the breach of a limit


To be notified within 24 hours of detection unless otherwise specified below

Emission point reference / source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substance(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Electrical specialists attending to investigate. Further updates will follow.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	N/A - Visible smoke was reported at the time of the trip but this cleared. It is intended that landfill gas extraction will be regained through the use of a back-up generator to power the site whilst longer term options are investigated.
The dates of any unauthorised emissions from the installation in the preceding 24 months	10/12/19

Name*	Kate Phillips
Post	Engineer, compliance
Signature	
Date	24/08/20

*authorised to sign on behalf of Novera Energy