

Schedule 3 - Form Number: A1

Operator: KEPAK Group Limited

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Air

Release Point: A1

Release for Month: **October 2020** (forms to be submitted quarterly)

NIL RETURNED

NOT YET COMMISSIONED

[illegible]

Signed on behalf of the Operator ...

P. Williams

Date ...27/01/2021

Permit EPR/AP3433ES

Date of form 13/10/14

NOT YET COMMISSIONED

Date of form 13/10/14

Schedule 3 - Form Number: A1

Operator: KEPAK Group Limited

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Air

Release Point: A1

Release for Month: **December 2020** (forms to be submitted quarterly)

NIL RETURNED

NOT YET COMMISSIONED

[illegible]

Signed on behalf of the Operator ...

P. Williams

Date 27/01/2021

Permit EPR/AP3433ES

Date of form 13/10/14

Schedule 3 - Form Number: A3

Operator: KEPAK Group Limited

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Air

Release Point: A2

Release for Quarter ending: December 2020

NIL RETURNED

Reporting Form A3			
Details of operation of by-pass stack			
Date	Time	Duration	Reason for Operation

Signed on behalf of the Operator ...

P. Williams

Date ...27/01/2021

Schedule 3 - Form Number: W1

Operator: KEPAK Group Limited

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse


Release to Water

Release Point: W1, W2

Release for Quarter ending: [December 2020](#)

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	1.11	0.6	15/10/2020
Suspended Solids mg/l	50	12.0	1.0	15/10/2020
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	05/11/2020
Suspended Solids mg/l	50	8.0	2.0	05/11/2020
Mineral oil and hydrocarbons mg/l	5	2.7	1.19	03/12/2020
Suspended Solids mg/l	50	16.0	47	03/12/2020

Signed on behalf of the Operator ...



Date ...27/01/2021

Schedule 3 - Form Number: S1**Operator: KEPAK Group Limited****Permit Number: AP3433ES**

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: [December 2020](#)

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95 th Percentile Value	Maximum
pH	6-11	6.5	7.8	10.02	10.8
Total suspended solids mg/l	600	16	37.9	72.8	78
Total chemical oxygen demand (COD) mg/l	3600	160	367.2	558.85	713
Free or emulsified grease or oil mg/l	100	0.78	5.1	16	18.7
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.0	0.03	0.025
Dissolved oxygen mg/l	-	0.5	2.0	7.475	9.1
Ammoniacal nitrogen as N mg/l	30	2.77	8.9	17.67	18.9
Daily flow m ³ /day	800	85.8	611.8	810.8	838.1
Maximum flow m ³ /h	34	3.6	25.5	33.8	34.9

Signed on behalf of the Operator ...



Date ...27/01/2021