

Permit Reference Number: BL3986ID

Operator: Aberthaw Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Air 11 / 19/07/2016

**Six-monthly Reporting of Particulate Emissions to Air from Emission Points A4, A5, A6 & A11
for the period from 01/01/20 to 31/12/20**

Emission Point	Parameter	Emission Limit Value (mg/Nm ³)	Result (mg/Nm ³) 1 st Six months	Result (mg/Nm ³) 2 nd Six months	Test Method	Sample Date & Times	Uncertainty
A4	Particulate Matter	10	1.07	14.36 3.43*	BS EN 13284-1	18.3.2020 11:27 – 13:36 3.9.202 09:00 – 11:04 3.12.2020 10:06 – 12:26	0.58 1.23 0.54
A5	Particulate Matter	10	-		BS EN 13284-1	-	-
A6	Particulate Matter	10	-		BS EN 13284-1	-	-
A7	Particulate Matter	10	-		BS EN 13284-1	-	-

*Second 6 month retest carried out due to breach result on first second 6 month test.

Signed: G Taubman
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date 27/01/2021