



NOTES:

- ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED.
- ALL LEVELS ARE IN METRES ABOVE ORDINANCE DATUM (NEWLYN).
- ALL NEW PIPEWORK LAID IN CLASS-S BEDDING WITH MIN. 900mm COVER UNLESS STATED OTHERWISE. DCWW STANDARD DETAIL SDC 2003/002.
- ROCKER PIPES OR COUPLINGS TO ALLOW DIFFERENTIAL SETTLEMENT NEXT TO ALL CONCRETE STRUCTURES PROVIDED.
- CIVIL WORKS IN ACCORDANCE WITH THE WELSH WATER CIVIL SPECIFICATION AND THE CIVIL ENGINEERING SPECIFICATION FOR THE WATER INDUSTRY 7th EDITION. DRAWING TO BE READ IN CONJUNCTION WITH:
-

- STORM TANK 1 PLAN AND SECTIONS - 3794-S-201-MMB-04-XX-DR-CX-05004.
- UTILITIES AND HST/BIOFILTER PLAN - 3794-S-201-MMB-04-XX-DR-CX-05008.
- HST DELIVERY PUMP STATION - 3794-S-201-MMB-04-XX-DR-CX-05010.
- HST DESLUDGE PUMPING STATION - 3794-S-201-MMB-04-XX-DR-CX-05011.
- HST PLAN - 3794-S-201-MMB-04-XX-DR-CX-05016.
- HST HYDRAULIC BREAK MANHOLE - 3794-S-201-MMB-04-XX-DR-CX-05018.
- HST DESLUDGE/DESCUM AND EFFLUENT PIPEWORK - 3794-S-201-MMB-04-XX-DR-CX-05019.

SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION

IN ADDITION TO THE HAZARDS/RISKS NORMALLY ASSOCIATED WITH THE TYPES OF WORK DETAILED ON THIS DRAWING, NOTE THE FOLLOWING:

CONSTRUCTION

MAINTENANCE / CLEANING / OPERATION

LOW GROUND COVER OVER HST EFFLUENT PIPE INBETWEEN BIOFILTERS

DECOMMISSIONING / DEMOLITION

LOW GROUND COVER OVER HST EFFLUENT PIPE INBETWEEN BIOFILTERS

REFER TO THE DESIGN RISK REGISTER FOR FURTHER DETAILS. IT IS ASSUMED THAT ALL THE WORKS ON THIS DRAWING WILL BE CARRIED OUT BY A COMPETENT CONTRACTOR WHO HAS CARRIED OUT A COMPREHENSIVE RISK ASSESSMENT.

Z01	17.12.19	JP	AS-BUILT	AA	JBC	06.01.20
Rev.	Date.	Drawn.	Description.	Chkd.	Appd.	Date.
 Capital Delivery Alliance Cynghrair Cyflawni Cyfalaf Ty Awen, Spooner Close, Coed Kernew, Newport, NP108FZ						
Project Name.		ABERBAIDEN WwTW				
Drawing Title.		NEW SITE PIPEWORK				
Suitability.					Suitability Code.	
AS-BUILT					AB	
Originator.		Designer.		Date.		
JP		SG		17.12.19		
Internal Project Number.		Scale.		Rev.		
PN43		1:250 @ A1		Z01		
Drawing Number.						
3794-S-201-MMB-00-XX-DR-CX-05009						

Dwr Cymru Cyf gives this information as to the position of its underground apparatus by way of general guidance only on the strict understanding that it is based on the best information available and no warranty as to its correctness is relied upon in the event of excavations or other works made in the vicinity of the company's apparatus and any onus of locating the apparatus before carrying out any excavations rests entirely on you. It must be understood that the furnishing of the information is entirely without prejudice to the provision of the New Roads and Streetworks Act 1991 and of the Company's right to be compensated for any damage to its apparatus.

Dwr Cymru Cyf has no duty to identify private apparatus and the information as to the position of the private apparatus is given by way of general guidance only on the strict understanding that it is based on the best information available and no warranty as to its correctness is relied upon. Not all private apparatus is identified but their presence should be anticipated.

PLAN
SCALE 1:250

WARNING:- THIS MAY BE A REDUCED SIZE PRINT, CHECK SCALE BELOW

5m 0 5m 10m 15m 20m 25m

1:250