

# 6 MONTHLY STORM OVERFLOW EVENT RECORD

<b>Site Name:</b>	<b>Ffos-y-fran Land Reclamation Scheme</b>			
<b>Permit No:</b>	<b>EPR/DB3131AF</b>			
<b>6 months from/to:</b>	<b>January – June 2021</b>			
<b>Consent Number</b>	<b>Suspended Solids Consent Limits</b>	<b>pH Consent limits</b>	<b>Start of storm overflow</b>	<b>Stop of storm overflow</b>
AN0264602 (WC1 Storm)	50 mg/l	5-9		
NPSWQD002105 (WI Storm)	50 mg/l	5-9		
AN0264502 (WB Storm)	N/A	N/A	04-03-21	04-03-21
AN0274601 (WC Storm)	N/A	N/A		
AN0265002 (WG Storm)	N/A	N/A		
AN0264802 (WF Storm)	N/A	N/A		
AN0264402 (WA Storm)	N/A	N/A		
<b>Notes:</b> 04-03-2021 – WB overflow due to residual water in the channels/pump line after pump turned off. The overflow only occurred for a very short period of time.				
<b>Name</b>	Stephen Woolmington	<b>Position:</b>	Engineer	<b>Date:</b> 26-07-21