

Note: Permit Number EPR/BP3738LS for both phases of the site.

	Date	Nox (mg/m3)	CO (mg/m3)	Fail/Pass	Action Taken
Unit 1					

Date	CH4 % v/v	CO2 % v/v	O2 % v/v	Balance % v/v	Suction -mb
12/04/2021	62.4	41.3	0.1	0	-17.86
13/04/2021	51.02	31.81	0.69	16.48	-14.79
23/04/2021	50	30.1	0.9	19	-23.6
05/05/2021	48.6	30.6	1.3	19.5	-19.52
14/05/2021	50.3	30.4	1.3	18	-31.76
17/05/2021	49.9	29.6	1.1	19.4	-30
20/05/2021	54.9	34.4	0.3	10.5	-15.62
26/05/2021	49.1	29.2	1	20.7	-30
04/06/2021	43.5	28.1	1.3		-30
07/06/2021	48.4	31.5	0.5	19.6	-8.5
21/06/2021	51	31.3	1.1		-12.6
22/06/2021	48.9	29.8	1.3		-13.4
25/06/2021	48.7	28.7	1.2		-29.7
28/06/2021	47.5	28.3	1.1	23.1	-29.4

Note: Permit Number EPR/BP3738LS for both phrases of the site.

Del. Pressure mb
154
142
137
158.02
140.51
118
172.98
122
122
138
138
121
123