

Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	PAN - 005141
Name of operator	NEWBRIDGE ENERGY LTD
Location of Facility	BRICKFIELD LANE, RUTTING
Time and date of the detection	18 05 21

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution	
To be notified within 24 hours of detection	
Date and time of the event	18 05 21 - EARLY HOURS
Reference or description of the location of the event	UN PLANNED SHUT DOWN OF NBI, DUE TO A DUAL SCREEN FAILURE
Description of where any release into the environment took place	NO RELEASE AS THE SHUTDOWN WAS CONTROLLED
Substances(s) potentially released	NO RELEASE
Best estimate of the quantity or rate of release of substances	NA
Measures taken, or intended to be taken, to stop any emission	NA
Description of the failure or accident.	FAILURE OF A DUAL SCREEN ON NBI.

(b) Notification requirements for the breach of a limit NO BREACH OF LIMIT	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	


(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	NO DETECTION OF SIGNIFICANT ADVERSE EFFECTS TO THE ENVIRONMENT
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	THE DURO SCREEN WAS REPLACED 18 05 21 AND THE N61 BOILER WAS STARTED USING DRY CHIP.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	THE START UP AND EMISSIONS FROM THE STACK DURING START UP WERE CLOSELY MONITORED.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	REBECCA TAYLOR
Post	COMPLIANCE
Signature	
Date	19 05 21

* authorised to sign on behalf of the operator