

REFERENCE W1 Treated Effluent.

Permit Reference Number: GP 32 35 GH

Operator: Randall Parker Foods

Installation: Oakley Park Abattoir, Dolwen, Oakley Park, Llanidloes, Powys. SY18 6LX

Form Number: W1

Reference W1 Date - 28/01/21

Reporting of emissions to water (other than sewer) for the period from

Time - 11:00am

Emission Point	Substance / Parameter	Emission Limit Value	Result [1]	Test Method [2]	Sample Date & Times [3]	Accreditation / Certification [4]	Uncertainty [5]
W1	BOD	40mg/l	17.5mg/l	SCA blue book 130 ISBN 0117522120	28/1/2021 11:00am	UKAS 1291	24.5 %
W1	Suspended Solids	60mg/l	17.6mg/l	SCA blue book 105 ISBN 011751957X	28/1/2021 11:00am	UKAS 1291	12.1 %
W1	Ammoniacal Nitrogen (as N)	25mg/l	13.2mg/l	SCA blue book 48 ISBN 0117516139	28/1/2021 11:00am	UKAS 1291	4.8 %
W1	Daily effluent flow rate	300m ³ /day	185.5m ³ /day	To a relevant EN, BS, ISO standard as agreed in IC6	Average calculated with 18 days Discharge	Mcerts	+/- 8%
W1	pH	6 - 10	7.16	SCA blue book 14 ISBN 0117514284	28/1/2021 11:00am	UKAS 1291	0.6 %

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result given as the 'minimum - maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated e.g. colorimetry.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements. Or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated. The following uncertainties are quoted on a different basis (basis as stated).

Signed:  Date: 28/1/2021
(authorised to sign as representative of the Operator)

Please also test for C.O.D.



585935

Superseded Report:

11:35:03 07/02/2021

REFERENCE W1 Treated Effluent.

Permit Reference Number: GP 32 35 GH

Operator: Randall Parker Foods

Installation: Oakley Park Abattoir, Dolwen, Oakley Park, Llanidloes, Powys, SY18 6LX

Form Number: W1

Reference W1 Date - 25/02/21

Reporting of emissions to water (other than sewer) for the period from

Time - 11:00am

Emission Point	Substance / Parameter	Emission Limit Value	Result [1]	Test Method [2]	Sample Date & Times [3]	Accreditation / Certification [4]	Uncertainty [5]
W1	BOD	40mg/l	<2mg/l	SCA blue book 130 ISBN 0117522120	25/2/2021 11:00am	UKAS 1291	24.5 %
W1	Suspended Solids	60mg/l	<4mg/l	SCA blue book 105 ISBN 011751957X	25/2/2021 11:00am	UKAS 1291	12.1 %
W1	Ammoniacal Nitrogen (as N)	25mg/l	11.4mg/l	SCA blue book 48 ISBN 0117516139	25/2/2021 11:00am	UKAS 1291	4.8 %
W1	Daily effluent flow rate	300m ³ /day	164.7m ³ /day	To a relevant EN, BS, ISO standard as agreed in IC6	Average calculated with 17 days Discharge 25/2/2021	Mcerts	+/- 8%
W1	pH	6 - 10	7.95	SCA blue book 14 ISBN 0117514284	25/2/2021 11:00am	UKAS 1291	0.6 %

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result given as the 'minimum - maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated e.g. colorimetry.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements: Or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated. The following uncertainties are quoted on a different basis (basis as stated).

Signed:  Date: 25/2/2021
(authorised to sign as representative of the Operator)

Please also test for C.O.D.

SDG:	210226-99
Location:	W1 Treated Effluent

Client Reference: Not Specified
Order Number:

Report Number:	589302
Superseded Report:	

[illegible]

REFERENCE EFL Treated Effluent.

Permit Reference Number: GP 32 35 GH

Operator: Randall Parker Foods

Installation: Oakley Park Abattoir, Dolwen, Oakley Park, Llanidloes, Powys. SY18 6LX

Form Number: W1

Reference W1 Date - 18/3/21

Reporting of emissions to water (other than sewer) for the period from

Time - 11:00am

Emission Point	Substance / Parameter	Emission Limit Value	Result [1]	Test Method [2]	Sample Date & Times [3]	Accreditation / Certification [4]	Uncertainty [5]
W1	BOD	40mg/l	10.9mg/l	SCA blue book 130 ISBN 0117522120	18/03/2021 11:00am	UKAS 1291	24.5 %
W1	Suspended Solids	60mg/l	24.5mg/l	SCA blue book 105 ISBN 011751957X	18/03/2021 11:00am	UKAS 1291	12.1 %
W1	Ammoniacal Nitrogen (as N)	25mg/l	15.2mg/l	SCA blue book 48 ISBN 0117516139	18/03/2021 11:00am	UKAS 1291	4.8 %
W1	Daily effluent flow rate	300m ³ /day	157.6m ³ /day	To a relevant EN, BS, ISO standard as agreed in IC6	Average calculated with 19 days Discharge	Mcerts	+/- 8%
W1	pH	6 -10	7.78	SCA blue book 14 ISBN 0117514284	18/03/2021 11:00am	UKAS 1291	0.6 %

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result given as the 'minimum - maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated e.g. colorimetry.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements. Or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval unless otherwise stated. The following uncertainties are quoted on a different basis (basis as stated).

Signed:  Date: 18/3/2021
(authorised to sign as representative of the Operator)

Please also test for C.O.D.

SDG: 210323-47
Location: RPF

[illegible]