

TITLE :	Annual Reporting of Emissions to Air		ISSUE NO.	4.0	
REF :	RCF50	AREA:	Site	DATE OF ISSUE:	16.06.11
RELATED DOCUMENT:			PAGE:	1 of 1	
FILENAME:	RCF 50 Reporting of Annual Emissions to Air (A2) Boilers Q1 & Q2 2020		Last printed 07/07/2020 17:03:00		



Permit Reference Number	BU2357 / AP363455
Installation :	Mostyn, Flintshire

Operator:	Warwick Chemicals
Form Number :	A2 / (Combustion process)

Reporting of Emissions to Air for the period:	From	1 st January 2020	To:	30 th July 2020
--	-------------	------------------------------	------------	----------------------------

Emission Point	Substance/Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
A17	Oxides of Nitrogen	170mg/m ³ ^[6]	157mg/m ³	BS EN 14792	13 th May 2020 15.11 – 16.11hrs	MCERTS	-
A18	Oxides of Nitrogen	170mg/m ³ ^[6]	138 mg/m ³	BS EN 14792	13 th May 2020 13.59 – 14.59hrs	MCERTS	-
A19	Oxides of Nitrogen	170mg/m ³ ^[6]	139mg/m ³	BS EN 14792	14 th May 2020 09.30 – 10.30hrs	MCERTS	-
A21	Oxides of Nitrogen	170mg/m ³ ^[6]	140mg/m ³	BS EN 14792	12 th May 2020 13.50 – 14.50hrs	MCERTS	-
A17	Carbon Monoxide	70mg/m ³ ^[6]	9.8mg/m ³	BS EN 15058	13 th May 2020 15.11 – 16.11hrs	MCERTS	-
A18	Carbon Monoxide	70mg/m ³ ^[6]	9.1 mg/m ³	BS EN 15058	13 th May 2020 13.59 – 14.59hrs	MCERTS	-
A19	Carbon Monoxide	70mg/m ³ ^[6]	6.1mg/m ³	BS EN 15058	14 th May 2020 09.30 – 10.30hrs	MCERTS	-
A21	Carbon Monoxide	70mg/m ³ ^[6]	64mg/m ³	BS EN 15058	12 th May 2020 13.50 – 14.50hrs	MCERTS	-

- [1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum measured values.
- [2] Where an internationally recognised standard test method is used the reference number is given; Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given. -
- [4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.
- [5] The uncertainty associated with the quoted result at the **95%** confidence interval, unless otherwise stated.
- [6] The emission limit values for oxides of nitrogen and carbon monoxide are expressed as a maximum individual hourly average value and corrected to 273K, 101.3kPa, 3% oxygen, dry.

Signed:	
	(Authorised to sign as representative of Warwick Chemicals)

Date:	7 th July 2020
--------------	---------------------------