


# Schedule 6 - Notification

## Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_268
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	08:10 26/4/21		

Any more accurate information on the matters for notification under Part A.	High temperature into W40 triggered opening of the emergency bypass, a safety device that operates when specific parameters reach set safety limits. The valve opened correctly. The high temperature was caused by a comms issue with the controller for a cooling valve that didn't open to control that temperature. It took until 08:19 to restart the enetex abatement burner and divert the blast back to the cupola
Measures taken, or intended to be taken, to prevent a recurrence of the incident	An additional alarm has been installed in WinCC to improve resilience of the system enabling action to help prevent reaching the high temperature that triggers the safety action.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	08/05/19, 12/06/19, 13/06/19, 18/06/19, 04/07/19, 08/07/19, 16/07/19, 06/08/19, 08/08/19, 16/08/19, 07-09/09/19, 16/09/19, 19/09/19, 02/10/19, 03/10/19, 25-27/10/19, 31/10/19, 24/11/19, 25/2/20, 12-14/5/20, 22-26/5/20, 22/6-2/7/20, 8/7/20, 16/8/20, 15/9/20, 6/10/20, 7/10/20, 16/2/21, 22/2/21 27/2-3/3/21, 9/3/21, 17-28/3/21, 5/4/21, 7-11/4/21

<b>Name*</b>	Graham Jones
<b>Post</b>	Environment Energy and Compliance Manager
<b>Signature</b>	
<b>Date</b>	8/7/2021

\* authorised to sign on behalf of Knauf Insulation Ltd