

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2  
for the period 1.1.21 – 31.1.21**

| Emission Point | Parameter                        | Emission Limit Value | Result       | Date of Measurement | Method       |
|----------------|----------------------------------|----------------------|--------------|---------------------|--------------|
| W1             | pH (minimum)                     | 6                    | 7.87         | 13.1.21             | BS ISO10523  |
| W1             | pH (maximum)                     | 9                    | -            | -                   | BS ISO10523  |
| W1             | Total Suspended Solids (Maximum) | 50 mg/l              | 17.5         | 13.1.21             | BS EN 872    |
| W1             | Oil or Grease                    | None Present         | None Visible | 13.1.21             | Visual Check |
| W2             | pH (minimum)                     | 6                    | -            | -                   | BS ISO10523  |
| W2             | pH (maximum)                     | 9                    | -            | -                   | BS ISO10523  |
| W2             | Total Suspended Solids (Maximum) | 50 mg/l              | -            | -                   | BS EN 872    |
| W2             | Oil or Grease                    | None Present         | -            | -                   | Visual Check |

Signed : G Taubman                      Date: 11.2.2021  
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)