

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2  
for the period 1.2.21 to 28.2.21**

<b>Emission Point</b>	<b>Parameter</b>	<b>Emission Limit Value</b>	<b>Result</b>	<b>Date of Measurement</b>	<b>Method</b>
<b>W1</b>	pH (minimum)	6	<b>8.14</b>	<b>10.2.21</b>	BS ISO10523
<b>W1</b>	pH (maximum)	9	-	-	BS ISO10523
<b>W1</b>	Total Suspended Solids (Maximum)	50 mg/l	<b>&lt;4</b>	<b>10.2.21</b>	BS EN 872
<b>W1</b>	Oil or Grease	None Present	<b>None Visible</b>	<b>10.2.21</b>	Visual Check
<b>W2</b>	pH (minimum)	6	-	-	BS ISO10523
<b>W2</b>	pH (maximum)	9	-	-	BS ISO10523
<b>W2</b>	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
<b>W2</b>	Oil or Grease	None Present	-	-	Visual Check

Signed : G Taubman  
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date : 9.3.2021