

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/CP3795FY
Name of operator	Sims Group UK Limited
Location of Facility	Northside, South Dock, Alexandra Dock, Newport, NP20 2WE
Time and date of the detection	Date of sampling - 17/01/2021

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment	
To be notified Immediately	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

(b) Notification requirements for the breach of a permit condition	
To be notified immediately	
Emission point reference/ source	Emission Point reference 7 stated in Schedule 3, Table S3.3 (sample taken from TSP1)
Parameter(s)	Copper
Limit	40ug/l
Measured value and uncertainty	55ug/l
Date and time of monitoring	17/01/2021
Measures taken, or intended to be taken, to stop the emission	An investigation has been undertaken. We have been unable to identify the root cause/ attribute an activity to the elevated result. A sample will be taken at the next rainfall event.

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

--	--

(c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment:

To be notified immediately	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	A sample will be taken at the next rainfall event.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	Georgina Sidney
Post	SHEC Business Partner
Signature	G Sidney
Date	19/02/2021

* authorised to sign on behalf of the operator