


Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_276
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	18/06/2021 10:30		

Any more accurate information on the matters for notification under Part A.	The fibre optic cable appeared to have been damaged while fitting a new weather protection box around the housing for the CEM Opsis system mirrors.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	A spare fibre optic cable was on site and this was fitted to restore all the affected CEMs measurements on 18/6/21. Another fibre optic cable is being ordered to restore having a spare available on site.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	04/07/19, 08/07/19, 16/07/19, 06/08/19, 08/08/19, 16/08/19, 07-09/09/19, 16/09/19, 19/09/19, 02/10/19, 03/10/19, 25-27/10/19, 31/10/19, 24/11/19, 25/2/20, 12-14/5/20, 22-26/5/20, 22/6-2/7/20, 8/7/20, 16/8/20, 15/9/20, 6/10/20, 7/10/20, 16/2/21, 22/2/21, 27/2-3/3/21, 9/3/21, 17-28/3/21, 5/4/21, 7-11/4/21, 24-25/4/21, 26/4/21, 12/5/21, 14/5/21, 17/5/21, 22-27/5/21, 8-9/6/21, 11-13/6/21, 17-18/6/21

Name*	Graham Jones
Post	Process and Energy Manager
Signature	
Date	8/7/2021

* authorised to sign on behalf of Knauf Insulation Ltd