

Schedule 5 Notification

PART A

Permit Number:	BR9715B
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	'W1' Effluent Pipeline
Time and date of the emission:	08/06/2021

Substance(s) emitted	Media e.g. air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Site effluent	Liquid discharge	Leak estimated at <100 l/h (whilst pumping operational)	Leading up to 08/06/2021

Description of the failure or accident, and... Measures taken, or intended to be taken, to stop the emission:	During a routine inspection, a leak was noted on the site main effluent discharge pipeline, at the on-site connection where the above-ground section meets the cast-iron underground effluent pipeline proper Physical & planning preparations have been made such that the repair can be effected at the first possible opportunity (i.e. the next day). This necessitates pipeline drain-down in order to carry out the (time-limited) repair during the low-tide 'cease discharge' window
--	--

* Signed:



Date: 09/06/2021

* authorised to sign on behalf of Solutia UK Ltd