

Compliance Report

Company:Harsco Environmental Contact:Paul Roberts

Authorisation number (s):Lancing Booth Stack Monitor Q3 2021

No exceedances

From:01 Jul 21 00:52:34 To:30 Sep 21 00:52:34

Device 1 : Stack1 Dust Cal Factor: WARNING CAL FACTOR IS NOT CONSTANT Average:0.275 Averaging Period:1 hrs

Emission Limit: 20.00 INDmg/m3

Date	Max Value (INDmg/m3)	Number of failures	95% Compliance	Max < 150% Limit
01 Jul 21	0.01	0	pass	pass
02 Jul 21	0.02	0	pass	pass
03 Jul 21	0.55	0	pass	pass
04 Jul 21	0.63	0	pass	pass
05 Jul 21	1.31	0	pass	pass
06 Jul 21	0.45	0	pass	pass
07 Jul 21	0.38	0	pass	pass
08 Jul 21	0.01	0	pass	pass
09 Jul 21	0.01	0	pass	pass
10 Jul 21	0.02	0	pass	pass
11 Jul 21	0.55	0	pass	pass
12 Jul 21	1.12	0	pass	pass
13 Jul 21	0.29	0	pass	pass
14 Jul 21	1.25	0	pass	pass
15 Jul 21	0.06	0	pass	pass
16 Jul 21	0.01	0	pass	pass
17 Jul 21	0.02	0	pass	pass
18 Jul 21	0.03	0	pass	pass
19 Jul 21	0.01	0	pass	pass
20 Jul 21	0.01	0	pass	pass
21 Jul 21	0.01	0	pass	pass
22 Jul 21	0.01	0	pass	pass
23 Jul 21	0.01	0	pass	pass
24 Jul 21	0.26	0	pass	pass
25 Jul 21	0.02	0	pass	pass
26 Jul 21	0.01	0	pass	pass
27 Jul 21	0.09	0	pass	pass
28 Jul 21	2.14	0	pass	pass
29 Jul 21	9.41	0	pass	pass
30 Jul 21	6.29	0	pass	pass
31 Jul 21	0.13	0	pass	pass
01 Aug 21	0.04	0	pass	pass
02 Aug 21	1.36	0	pass	pass
03 Aug 21	9.08	0	pass	pass
04 Aug 21	7.31	0	pass	pass
05 Aug 21	0.57	0	pass	pass
06 Aug 21	0.09	0	pass	pass
07 Aug 21	0.72	0	pass	pass
08 Aug 21	0.59	0	pass	pass
09 Aug 21	1.71	0	pass	pass
10 Aug 21	0.02	0	pass	pass
11 Aug 21	0.05	0	pass	pass
12 Aug 21	0.66	0	pass	pass
13 Aug 21	0.02	0	pass	pass
14 Aug 21	0.19	0	pass	pass
15 Aug 21	0.07	0	pass	pass
16 Aug 21	0.05	0	pass	pass
17 Aug 21	0.01	0	pass	pass
18 Aug 21	0.01	0	pass	pass
19 Aug 21	0.02	0	pass	pass
20 Aug 21	6.29	0	pass	pass
21 Aug 21	0.18	0	pass	pass
22 Aug 21	0.10	0	pass	pass
23 Aug 21	0.05	0	pass	pass
24 Aug 21	0.09	0	pass	pass
25 Aug 21	0.06	0	pass	pass
26 Aug 21	4.07	0	pass	pass
27 Aug 21	0.01	0	pass	pass
28 Aug 21	0.01	0	pass	pass
29 Aug 21	0.01	0	pass	pass
30 Aug 21	0.01	0	pass	pass
31 Aug 21	0.01	0	pass	pass
01 Sep 21	0.01	0	pass	pass
02 Sep 21	0.01	0	pass	pass
03 Sep 21	0.01	0	pass	pass
04 Sep 21	0.01	0	pass	pass
05 Sep 21	0.01	0	pass	pass
06 Sep 21	0.01	0	pass	pass
07 Sep 21	6.36	0	pass	pass
08 Sep 21	8.41	0	pass	pass

Date	Max Value (INDmg/m3)	Number of failures	95% Compliance	Max < 150% Limit
09 Sep 21	0.09	0	pass	pass
10 Sep 21	0.07	0	pass	pass
11 Sep 21	0.02	0	pass	pass
12 Sep 21	0.01	0	pass	pass
13 Sep 21	0.11	0	pass	pass
14 Sep 21	4.40	0	pass	pass
15 Sep 21	7.12	0	pass	pass
16 Sep 21	4.75	0	pass	pass
17 Sep 21	5.57	0	pass	pass
18 Sep 21	0.08	0	pass	pass
19 Sep 21	0.06	0	pass	pass
20 Sep 21	8.61	0	pass	pass
21 Sep 21	10.01	0	pass	pass
22 Sep 21	5.12	0	pass	pass
23 Sep 21	0.26	0	pass	pass
24 Sep 21	0.01	0	pass	pass
25 Sep 21	0.02	0	pass	pass
26 Sep 21	0.09	0	pass	pass
27 Sep 21	1.07	0	pass	pass
28 Sep 21	10.47	0	pass	pass
29 Sep 21	6.84	0	pass	pass
30 Sep 21	0.11	0	pass	pass