

**FORM WATER 1b: Emissions to controlled water (W1) – Weekly and quarterly samples**

Permit Number: EPR/KP3036AX

Operator: Puma Energy (UK) Limited

Installation Location: Milford Haven Terminal, Milford Haven, SA73 3JD


Q3 2021

Parameters: COD, Cyanides, Suspended Solids

Release Point	W1 discharge from effluent treatment plant		
Parameter	ELV (mg/l)	3-month average of weekly results (mg/l)	Maximum weekly result (mg/l)
COD	200	62	70
Sulphides	1	0.2	0.2
Suspended Solids	45	12	16

Parameters: Copper, Nickel, Iron, Zinc, Arsenic, Chromium, Lead, Mercury, Cadmium

Release Point	W1 discharge from effluent treatment plant		
Parameter	ELV (µg/l)	3-month average of quarterly results (µg/l)	Maximum result (µg/l)
Copper	220	<1	<1
Nickel	120	5.28	5.28
Iron	4000	1920	1920
Zinc	85	23.1	23.1
Arsenic	-	<2	<2
Chromium	-	<3	<3
Lead	-	<1	<1
Mercury	2.4	<0.02	<0.02
Cadmium	8	<0.5	<0.5

Signed   
 Name Edmund Whitmore  
 On behalf of the Operator Puma Energy (UK) Limited  
 Date 06/10/2021