

Permit Number: EPR/TP3639BH

Operator: Celsa Manufacturing (UK) Limited

Facility: Tremorfa Melt Shop


Form Number: Process Monitoring1 / 14/10/2020

Reporting of Asphalt Plant process monitoring particulate CEM for the period from 01/07/2020 to 30/09/2020

Emission Point	Substance / Parameter	Trigger level	Parameter	Result
			Number of hourly averages recorded	
A5	Particulate Matter (indicative CEM)	20 mg/m ³	Number of hourly averages during plant operation (excluding start up and shut down) over trigger level	725 0

Notes: A review of the data concluded that there were no hourly averages over the trigger level for the 3rd quarter, however a number anomalies were identified, first on the 17/08/2020 where data was recorded on the stack sensor even though the Asphalt Plant was not in operation. On Investigation, the most likely cause is rain falling vertically down the stack and impinging the probe and looking at the weather for the time of the readings light rain was forecasted but this varies from different sources. Note: we have not experienced a reoccurrence of this anomaly. Also on the 17/09/2020, we were upgrading the data retrieval system, this caused 3 "ghost" readings on the 17th and 18th September.

Signed


(Authorised to sign as representative of Operator)

Date: 14/10/2020