

**Notice of refusal**

Environmental Permitting (England and Wales) Regulations 2016

**Refusal of an application for a variation of a permit**

Application number: PAN-013449

Permit number: CG0070201

To: Mr David Thornley  
Thornley Leisure Parks Limited  
William Sutcliffe Suite  
Raymond Court  
Princes Drive  
Colwyn Bay  
Conwy  
LL29 8HT

Natural Resources Wales has considered your application. We give notice that the application for a variation of a permit is refused.

The reasons for this decision are outlined in the attached schedule.

Name	Date
<b>Melissa Broad</b>	<b>27<sup>th</sup> October 2021</b>

Authorised on behalf of Natural Resources Wales

## **Schedule**

### **Reasons for Refusal**

Water quality modelling was used to derive an environmentally protective ammonia limit which was calculated to be 10mg/l. After numerous discussions with the Agent and Operator, it was stated in an email from the Operator to the Environment Team Leader dated the 20th September 2021, that the Operator will not be able to and therefore is not willing to comply with the limit of 10mg/l of ammonia so therefore the application to vary the permit is refused.

The refusal decision document explains how we reached our decision.