

Reference conditions

All concentrations in this spreadsheet are reported in dry air at a temperature of 273K, at a pressure of 10

Uncertainty

Concentrations in this spreadsheet are reported after having subtracted the value of the 95% confidence i

95% confidence interval for nitrogen oxides is taken to be 20%

95% confidence interval for sulphur dioxide is taken to be 20%

95% confidence interval for dust is taken to be 30%

95% confidence interval for carbon monoxide is taken to be 10%

Normal operating conditions

The document "Power Plant Boiler Abnormal Conditions" sets out the criteria for excluding emissions mor

Parameter	Plant	Level representing abnormal conditions
Boiler oxygen	All boilers	>17% oxygen
Fuel input	A51, A52A, A52B, A53 and A62	<50% BFG by thermal input
	A50 (Service Boilers)	<35% BFG by thermal input