



EMISSIONS MONITORING SURVEY

Prepared for:

Babcock & Wilcox Volund Limited.

Margam Green Energy Plant

Harbour Way

Margam

Port Talbot

Neath Port Talbot

SA13 2NW

Permit Number	: EPR/DP3137EG
Variation Number	: ...
Installation	: A1 Incinerator
Visit Details	: PM10 & 2.5 - November 2020 Visit
Job Number	: P4246
Report Number	: R004
Report Issue Date	: 15th January 2021
Survey Dates	: 25th November 2020

Prepared by:

Environmental Compliance Limited

Unit G1

Main Avenue

Treforest Industrial Estate

Pontypridd

CF37 5BF.

Tel: 01443 841760

Fax: 01443 841761

Report Issue:		FINAL	
Report Prepared by:		Report Reviewed & Approved by MCERTS Level Two Technical Endorsements TE1, TE2, TE3 & TE4	
Name:	Harry Round	Name:	Andy Barnes
		MCERTS No:	MM 03 235
		Signature:	
Date:	5 th January 2021	Date:	15 th January 2021

This report is not to be used for contractual or engineering purposes unless this approval sheet is signed where indicated by the approver and the report is designated "FINAL".



2499

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
Permit No : EPR/DP3137EG
Variation No : ...
Report Ref : P4246 : R004

Installation Name : A1 Incinerator
Visit Details : PM10 & 2.5 - November 2020 Visit
Survey Dates : 25th November 2020
Report Issue Date. : 15th January 2021

This report has been prepared by Environmental Compliance Limited (ECL) in their professional capacity as Environmental Consultants. The contents of the report reflect the conditions that prevailed and the information available or supplied at the time of its preparation. The report, and the information contained therein, is provided by ECL solely for use and reliance by the Client in performance of ECL's duties and liabilities under its contract with the Client. Until ECL has received payment in full as detailed in the quotation or contract the contents of this report remain the legal property of ECL. The contents of the report do not, in any way, purport to include any manner of legal advice or opinion.

Any operating information and CEMS data used in this report has been supplied by the client.

This report should not be reproduced, (except in full) without the written approval of the laboratory.

Should the Client wish to release this report to a Third Party for the party's reliance, Environmental Compliance Ltd may, at its discretion, agree to such release provided that:

- Environmental Compliance Ltd gives written agreement prior to such release and ECL has received payment in full for all works/services undertaken;
- By release of the report to the Third Party, that Third Party does not acquire any rights, contractual or otherwise, whatsoever against Environmental Compliance Ltd and, accordingly, Environmental Compliance Ltd assume no duties, liabilities or obligations to that Third Party;
- Environmental Compliance Ltd accepts no responsibility for any loss or damage incurred by the Client or for any conflict of Environmental Compliance Ltd interests arising out of the Client's release of this report to the Third Party.

In the event that a report is revised and re-issued, the client shall ensure that any earlier versions of the report, and any copies thereof, are void and such copies should be marked with the words "superseded and revised".

Opinions and Interpretation expressed within this report are outside the scope of the UKAS accreditation.

MCERTS requirements mean that comparison of results with emissions limit values is not permitted within this report.

TABLE OF CONTENTS

Section	Description	Page Number
	Document Control Sheet	
PART 1	EXECUTIVE SUMMARY	4
1	MONITORING OBJECTIVES	4
1.1	Monitoring Results	5
1.2	Operating Information	6
2	MONITORING DEVIATIONS	7
PART 2	SUPPORTING INFORMATION	8
3	SAMPLING STAFF DETAILS	8
4	SAMPLING PROTOCOLS / METHODOLOGIES	9
5	SAMPLE POINT DESCRIPTIONS	10
	EQUIPMENT IDs	11
	TABLES	13
	VELOCITY TRAVERSE PROFILES	15
	FIELD CALIBRATION AND SAMPLING DATA	17
	LABORATORY ANALYSIS RESULTS	20
	UNCERTAINTY CALCULATIONS	22

PART 1 - EXECUTIVE SUMMARY

1 Monitoring Objectives

Environmental Compliance Ltd (ECL) was commissioned by **Babcock & Wilcox Volund Limited** to undertake an emission monitoring survey at their **Margam Green Energy Plant**. This report presents the findings of the study.

The monitoring at this installation was carried out in accordance with our quotation reference **DHFB/P4246/Q002**, for compliance check monitoring of emissions to air. The substances requested for monitoring at each emissions point are listed below:

Substances to be monitored	Emission Point Identification
	A1
Velocity / Flowrate	● U
Oxygen	● U
PM10/ PM2.5	● U

- Denotes the substances to be monitored.
- U Denotes UKAS accreditation is held for monitoring that substance, but does not mean that it has been claimed which will depend on whether the testing could be completed in accordance with the Standard Reference Method.

Special Requirements: During Normal Operation.

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
 Permit No : EPR/DP3137EG
 Variation No : ...
 Report Ref : P4246 : R004

Installation Name : A1 Incinerator
 Visit Details : PM10 & 2.5 - November 2020 Visit
 Survey Dates : 25th November 2020
 Report Issue Date : 15th January 2021

1.1 Monitoring Results

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
A1	Volumetric Flowrate	...	88.47338	m ³ /sec	4	Stack Conditions	23/11/2020	12:00 – 13:05	BS EN 16911-1:2013 & MID	UKAS / MCERTS		Normal
	Volumetric Flowrate	...	51.27988	m ³ /sec	6	Dry & 6% O ₂	23/11/2020	12:00 – 13:05	BS EN 16911-1:2013 & MID	UKAS / MCERTS		
	Particulate Fraction <PM ₁₀ [§]	...	0.74	mg/m ³	8	Dry & 6% O ₂	25/11/2020	09:20 – 12:20	BS EN ISO 23210:2009	UKAS / MCERTS		
	Particulate Fraction <PM _{2.5} [§]	...	0.64	mg/m ³	8	Dry & 6% O ₂	25/11/2020	09:20 – 12:20	BS EN ISO 23210:2009	UKAS / MCERTS		
	Particulate Fraction <PM ₁₀ [§]	...	0.66	mg/m ³	8	Dry & 6% O ₂	25/11/2020	13:00 – 16:00	BS EN ISO 23210:2009	UKAS / MCERTS		
	Particulate Fraction <PM _{2.5} [§]	...	0.55	mg/m ³	8	Dry & 6% O ₂	25/11/2020	13:00 – 16:00	BS EN ISO 23210:2009	UKAS / MCERTS		

The volumetric flowrate shown above is that from the initial pitot traverse.

Any other flow measurements made during isokinetic sampling and/ or repeat traverses are shown later in the tables section.

Notes

Emission Limit Value
 Periodic Monitoring Result
 Uncertainty
 Reference Conditions
 Monitoring Method Reference
Accreditation for use of Method
 Operating Status
[§]
 NU
 NA

The emission limit value is that stated in the permit and will be expressed as a concentration or a mass emission.
 The result given is expressed in the same terms and units as the emission limit value.
 The uncertainty associated with the quoted result is at the 95% confidence interval. The Uncertainty results **DO NOT** take into account the effect of the sample location limitations.
 All results are expressed at 273 K and 101.3kPa. The oxygen and moisture corrections are stated.
 The method stated is in accordance with the Environment Agency Technical Guidance Note M2, or other method approved by the Environment Agency.
The details indicate the accreditation for the use of the complete monitoring method, e.g. MCERTs, UKAS. If use of the method is not accredited " NA" is stated.
 The details indicate the feedstock and the loading rate of the plant during monitoring.
 Chemical Analysis on sample reagents was performed by an External Laboratory as detailed in Section 4
 UKAS Accreditation Held but UKAS Accreditation cannot be claimed for the test as sampling did not comply with the Standard Reference Method (SRM), see section 2 & 5
Method is NOT UKAS Accredited.

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
 Permit No : EPR/DP3137EG
 Variation No : ...
 Report Ref : P4246 : R004

Installation Name : A1 Incinerator
 Visit Details : PM10 & 2.5 - November 2020 Visit
 Survey Dates : 25th November 2020
 Report Issue Date. : 15th January 2021

1.2 Operating Information

Any operating information and CEMS data below has been supplied by the client.

Emission Point Reference	Process Type	Process Duration	Fuel	Feedstock	Abatement	Load	Comparison of Operator CEMS and Periodic Monitoring Results					
							Parameter	Date	Time	CEMS Results	Periodic Monitoring Results	Units
A1	Continuous	Continuous	Wood	Wood Grade 2-4	PAC, Lime & SNCR Injection, NH ₃	100%	NP

Notes:

Process Type State whether the process is a continuous or batch process.
 Process Duration If a batch process, state the duration, frequency and details of the portion of the batch sampled. If continuous state "NA"
 Fuel If applicable, state the fuel type If not applicable state "NA"
 Feedstock State the feedstock type
 Abatement State the type and whether operational during monitoring. If not applicable state "NA"
 Load State the normal load, throughput or rating of the plant
 CEMS Data Enter this data for each CEM installed if it is has been provided by operator otherwise state "NP" (NOT PROVIDED)

Babcock & Wilcox Volund Limited
Permit No : EPR/DP3137EG
Variation No : ...
Report Ref : P4246 : R004

Installation Name : A1 Incinerator
Visit Details : PM10 & 2.5 - November 2020 Visit
Survey Dates : 25th November 2020
Report Issue Date. : 15th January 2021

2 Monitoring Deviations

The objective of the survey was to measure the concentrations of pollutants from the processes / locations as detailed in Section 1. This survey meets the requirements of the site's **PPC Permit Number: EPR/DP3137EG** where UKAS and MCERTS accreditation has and could be claimed for the testing in the monitoring results table.

There were no modifications to the sampling procedures (TPDs) listed in section 4.

There were no substance deviations from the original and agreed emissions monitoring schedule.

There were no non-conforming tests.

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of non-conformities or sample location limitations

Homogeneity tests have not been completed for pollutants at the following locations: **A1**. Such tests were not requested by the client.

PART 2 – SUPPORTING INFORMATION

3 SAMPLING STAFF DETAILS

Site Sampling Team

Names of Site Team	Dates on Site	MCERTS No.	LEVEL	Technical Endorsements
Harry Round	25 th November 2020	MM 14 1278	2	TE1, TE2, TE3, TE4
Scott Hackett		MM 07 889	2	TE1, TE2, TE3, TE4
Peter Brockway		MM 17 1459	2	TE1, TE4
Zac Watkinson		MM 20 1612	Trainee	...

Report Reviewer

Name	MCERTS No.	LEVEL	Technical Endorsements
Andy Barnes	MM 03 235	2	TE1, TE2, TE3, TE4

Technical Endorsement Key:-

- TE1 – Isokinetic** Particulates, Temperature & Velocity Profiles, Oxygen.
- TE2 – Isokinetic** Extractive Pollutants:- Metals, Dioxin & Furans, PAHs, PCBs, HCl, HF.
- TE3 – Non-Isokinetic** Extractive Pollutants:- Speciated VOCs, HF, HCl, Cyanide.
- TE4 – Continuous Analysers** (Combustion Gases):- TVOC, CO, NOx, SO2.

4 SAMPLING PROTOCOLS / METHODOLOGIES

Details of the substances monitored, the standard methods used and the Environmental Compliance Limited Technical Procedures used during this survey are shown in the table below. Detailed sampling protocols are included in a separate document which will be sent with the report.

In all cases, where analysis of collected samples was required, the analysis was by a subcontract laboratory. Details of the sub-contract laboratory are shown on the analysis certificates in this report. The UKAS/MCERTs accreditation status of the analysis is also indicated on the certificates.

Any required modifications to the Technical Procedure Documents (TPDs) specified below will be detailed in section 2 of this report.

Determinand	External Reference Method	ECL Technical Procedure Number
Velocity and Flowrate	BS EN 16911-1:2013 & MID	ECL/ TPD/ 022A
Oxygen (PG350)	BS EN 14789: 2017	ECL / TPD / 033D
PM 10 & PM 2.5	EN ISO 23210:2009	ECL / TPD / 095
Moisture	BS EN 14790: 2017	ECL / TPD / 082

5 SAMPLE POINT DESCRIPTIONS

The homogeneity test is applicable to combustion processes, but may also be requested by the regulator for non-combustion processes.

Homogeneity testing has not been completed at this location.

The test is not usually required for stacks with sampling plane areas of $< 1\text{m}^2$ (below 1.13m in diameter for circular ducts).

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of non-conformities or sample location limitations.

The sample location that was monitored is detailed below:

A1

The stack diameter is 2.40m and the sample platform width back from the sample port is 4m.

Two sample ports are located on the stack at 90 degrees to each other and are located on the same plane.

These sample ports are located at a height of approximately 1.2m from the working sample platform.

Access to the sample platform was attained by means of permanent ladder accessed from outside the main production building. Platform is approximately 45m from ground level. Two scaffold shelters were constructed, one at the base of the stack and one on the stack's platform.

Two transformers, with 6 x 110v (4x16amp, 2x32amp) sockets on each, are supplied at the base of the stack on request.

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
Permit No : EPR/DP3137EG
Variation No : ...
Report Ref : P4246 : R004

Installation Name : A1 Incinerator
Visit Details : PM10 & 2.5 - November 2020 Visit
Survey Dates : 25th November 2020
Report Issue Date. : 15th January 2021

EQUIPMENT IDs
(Pre site checklist from SSP)

Babcock & Wilcox Volund Limited
 Permit No : EPR/DP3137EG
 Variation No : ...
 Report Ref : P4246 : R004

Installation Name : A1 Incinerator
 Visit Details : PM10 & 2.5 - November 2020 Visit
 Survey Dates : 25th November 2020
 Report Issue Date. : 15th January 2021

PRE SITE EQUIPMENT CHECKLIST/ EQUIPMENT USED

(Completed before departure to site and when on site in full)

Equipment	Equip. Type	ID No:							
MST console/pump	E001	U010							
MST Nozzle set		905							
MST "S" Type Pitot		666	769						
MST Probe		143							
MST Hot Box		390							
MST Impinger Arm		391							
		...							
Barometer		627							
Site Balance		1069							
Site Check weights		190							
			191						
Horiba	E002	1065							
Heated Probe / Filter		632							
Chiller		970							
MFC									
Heated Line		875							
FID	E003								
Heated Line									
Heated Probe / Filter									
Testo	E004								
FTIR	E005								
Heated Probe / Filter									
Heated Line									
Stackmite	E006								
"L" Type Pitot									
Digital Manometer									
Stack Thermocouple		1198	857						
Thermocouple Reader									
Nozzle Set									
Workhorse Pumps	E007								
Stack Thermocouple									
Tube Thermocouple									
Meter Thermocouple									
High Vac Gauge									
Dioxin Thermocouple									

Quantity of Ice Required / Used for Survey	8	Bags (2kg bags)
--	---	-----------------

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
Permit No : EPR/DP3137EG
Variation No : ...
Report Ref : P4246 : R004

Installation Name : A1 Incinerator
Visit Details : PM10 & 2.5 - November 2020 Visit
Survey Dates : 25th November 2020
Report Issue Date. : 15th January 2021

TABLES

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
 Permit No : EPR/DP3137EG
 Variation No : ...
 Report Ref : P4246 : R004

Installation Name : A1 Incinerator
 Visit Details : PM10 & 2.5 - November 2020 Visit
 Survey Dates : 25th November 2020
 Report Issue Date. : 15th January 2021

Table 1 – PM10 / 2.5

Data Recorded from A1 - Incinerator

Emission Parameter	Units	PM 10 & 2.5 - 1	PM 10 & 2.5 - 2	Blank
Stack Diameter	metres	2.40		...
Area of Sample Plane	m ²	4.524		...
Moisture Content	%	17.13	16.55	...
Oxygen Content	%	5.77	5.60	...
Stack Temperature	°C	118	118	...
Gas Velocity (as Measured, adjusted for wall texture)	m/sec	19.9207	19.5681	...
Gas Velocity (Reference Conditions)	m/sec*	11.6722	11.6723	...
Volumetric Flowrate (as Measured)	m ³ /sec	90.1192	88.5241	...
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	52.8037	52.8043	...
Sample Date	...	25/11/2020	25/11/2020	...
Sample Period	...	09:20 - 12:20	13:00 - 16:00	...
Sample Volume (reference Conditions)	m ³ *	5.276	5.183	5.229
Isokinetic Sampling Rate	%	109.16	107.23	...
Sample Reference (ECL ID)	ECL/20/	6333 & 6332	6336 & 6335	6339 & 6338
Mass of PM 10 Collected	mg	3.91	3.41	0.08
Concentration of PM 10	mg/m ³ *	0.74	0.66	0.02
Emission Rate of PM 10	g/hr	140.88	125.07	...
Mass of PM 2.5 Collected	mg	3.38	2.83	0.04
Concentration of PM 2.5	mg/m ³ *	0.64	0.55	0.01
Emission Rate of PM 2.5	g/hr	121.78	103.80	...
Expanded Uncertainty (% Relative)	%	8	8	...

*Reference Conditions (273K, 101.3kPa, 6% Oxygen, Dry Gas)

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
Permit No : **EPR/DP3137EG**
Variation No : **...**
Report Ref : **P4246 : R004**

Installation Name : **A1 Incinerator**
Visit Details : **PM10 & 2.5 - November 2020 Visit**
Survey Dates : **25th November 2020**
Report Issue Date. : **15th January 2021**

VELOCITY TRAVERSE PROFILES

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
 Permit No : EPR/DP3137EG
 Variation No : ...
 Report Ref : P4246 : R004

Installation Name : A1 Incinerator
 Visit Details : PM10 & 2.5 - November 2020 Visit
 Survey Dates : 25th November 2020
 Report Issue Date : 15th January 2021

Environmental Compliance Limited	Traverse Data Profoma	Date of Measurement	23/11/2020
----------------------------------	-----------------------	---------------------	------------

Company	B&W Volund Ltd	Stack Diameter Port A (mm)	2400	Average Stack Diameter (mm)	2400	Pitot tube coefficient	0.85
Site	Margam	Stack Diameter Port B (mm)	2400	Port Length (mm)	250	Pitot Id	769
Location	Incinerator	Duct Length Port A (mm)		Average Duct Length (mm) L		Stack Thermocouple ID	1198
Stack	A1	Duct Length Port B (mm)		Duct width (mm) B		Stack Temp Reader ID	121
Job No	P4246	Duct Length Port C (mm)		Barometric Pressure. (mb)	1007	Manometer ID	120
Operators	HR / PB / ZW	Duct Length Port D (mm)		Ave Static Press. (mm H ₂ O)	-19.00	Barometer ID	627

Pre - Traverse Checks Carried Out	Time	Pass/ Fail
Pre - Traverse PITOT Visual Inspection	12:00:00	Pass
Pre - Traverse PITOT Leak Check	12:02:00	Pass

Smooth Walls

Static Pressure Readings (mm H ₂ O)			
Port A	Port B	Port C	Port D
-19.00	-19.00		

Port/ Point	Distance to Point (mm)	Time	Temperature Readings (°C)			(ΔP) Pitot Readings (mm H ₂ O)			Average Temp. (°C)	Average (ΔP) (mm H ₂ O)	Swirl Test ° From Reference
			1	2	3	1	2	3			
A1	78	12:06:00	118.0	118.0	118.0	16.00	17.00	16.50	118.0	16.50	11
A2	251	12:09:00	118.0	118.0	118.0	17.50	17.50	17.00	118.0	17.33	11
A3	465	12:12:00	118.0	118.0	118.0	20.00	19.50	20.00	118.0	19.83	10
A4	776	12:15:00	118.0	118.0	118.0	24.50	24.00	25.00	118.0	24.50	9
A5	1624	12:18:00	118.0	118.0	118.0	30.00	30.00	30.00	118.0	30.00	9
A6	1935	12:21:00	118.0	118.0	118.0	32.00	32.00	32.00	118.0	32.00	10
A7	2149	12:24:00	118.0	118.0	118.0	32.00	32.00	30.00	118.0	31.33	9
A8	2322	12:27:00	118.0	118.0	118.0	30.00	30.00	30.00	118.0	30.00	10
B1	78	12:30:00	118.0	118.0	118.0	16.00	16.00	16.00	118.0	16.00	12
B2	251	12:33:00	118.0	118.0	118.0	17.00	17.00	16.50	118.0	16.83	11
B3	465	12:36:00	118.0	118.0	118.0	19.00	20.00	20.00	118.0	19.67	11
B4	776	12:39:00	118.0	118.0	118.0	22.00	23.00	23.00	118.0	22.67	11
B5	1624	12:42:00	118.0	118.0	118.0	25.00	24.50	24.50	118.0	24.67	9
B6	1935	12:45:00	118.0	118.0	118.0	25.00	25.00	25.00	118.0	25.00	10
B7	2149	12:48:00	118.0	118.0	118.0	30.00	30.00	30.00	118.0	30.00	10
B8	2322	12:51:00	118.0	118.0	118.0	30.00	30.00	32.00	118.0	30.67	9
Blockage Check @ A1 (L-Type Pitot Only)									1888.0	387.0	Total
Mean									118.0	32.0	Max
Difference <5% from Initial ?									118.0	16.0	Min
Mean									118.0	24.2	Average

Stagnation Check (S-type Pitot Only)	Time	Reading
Static Pressure Via Positive Leg (mm H ₂ O)	12:55:00	-19.00
Static Pressure Via Negative Leg (mm H ₂ O)	12:58:00	-19.00
Difference (Pa) < 1 mm H ₂ O ?		0.00


Average temp (K)	391.000
--------------------	---------

Suitability of Sampling Position	Actual Stack Conditions
Highest/lowest flow pressure ratio < 9:1?	2:1
Maximum deviation of flow from axis < 15°?	12
X-sectional area for stacks = πr ²	4.52 m ²
X-sectional area for ducts = L x B	m ²
Suitability of Position for Sampling	OK

Post - Traverse Checks Carried Out	Time	Pass/ Fail
Post - Traverse PITOT Visual Inspection	13:02:00	Pass
Post - Traverse PITOT Leak Check	13:05:00	Pass

Stack Moisture	18.15	%	Gas Velocity (as Measured) Adjusted for Smooth Walls	19.55691	m/sec
Measured Oxygen	5.67	%	Gas Velocity (Reference Conditions) Adjusted for Smooth Walls	11.33534	m/sec*
Measured Carbon Dioxide	14.48	%	Volumetric Flowrate (as Measured) Adjusted for Smooth Walls	88.47338	m ³ /sec
Dry Gas Molecular Weight	30.54360	g/g mole	Volumetric Flowrate (Ref Cond) Adjusted for Smooth Walls	51.27988	m ³ /sec*

*Reference Conditions: 273K, 101.3kPa, 6% Oxygen, Dry Gas NOTE: Velocity / volume flowrate calculations exclude contributions from the measurement point(s) where swirl > 15°



Notes
 Including expected or actual deviations from procedures / non-conformities

Compliance With Positional Requirements?

Height of sample ports from Platform	1.2m
Number of sample ports	2
Width of platform (port back to handrail)	4m

Nearest downstream disturbance	Inlet	15m
Nearest upstream disturbance	Exit	20m

Disturbances are classed as bends, fans or diameter variations

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
Permit No : EPR/DP3137EG
Variation No : ...
Report Ref : P4246 : R004

Installation Name : A1 Incinerator
Visit Details : PM10 & 2.5 - November 2020 Visit
Survey Dates : 25th November 2020
Report Issue Date. : 15th January 2021

FIELD CALIBRATION AND SAMPLING DATA

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
 Permit No : EPR/DP3137EG
 Variation No : ...
 Report Ref : P4246 : R004

Installation Name : A1 Incinerator
 Visit Details : PM10 & 2.5 - November 2020 Visit
 Survey Dates : 25th November 2020
 Report Issue Date : 15th January 2021

PM10 / 2.5 - Test 1

Environmental Compliance Limited		PM10/2.5 DATA SAMPLING PROFORMA				Date of Measurement		25/11/2020							
ECL/TPD		095		Stoppages? (min)		0		Start Time		09:20		End Time		12:20	
Client	B & W Volund Ltd	Stack Profile	Circular	Console id	U010	Barometer id	628	Impinger 1	DI H ₂ O	Solution	SOL NO	Rinse Solutions used			
Site	Margam	Stack Area (m ²)	4.52	Pump id	U010	Nozzle id	905	SOL/	4165	DI Water	4165	DI Water	4165		
Location	Incinerator	Barometric Pressure (mb)	1011	Probe id	143	Nozzle size	6.97	Start Weight (g)	628.8	Acetone	4139	Acetone	4139		
Stack ID	A1	Static Pres. (mm H ² O)	-19	DGM Yd	0.9786	Impactor 1 Filter ID	1989-213206	End Weight (g)	862.7						
Test No.	PM 10 & 2.5 - 1	Pitot coefficient	0.86	ΔH@	48.32	Impactor 2 Filter ID	1989-213207	Total weight (g)	233.9						
Job No	P4246	Probe Heater Setting (°C)	160	Impinger Id	391	Back Up Filter ID	1989-213232								
ECL Site Staff	SH, HR, PB & ZW	Hot Box Setting (°C)	160	Balance Id	1069	Pitot ID	666	Impinger 2	DI H ₂ O						
		Visible deposits on internal walls in front of first nozzle plate? (Y/N)	N	Smooth Walls		Silica < 5% Spent at End of Test		Yes							
		Sampling Head Orientation (Vertical or Horizontal)	N	Total		FIXED ΔH Settings									
Start Volume	2018267.8	Head heated outside stack (due to moisture saturation?) (m)	N/A	Meter Temp.	30	Stack Temp	120	Impinger 3	DI H ₂ O						
Final Volume	2023872.2	Heating start and finish time	N/A	%Moisture	19.03			SOL/	4165						
Total Volume	5604.4	Equilibration in-stack start and finish time	09:20					Start Weight (g)	702.6						
								End Weight (g)	941.3						
								Total weight (g)	238.7						

Leak Check	First	Leak check is only performed before sampling	Measured O ₂ (Atmospheric)	5.77	Fixed ΔH	93.3
Rate Limit	0		Measured Carbon Dioxide %	14.48	Reference Oxygen Percentage	6
Vacuum *Hg	-15					
Time of Check	09:00					

Traverse Point	A4	A4	A4	A4	A4	A4	A4	A4	Total
TimePoint (mins)	0 - 10	10 - 20	20 - 30	30 - 40	40 - 50	50 - 60	60 - 70	70 - 80	
ΔH (mm H2O)	30.00	24.80	23.20	23.40	23.00	24.80	25.80	25.60	25.08
K factor	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
Fixed ΔH (Orifice)	93.30	93.30	93.30	93.30	93.30	93.30	93.30	93.30	93.30
Meter (Im in)	9.00	11.00	13.00	15.00	18.00	19.00	20.00	19.00	15.50
Meter (Im out)	9.00	11.00	13.00	15.00	18.00	19.00	20.00	19.00	15.50
Stack Temp (F)	117.00	118.00	118.00	118.00	118.00	118.00	118.00	118.00	117.25
Impinger T Outlet	8.00	8.00	9.00	9.00	10.00	10.00	11.00	11.00	9.48
Impinger T Inlet	8.00	8.00	9.00	9.00	10.00	10.00	11.00	11.00	9.48
Vacuum (° Hg)	-5.00	-5.00	-5.00	-5.00	-5.00	-5.00	-5.00	-5.00	-5.00

Traverse Point	A4	A4	A4	A4	A4	A4	A4	A4	Total
TimePoint (mins)	90 - 90	90 - 100	100 - 110	110 - 120	120 - 130	130 - 140	140 - 150	150 - 160	
ΔH (mm H2O)	25.00	24.50	24.00	24.00	23.00	22.50	22.50	24.00	23.69
K factor	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
Fixed ΔH (Orifice)	93.30	93.30	93.30	93.30	93.30	93.30	93.30	93.30	93.30
Meter (Im in)	19.00	19.00	19.00	19.00	18.00	18.00	18.00	18.00	18.50
Meter (Im out)	19.00	19.00	19.00	19.00	18.00	18.00	18.00	18.00	18.50
Stack Temp (F)	118.00	118.00	117.00	117.00	117.00	117.00	117.00	117.00	117.25
Impinger T Outlet	8.00	9.00	9.00	12.00	14.00	9.00	9.00	10.00	10.00
Impinger T Inlet	8.00	9.00	9.00	12.00	14.00	9.00	9.00	10.00	10.00
Vacuum (° Hg)	-5.00	-6.00	-6.00	-6.00	-6.00	-6.00	-6.00	-6.00	-5.88

Traverse Point	A4	A4	Total
TimePoint (mins)	160 - 170	170 - 180	
ΔH (mm H2O)	23.20	25.80	24.50
K factor	n/a	n/a	
Fixed ΔH (Orifice)	93.30	93.30	93.30
Meter (Im in)	18.00	18.00	18.00
Meter (Im out)	18.00	18.00	18.00
Stack Temp (F)	117.00	117.00	117.00
Impinger T Outlet	11.00	12.00	11.50
Impinger T Inlet	11.00	12.00	11.50
Vacuum (° Hg)	-6.00	-6.00	-6.00

Traverse Point	A4	A4	Total
TimePoint (mins)			
ΔH (mm H2O)			
K factor			
Fixed ΔH (Orifice)			
Meter (Im in)			
Meter (Im out)			
Stack Temp (F)			
Impinger T Outlet			
Impinger T Inlet			
Vacuum (° Hg)			

Impinger	DI H ₂ O	SOL	Start Weight (g)	End Weight (g)	Total weight (g)
Impinger 1	DI H ₂ O		4165	4165	0
Impinger 2	DI H ₂ O		4165	4165	0
Impinger 3	DI H ₂ O		4165	4165	0
Impinger 4	Empty				0
Impinger 5	Silica		902.4	117.88	0
Impinger 6	Silica		926.4	26	0
Impinger 7	Silica		902.4	117.88	0
Impinger 8	Silica		926.4	26	0
Total (g)			862.10		0

PRE-Sample PITOT Visual Inspection	Time	09:03	Pass (Y/N)	Y
Post-Sample Blockage Check (L-type)	Time	09:03	Reading (mm H ₂ O)	
Pass (< 5%) ?	Time	09:05	Pass (Y/N)	Y

PM10 / 2.5 - Test 2

Environmental Compliance Limited		PM10/2.5 DATA SAMPLING PROFORMA				Date of Measurement		25/11/2020							
ECL/TPD		095		Stoppages? (min)		0		Start Time		12:00		End Time		16:00	
Client	B & W Volund Ltd	Stack Profile	Circular	Console id	U010	Barometer id	628	Impinger 1	DI H ₂ O	Solution	SOL NO	Rinse Solutions used			
Site	Margam	Stack Area (m ²)	4.52	Pump id	U010	Nozzle id	905	SOL/	4165	DI Water	4165	DI Water	4165		
Location	Incinerator	Barometric Pressure (mb)	1011	Probe id	143	Nozzle size	6.97	Start Weight (g)	613.2	Acetone	4139	Acetone	4139		
Stack ID	A1	Static Pres. (mm H ² O)	-19	DGM Yd	0.9786	Impactor 1 Filter ID	1989-213202	End Weight (g)	846.2						
Test No.	PM 10 & 2.5 - 2	Pitot coefficient	0.86	ΔH@	48.32	Impactor 2 Filter ID	1989-213205	Total weight (g)	233						
Job No	P4246	Probe Heater Setting (°C)	160	Impinger Id	391	Back Up Filter ID	1989-213234								
ECL Site Staff	SH, HR, PB & ZW	Hot Box Setting (°C)	160	Balance Id	1069	Pitot ID	666	Impinger 2	DI H ₂ O						
		Visible deposits on internal walls in front of first nozzle plate? (Y/N)	N	Smooth Walls		Silica < 5% Spent at End of Test		Yes							
		Sampling Head Orientation (Vertical or Horizontal)	N	Total		FIXED ΔH Settings									
Start Volume	2022233.6	Head heated outside stack (due to moisture saturation?) (m)	N/A	Meter Temp.	30	Stack Temp	120	Impinger 3	DI H ₂ O						
Final Volume	2030784.8	Heating start and finish time	N/A	%Moisture	19.03			SOL/	4165						
Total Volume	5531.2	Equilibration in-stack start and finish time	12:50					Start Weight (g)	724						
								End Weight (g)	921.7						
								Total weight (g)	218.2						

Leak Check	First	Leak check is only performed before sampling	Measured O ₂ (Atmospheric)	5.60	Fixed ΔH	93.3
Rate Limit	0		Measured Carbon Dioxide %	14.48	Reference Oxygen Percentage	6
Vacuum *Hg	-8					
Time of Check	12:47					

Traverse Point	B4	B4	B4	B4	B4	B4	B4	B4	Total
TimePoint (mins)	0 - 10	10 - 20	20 - 30	30 - 40	40 - 50	50 - 60	60 - 70	70 - 80	
ΔH (mm H2O)	24.20	23.00	23.40	22.78	23.80	22.80	23.20	24.00	23.40
K factor	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
Fixed ΔH (Orifice)	93.30	93.30	93.30	93.30	93.30	93.30	93.30	93.30	93.30
Meter (Im in)	20.00	20.00	20.00	21.00	21.00	22.00	22.00	23.00	21.13
Meter (Im out)	20.00	20.00	20.00	21.00	21.00	22.00	22.00	23.00	21.13
Stack Temp (F)	117.00	117.00	117.00	117.00	117.00	117.00	117.00	118.00	117.13
Impinger T Outlet	10.00	10.00	11.00	11.00	12.00	13.00	14.00	15.00	12.00
Impinger T Inlet	10.00	10.00	11.00	11.00	12.00	13.00	14.00	15.00	12.00
Vacuum (° Hg)	-6.00	-6.00	-6.00	-6.00	-6.00	-6.00	-6.00	-6.00	-6.00

Traverse Point	B4	B4	B4	B4	B4	B4	B4	B4	Total
TimePoint (mins)	80 - 90	90 - 100	100 - 110	110 - 120	120 - 130	130 - 140	140 - 150	150 - 160	
ΔH (mm H2O)	24.20	24.20	25.20	23.80	24.00	22.80	21.80	22.80	23.60
K factor	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
Fixed ΔH (Orifice)	93.30	93.30	93.30	93.30	93.30	93.30	93.30	93.30	93.30
Meter (Im in)	23.00	23.00	23.00	23.00	23.00	22.00	22.00	21.00	22.50
Meter (Im out)	23.00	23.00	23.00	23.00	23.00	22.00	22.00	21.00	22.50
Stack Temp (F)	118.00	118.00	118.00	118.00	118.00	118.00	118.00	118.00	118.00
Impinger T Outlet	16.00	16.00	18.00	15.00	12.00	9.00	10.00	10.00	13.25
Impinger T Inlet	16.00	16.00	18.00	15.00	12.00	9.00	10.00	10.00	13.25
Vacuum (° Hg)	-6.00	-6.00	-6.00	-6.00	-6.00	-6.00	-6.00	-6.00	-6.00

Traverse Point	B4	B4	Total
TimePoint (mins)	160 - 170	170 - 180	
ΔH (mm H2O)	24.00	24.60	24.30
K factor	n/a	n/a	
Fixed ΔH (Orifice)	93.30	93.30	93.30
Meter (Im in)	21.00	21.00	21.00
Meter (Im out)	21.00	21.00	21.00
Stack Temp (F)	118.00	118.00	118.00
Impinger T Outlet	10.00	11.00	

Babcock & Wilcox Volund Limited
 Permit No : EPR/DP3137EG
 Variation No : ...
 Report Ref : P4246 : R004

Installation Name : A1 Incinerator
 Visit Details : PM10 & 2.5 - November 2020 Visit
 Survey Dates : 25th November 2020
 Report Issue Date : 15th January 2021

Oxygen Calibration Summary – 25th November 2020

Units

Mean Initial Direct Zero
 Mean Confirmation Direct Zero
 Difference in Direct Zero
 Repeatability at Zero
 <2 x Repeatability at Zero?

Mean Pre Test Zero
 % of Measurement Range?
 Detection Limit (LOD)

Actual Applied Span Concentration

Mean Pre Test System Zero
 Difference $\leq \pm 2\%$ of Span Value?

Mean Post Test Direct Zero
 % of Certified Range?
 Zero Drift $\leq \pm 5\%$ of Applied Span?

Mean Pre Test System Span
 Difference $\leq \pm 2\%$ of Span Value ?

Mean Post Test Direct Span
 Span Drift $\leq \pm 5\%$ Span Value?

Horiba PG 350 Measurement Ranges:	
	O₂
	25
	%Vol
Zero Values (Direct)	
	-0.01
	-0.02
	0.01
	0.20
	YES
Pre Zero Values (System)	
	0.10
	0.40%
	0.20
Applied Span:	
	O₂
	14.89
Pre Test System Zero Values	
	0.10
	0.68%
Post Test Direct Zero Values	
	0.00
	0.00%
	0.03%
Pre Test System Span Values	
	14.86
	0.20%
Post Test Direct Span Values	
	14.90
	0.08%

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
Permit No : EPR/DP3137EG
Variation No : ...
Report Ref : P4246 : R004

Installation Name : A1 Incinerator
Visit Details : PM10 & 2.5 - November 2020 Visit
Survey Dates : 25th November 2020
Report Issue Date. : 15th January 2021

LABORATORY ANALYSIS RESULTS

Laboratory analysis for particulate matter was subcontracted to RPS laboratories, a UKAS Accredited Testing Laboratory, Number 0605. RPS DO hold UKAS & MCERTS accreditation for this analysis. As required by the MCERTS Performance Standard for Organisations, the analysis results are shown below.

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
 Permit No : EPR/DP3137EG
 Variation No : ...
 Report Ref : P4246 : R004

Installation Name : A1 Incinerator
 Visit Details : PM10 & 2.5 - November 2020 Visit
 Survey Dates : 25th November 2020
 Report Issue Date : 15th January 2021

Sample No.	1160461	ECL/20/6332
Total particulate matter	3.38 mg	
Sample No.	1160462	ECL/20/6333
Total particulate matter	0.53 mg	
Sample No.	1160463	ECL/20/6334
Total particulate matter	<0.04 mg	
Sample No.	1160464	ECL/20/6335
Total particulate matter	2.83 mg	
Sample No.	1160465	ECL/20/6336
Total particulate matter	0.58 mg	
Sample No.	1160466	ECL/20/6337
Total particulate matter	0.54 mg	
Sample No.	1160467	ECL/20/6338
Total particulate matter	<0.04 mg	
Sample No.	1160468	ECL/20/6339
Total particulate matter	<0.04 mg	
Sample No.	1160469	ECL/20/6340
Total particulate matter	<0.04 mg	

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
Permit No : EPR/DP3137EG
Variation No : ...
Report Ref : P4246 : R004

Installation Name : A1 Incinerator
Visit Details : PM10 & 2.5 - November 2020 Visit
Survey Dates : 25th November 2020
Report Issue Date. : 15th January 2021

UNCERTAINTY CALCULATIONS

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
 Permit No : EPR/DP3137EG
 Variation No : ...
 Report Ref : P4246 : R004

Installation Name : A1 Incinerator
 Visit Details : PM10 & 2.5 - November 2020 Visit
 Survey Dates : 25th November 2020
 Report Issue Date : 15th January 2021

Site: Margam
 Location: A1

$$u_{mass} = \sqrt{\sum(u_{filter})^2 + (u_{solution})^2}$$

Determinand	Impactor 2 mg	Back Up mg	Recovered Mass mg	LAB Method Uncert (%) K=2		Standard Uncertainty		Combined Uncertainty mg
				Impactor 2 mg	Back Up mg	Impactor 2 mg	Back Up mg	
PM 10 & 2.5 - 1								
PM10 & 2.5	0.53	3.38	3.91	0.0800	0.0800	0.0400	0.0400	0.0566
...
...
...
PM 10 & 2.5 - 2								
PM10 & 2.5	0.58	2.83	3.41	0.0800	0.0800	0.0400	0.0400	0.0566
...
...
...

	PM 10 & 2.5 - 1	PM 10 & 2.5 - 2		Standard Uncertainty @ 95%		
Sampled Volume (V _m)	5.60	5.53	m ³	uV _m	0.001 m ³	
Meter Correction Factor (Y _d)	0.98	0.98	
Meter Temperature (T _m)	290.11	294.72	k	uT _m	1.5 k	
Average Differential Pressure (ΔH)	93.30	93.30	mmH ₂ O	uΔH	0.25 mmH ₂ O	
Barometric Pressure (p _b)	758.31	758.31	mmHg	up _b	3.8 mmHg	
ΔH + p _s (p _m)	102.01	102.01	kPa	
Oxygen content (O _{2,m})	5.77	5.60	% by volume	uO _{2,m} = σ/√n	0.0803	0.0167 % by volume
Moisture Content (H ₂ O)	17.13	16.55	% by volume	uH ₂ O	0.45	0.43 % by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:

$$C_i = \frac{\partial f}{\partial x_i}$$

For each factor, uncertainty is then calculated by C_iu_i, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i = uV_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

PM 10 & 2.5 - 1:	PM 10 & 2.5 - 2:
$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$	$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (up_b) & measured temperature of dry gas uncertainty component (uT_{m,dry})

PM 10 & 2.5 - 1:	PM 10 & 2.5 - 2:																																																		
$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.927$	$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.913$																																																		
<table border="1"> <thead> <tr> <th></th> <th>Maximum</th> <th>Minimum</th> <th>Sensitivity</th> <th>ufstp</th> </tr> </thead> <tbody> <tr> <td>uΔH</td> <td>0.93</td> <td>0.93</td> <td>0.0000891</td> <td>0.0000223</td> </tr> <tr> <td>up_b</td> <td>0.93</td> <td>0.92</td> <td>0.00121</td> <td>0.00454</td> </tr> <tr> <td>uT_m</td> <td>0.93</td> <td>0.92</td> <td>0.00320</td> <td>0.00479</td> </tr> <tr> <td>H₂O</td> <td>...</td> <td>...</td> <td>...</td> <td>...</td> </tr> </tbody> </table>		Maximum	Minimum	Sensitivity	ufstp	uΔH	0.93	0.93	0.0000891	0.0000223	up _b	0.93	0.92	0.00121	0.00454	uT _m	0.93	0.92	0.00320	0.00479	H ₂ O	<table border="1"> <thead> <tr> <th></th> <th>Maximum</th> <th>Minimum</th> <th>Sensitivity</th> <th>ufstp</th> </tr> </thead> <tbody> <tr> <td>uΔH</td> <td>0.91</td> <td>0.91</td> <td>0.0000877</td> <td>0.0000219</td> </tr> <tr> <td>up_b</td> <td>0.92</td> <td>0.91</td> <td>0.00119</td> <td>0.00447</td> </tr> <tr> <td>uT_m</td> <td>0.92</td> <td>0.91</td> <td>0.00310</td> <td>0.00465</td> </tr> <tr> <td>H₂O</td> <td>...</td> <td>...</td> <td>...</td> <td>...</td> </tr> </tbody> </table>		Maximum	Minimum	Sensitivity	ufstp	uΔH	0.91	0.91	0.0000877	0.0000219	up _b	0.92	0.91	0.00119	0.00447	uT _m	0.92	0.91	0.00310	0.00465	H ₂ O
	Maximum	Minimum	Sensitivity	ufstp																																															
uΔH	0.93	0.93	0.0000891	0.0000223																																															
up _b	0.93	0.92	0.00121	0.00454																																															
uT _m	0.93	0.92	0.00320	0.00479																																															
H ₂ O																																															
	Maximum	Minimum	Sensitivity	ufstp																																															
uΔH	0.91	0.91	0.0000877	0.0000219																																															
up _b	0.92	0.91	0.00119	0.00447																																															
uT _m	0.92	0.91	0.00310	0.00465																																															
H ₂ O																																															
$\frac{uf_s}{f_s} = \sqrt{\left(\frac{u\Delta H}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100-H_2O)}\right)^2} = 0.00592$	$\frac{uf_s}{f_s} = \sqrt{\left(\frac{u\Delta H}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100-H_2O)}\right)^2} = 0.00565$																																																		

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

PM 10 & 2.5 - 1:	PM 10 & 2.5 - 2:																														
$V_{std} = V_{measured} \times f_s = 5.196$	$V_{std} = V_{measured} \times f_s = 5.048$																														
<table border="1"> <thead> <tr> <th></th> <th>Maximum m³</th> <th>Minimum m³</th> <th>Sensitivity</th> <th>Standard Uncertainty (m³)</th> </tr> </thead> <tbody> <tr> <td>Effect of uV_{std}</td> <td>5.23</td> <td>5.16</td> <td>5.60</td> <td>0.0332</td> </tr> <tr> <td>Effect of uV_m</td> <td>5.20</td> <td>5.20</td> <td>0.93</td> <td>0.000927</td> </tr> </tbody> </table>		Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty (m ³)	Effect of uV _{std}	5.23	5.16	5.60	0.0332	Effect of uV _m	5.20	5.20	0.93	0.000927	<table border="1"> <thead> <tr> <th></th> <th>Maximum m³</th> <th>Minimum m³</th> <th>Sensitivity</th> <th>Standard Uncertainty (m³)</th> </tr> </thead> <tbody> <tr> <td>Effect of uV_{std}</td> <td>5.08</td> <td>5.02</td> <td>5.53</td> <td>0.0312</td> </tr> <tr> <td>Effect of uV_m</td> <td>5.05</td> <td>5.05</td> <td>0.91</td> <td>0.000913</td> </tr> </tbody> </table>		Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty (m ³)	Effect of uV _{std}	5.08	5.02	5.53	0.0312	Effect of uV _m	5.05	5.05	0.91	0.000913
	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty (m ³)																											
Effect of uV _{std}	5.23	5.16	5.60	0.0332																											
Effect of uV _m	5.20	5.20	0.93	0.000927																											
	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty (m ³)																											
Effect of uV _{std}	5.08	5.02	5.53	0.0312																											
Effect of uV _m	5.05	5.05	0.91	0.000913																											
<p>Combined Standard Uncertainty</p> $\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.19$	<p>Combined Standard Uncertainty</p> $\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.17$																														

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
 Permit No : EPR/DP3137EG
 Variation No : ...
 Report Ref : P4246 : R004

Installation Name : A1 Incinerator
 Visit Details : PM10 & 2.5 - November 2020 Visit
 Survey Dates : 25th November 2020
 Report Issue Date : 15th January 2021

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	PM 10 & 2.5 - 1:				PM 10 & 2.5 - 2:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³
PM 10 & 2.5	0.76	0.74	0.19	0.01	0.69	0.66	0.20	0.01
...
...
...

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

Determinand	PM 10 & 2.5 - 1:	PM 10 & 2.5 - 2:
	uL mg/Nm ³	uL mg/Nm ³
PM 10 & 2.5	0.01	0.01
...
...
...

Uncertainty in final measurement @ Reference Conditions due to uVstp

Determinand	PM 10 & 2.5 - 1:				PM 10 & 2.5 - 2:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uVstp mg/Nm ³	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uVstp mg/Nm ³
PM 10 & 2.5	0.78	0.73	0.15	0.0269	0.70	0.65	0.13	0.0231
...
...
...

Combined Uncertainty excluding oxygen contribution

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Determinand	PM 10 & 2.5 - 1:				PM 10 & 2.5 - 2:			
	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
PM 10 & 2.5	0.0303	0.0607	0.75	8.06	0.0269	0.0537	0.68	7.95
...
...
...

Uncertainty of Oxygen Correction Factor (%):-

PM 10 & 2.5 - 1:

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 0.98$$

$$u_{Corr_{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.0234$$

$$uf_{O_2} = \frac{u_{Corr_{O_2}}}{f_{O_2}} \times 100 = 2.38\%$$

Uncertainty of Oxygen Correction Factor (%):-

PM 10 & 2.5 - 2:

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} =$$

$$u_{Corr_{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} =$$

$$uf_{O_2} = \frac{u_{Corr_{O_2}}}{f_{O_2}} \times 100 =$$

Combined Uncertainty including oxygen contribution

$$u_{combined} = \sqrt{\sum (uf_{O_2})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Determinand	PM 10 & 2.5 - 1:			PM 10 & 2.5 - 2:		
	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr ⁿ Factor	Overall Measurement Uncertainty inc O ₂ Corr ⁿ factor (U _{combined})	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr ⁿ Factor	Overall Measurement Uncertainty inc O ₂ Corr ⁿ factor (U _{combined})
PM 10 & 2.5	8.06	2.38	8.41	7.95	2.38	8.30
...
...
...

Environmental Compliance Limited

Babcock & Wilcox Volund Limited
 Permit No : EPR/DP3137EG
 Variation No : ...
 Report Ref : P4246 : R004

Installation Name : A1 Incinerator
 Visit Details : PM10 & 2.5 - November 2020 Visit
 Survey Dates : 25th November 2020
 Report Issue Date : 15th January 2021

Stack Reference A1

Measurement Uncertainty Calculations - Velocity at Stack Conditions

Contribution From	Standard u/c (mm H ₂ O)	
Pitot Calibration Uncertainty Contribution	0.121	A
Manometer Calibration Uncertainty Contribution	0.121	B
Variation in Actual Pitot reading at sample points	0.31	C
Combined u/c (mm H₂O) =	Combined u/c (mm H₂O)	
SQRT (A/ $\sqrt{3}$) ² + (B/ $\sqrt{3}$) ² + (C/ $\sqrt{3}$) ²	0.21	
Expanded Uncertainty of Flow Measurements (mm H₂O)	0.41	
	Standard u/c (K)	
Temperature Calibration (K)	1.96	D
Variation in Actual Temp reading at sample points	0.00	E
Combined u/c of Temp (K)	Combined u/c (K)	
SQRT ((D/ $\sqrt{3}$) ² + (E/ $\sqrt{3}$) ²)	1.13	
Expanded Uncertainty of Temp Measurements (K)	2.26	
Measured Average Velocity (m/s) at Stack Conds	19.66	
Maximum Average Velocity (m/s) at Stack Conds	19.88	
Standard Uncertainty Velocity at Stack Conditions (%)	1.14	
Expanded Uncertainty Velocity (at Stack Conditions)	2.27 (%)	

Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m ²)
Area (m ²)	0.04524
Measured Average Flowrate (m ³ /s) at Stack Conds	88.92
Maximum Average Flowrate (m ³ /s) at Stack Conds	90.83
Standard Uncertainty Flowrate (m ³ /s) at Stack Conditions (%)	2.15
Expanded Uncertainty Flowrate (m³/s) at Stack Conditions	4.30 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)
Temperature Calibration (K)	0.5
Barometer Calibration	0.5
Measured Average Flowrate (m ³ /s) at STP Wet	61.72
Maximum Average Flowrate (m ³ /s) at STP Wet	63.26
Standard Uncertainty Flowrate (m ³ /s) at STP Wet	2.50
Expanded Uncertainty Flowrate (m³/s) at STP Wet	5.01 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Dry Gas

Contribution From	Standard u/c (%)
Moisture Uncertainty (% v/v)	0.25
Measured Average Flowrate (m ³ /s) at STP Dry	50.51
Maximum Average Flowrate (m ³ /s) at STP Dry	51.94
Standard Uncertainty Flowrate (m ³ /s) at STP Dry	2.82
Expanded Uncertainty Flowrate (m³/s) at STP Dry	5.64 (%)

Measurement Uncertainty Calculations - Flowrate at STP, Dry Gas & Ref Oxygen

Contribution From	Standard u/c (%)
Oxygen Uncertainty (% v/v)	0.057
Measured Average Flowrate (m ³ /s) at STP Dry & Ref Oxygen	51.63
Maximum Average Flowrate (m ³ /s) at STP Dry & Ref Oxygen	53.28
Standard Uncertainty Flowrate (m ³ /s) at STP Dry & Ref Oxygen	3.20
Expanded Uncertainty Flowrate (m³/s) at STP Dry & Ref O₂	6.40 (%)