

Schedule 1 - Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	AP3433ES
Name of Operator	Kepak Group Ltd
Location of Installation	Merthyr Tydfil
Location of the emission	S1
Time and date of the emission	22/01/2021

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Fats, Oil and Grease	Effluent	884 mg/l	22/01/2021
Suspended Solids	Effluent	1586 mg/l	22/01/2021

Measures taken, or intended to be taken, to stop the emission	Emission detected after the date of emission
---	--

Part B

Any more accurate information on the matters for notification under Part A.	Issue with sampler was reported on the day the sample was taken by Welsh Wate (22/01/21).
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Water sampler serviced and repaired on 26/01/2021. Welsh water came back to site on 27/01/2021 and 29/01/2021 to conduct repeat sampling and both were analysed and found to be within specification.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	
The dates of any unauthorised emissions from the installation in the preceding 24 months.	21/07/21 S1 - Emission exceedance - fats oil and grease 22/05/21 Emissions to Air refrigerant-R404AR 16/04/21 SI Emission exceedance – fats oil and grease 23/12/20 W2 Surface water (Run off from scrapyard) 02/04/20- W1 Emission of Suspended Solids 02/04/20- W1 Emission of Mineral oil and hydrocarbon 15/03/20- Emissions to Air refrigerant -R404A & R448A 31/01/2020- W1 and W2 sample not taken for January 02/02/2020- Emissions to Air refrigerant R404A 02/02/20- S1 - Emission exceedance-SS 02/02/20- S1 - Emission exceedance- COD 02/01/20- S1 - Emission exceedance-Oils & Grease 01/12/19- Emissions to Air refrigerant-R448A

Name*	Steve Davies
Post	Technical Services Manager
Signature	
Date	04/11/2021

* authorised to sign on behalf of Kepak Red Meat Division