

Permit Nur	Sample Poi	Sample Poi	Sample Poi	Sampling F	Source Nar	Treatment	Determinand Code, Description & Units	Season Sta	Season Sta	Season Enc	Season Enc	Limit 1	Limit 1 Def	Limit 2	Limit 2 Def	Limit 3	Limit 3 Def	Population Equivalent
CG005800	SH 52390	7 SA: SEWAG	27589			01: BIOLOC	0085: BOD : 5 Day ATU (mg/l)	1	1	31	12			28	95%			
CG005800	SH 52390	7 SA: SEWAG	27589			01: BIOLOC	0135: Solids, Suspended at 105 C (mg/l)	1	1	31	12			35	95%			
CG005800	SH 52390	7 SA: SEWAG	27589			01: BIOLOC	3527: Flow, instantaneous (l/s)	1	1	31	12	2.8	Max					
CG005800	SH 52390	7 SA: SEWAG	27589			01: BIOLOC	6425: Flow : Daily total (m3/d)	1	1	31	12	711	Max					
CG005800	SH 52390	7 SA: SEWAG	27589			01: BIOLOC	7782: Flow : Dry Weather :- {DWF} (m3/d)	1	1	31	12	237	Max					