

Aug 2021

Day	Downtime	Rationale
1	0	
2	0	
3	0	
4	4.5	Shut plant due to excessive fouling
5	24	Manual cleaning of boiler screen & S/H 4 due to excess fouling
6	0.5	Starting up from above
7	0	
8	0	
9	0	
10	0	
11	0	
12	0	
13	1.5	Plant trip due to Super heater steam Temp T/C failure, replaced and restarted.
14	0	
15	0	
16	0	
17	0	
18	0	
19	0	
20	0	
21	2	High clinker deposits damaged west ash conveyor paddles requiring replacement.
22	0	
23	0	
24	0	
25	0	
26	0	
27	0	
28	0	
29	0	
30	0	
31	0	
Month	32.5	