

Ms Gillian Jones  
Infinite renewables Group Limited  
Number 1 Waterton  
Bridgend  
CF31 3PH

**Our ref: PAN-014743**  
**Your ref: PAN-014743**

**Date: 17/11/2021**

Dear Ms Jones

**We need more information about your application**

**Application reference: PAN-014743**  
**Operator: Infinite Renewables Group Limited**  
**Facility: The Royal Mint CHP Facility, Llantrisant, Pontyclun, CF72 8YT.**

Thank you for your application received on 19/07/2021.

I need to ask you for some more information before I can do any more work on it. Please would you

- Please provide a copy H1 screening tool to demonstrate the CO screens out at the initial stage and requires no further assessment.
- Please provide us with more information to question Form B2 part 5a. We need the site plan to contains the installation
  - the CHP plant boundary outlined in one color
  - the proposed Royal Mint installation boundary outlined in another color
  - labelled emission point for the CHP
- Please provide us with more information to question Form B3 question 3 part b. Carry out an air emissions risk assessment of emissions on all non-statutory habitat sites within 2 km of the CHP (ancient woodland, national nature reserves, local nature reserves, local wildlife sites) in line with the following guidance: [Air emissions risk assessment for your environmental permit - GOV.UK \(www.gov.uk\)](https://www.gov.uk/guidance/air-emissions-risk-assessment-for-your-environmental-permit). As per [Air emissions risk assessment for your environmental permit - GOV.UK \(www.gov.uk\)](https://www.gov.uk/guidance/air-emissions-risk-assessment-for-your-environmental-permit) for local wildlife sites, local nature reserves, national nature reserves and ancient woodlands you can screen out your emissions as insignificant if your emissions are less than 100 % of the short term and long term environmental standards.

Ffôn/Tel 0300 065 3000  
Eboest/Email [William.Wallace@cyfoethnaturiolcymru.gov.uk](mailto:William.Wallace@cyfoethnaturiolcymru.gov.uk)  
[William.Wallace @naturalresourceswales.gov.uk](mailto:William.Wallace@naturalresourceswales.gov.uk)

Canolfan Trwyddedu Cymru (Caerdydd), Cyfoeth Naturiol Cymru, Tŷ Cambria, 29 Heol Casnewydd, Caerdydd.  
CF24 0TP  
Wales Permitting Centre (Cardiff), Natural Resources Wales, Cambria House, 29 Newport Road, Cardiff. CF24 0TP

Gwefan/Website [www.cyfoethnaturiolcymru.gov.uk](http://www.cyfoethnaturiolcymru.gov.uk)  
[www.naturalresourceswales.gov.uk](http://www.naturalresourceswales.gov.uk)

Croesewir gohebiaeth yn y Gymraeg a'r Saesneg  
Correspondence welcomed in Welsh and English

- Confirm the MWth input of the CHP, there is a contradiction in the application between 4.28 MWth and 4.3 MWth.
- provide a suitable MCPD identifier as per Appendix 8 of Form B3. The MCPD identifier must be traceable via a serial number or other unique identifier, name plate, manufacturer and/or model.

If you need advice about how to complete the form, please contact your local area office. Call 0300 065 3000 and ask to speak to your local area office or your site officer.

Please reply within 10 working days from the date of this letter. If we don't hear from you we must return your application and fee.

If you email or write to us please quote the application PAN-014743 on any correspondence and send it to the relevant address below.

When we receive the missing items we'll continue to check the details in your application. If there's enough there for us to begin the process of deciding whether or not we can grant your application we say the application is 'duly made' and we'll let you know this by letter.

Please quote our reference if you contact us. If you have any questions please email [william.wallace@naturalresourceswales.gov.uk](mailto:william.wallace@naturalresourceswales.gov.uk).

Yours sincerely

William Wallace  
Permitting Officer, Installations and RSR