


# Renewable Heat Incentive

## Non-domestic Renewable Heat Incentive Emissions Certificate

<b>1. TEST HOUSE</b>	
a) name and address of testing laboratory	<i>Envirocare Technical Consultancy Ltd. St. Blaise House, Vaughan Street, Bardford, BD1 2LL</i>
b) name and signature of the person authorised by the testing laboratory to issue the certificate	Name: <i>Adam May</i>
	Signature: 
c) date of issue of this certificate together with certificate reference number *Please see Note A	Date: <i>22/08/2016</i>
	Ref: <i>ETC_RHI_025.1_WOODTEK</i>
d) if testing laboratory is accredited to BS EN ISO/IEC 17025:2005, date of accreditation and accreditation number <i>(note: if testing conducted after 24 September 2013, the testing laboratory <b>must be</b> BS EN ISO/IEC 17025:2005 accredited)</i>	Date: <i>December 2003</i> <i>Latest update January 2015</i>
	Accreditation number: <i>2522</i>

<b>2. PLANT</b> <i>Please see Note B</i>	
a) name of the plant tested	<i>Kotlozavod Kriger Lta</i>
b) model of the plant tested	<i>KVm 1.0</i>
c) manufacturer of the plant tested	<i>Kotlozavod Kriger Lta</i>
d) installation capacity* of the <b>tested</b> plant in kilowatts (kW) *defined in the RHI Regulations as the total installed peak heat output capacity of the plant	<i>999kW</i>
e) is the plant a <u>manually stoked, natural draught</u> plant? (that is, without a fan providing forced or induced draught)	<i>No</i>
f) (i) the date the plant was tested* (ii) please confirm that NOx and PM have been tested on the same occasion *This is in reference to the emissions testing for PM and NOx, not any wider range of tests. A specific date is required.	<i>11/08/2016</i> <i>Yes</i>
g) list of all the plants in the type-testing range* of plants to which the certificate applies, if any <sup>1</sup> Please include the <b>installation capacity</b> of each model. <i>*This must follow the ratio rules: If the smallest plant in the range is 500kW or less, the largest plant in the range can't be more than double the smallest. If the smallest plant in the range is over 500kW, the largest plant in the range can't be more than 500kW greater than the smallest.</i>	

<sup>1</sup> The type-testing approach enables testing laboratories to provide assurance that all boilers in a given range meet the air quality requirements, without needing to specifically test each boiler.

<b>3. FUELS</b>	
a) types of fuels used when testing	<i>B2 Chipped Wood (G50)</i>
b) based on the testing, list the range of fuels that can be used in compliance with the emission limits of 30 grams per gigajoule (g/GJ) net heat input for particulate matter (PM), and 150 g/GJ net heat input for oxides of nitrogen (NO <sub>x</sub> ) <i>(based if relevant on classifications from EN14961 or EN303-5)</i>	<i>B2 Chipped Wood (G50)</i>
c) moisture content of the fuel used during testing	<i>40%</i>
d) maximum moisture content* of the fuel which can be used with the certified plant(s) so as to ensure that the RHI emission limits are not exceeded. <i>* This value may be obtained from ranges specified in EN 303-5 based on the fuel type(s) tested</i>	<i>50%</i>

<b>4. TESTS</b>	
Confirm which requirements the emissions of NOx and PM have been tested in accordance with. <b><u>Either 4a or 4b should be confirmed, the other should be 'not applicable'</u></b>	
a) <b>if the testing was carried out in accordance with the provisions relevant to emissions of PM and NOx in either BS EN 303-5:1999 or BS EN 303-5:2012<sup>2</sup></b> , please confirm: - the test was conducted to whichever standard was current at the time of testing.	<i>BS EN 303-5:1999: BS EN 303-5:2012:</i>
b) <b>if the testing was carried out in accordance with the following requirements</b> , please confirm: (i) testing was carried out in accordance with: - EN 14792:2005 in respect of NOx emissions, and; - EN 13284-1:2002 or ISO 9096:2003 in respect of PM emissions <sup>3</sup> ; and  (ii) emissions of PM represent the average of at least three measurements of emissions of PM, each of at least 30 minutes duration; and  (iii) the value for NOx emissions is derived from the average of measurements made throughout the PM emission tests.	<i>Yes</i>  <i>Yes</i>  <i>Yes</i>
c) please confirm the plant was tested at ≥85% of the installation capacity of the plant	<i>Yes</i>
d) please confirm the test shows that emissions from the plant were no greater than 30 g/GJ PM and 150 g/GJ NOx	<i>Yes</i>
e) measured* emissions of PM in <b>g/GJ</b> net heat input *this value should be from the test confirmed in 4c. Results from partial load tests are not required. This value must be in the specified units.	<i>15.2, 13.3 &amp; 15.6g/GJ</i>
f) measured* emissions of NOx in <b>g/GJ</b> net heat input *this value should be from the test confirmed in 4c. Results from partial load tests are not required. This value must be in the specified units.	<i>85.0g/GJ</i>

<sup>2</sup> BS EN303-5:1999 and 2012 explain what should be measured and when.

<sup>3</sup> These standards explain how to make the PM and NOx measurements.