

# Schedule 6 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

## Part A


Permit Number	<b>BR9383ID</b>	Notification Reference	<b>EP_EX_208</b>
Name of operator	<b>Knauf Insulation Ltd</b>		
Location of Facility	<b>Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA</b>		
Time and date of the detection	<b>08:00 17<sup>th</sup> October 2018</b>		

<b>(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution</b>	
<b>To be notified within 24 hours of detection</b>	
Date and time of the event	<b>17:15 16<sup>th</sup> October 2018</b>
Reference or description of the location of the event	<b>CEMS data for SO2 not transferring correctly into plant computer resulting in loss of corrected data for SO2 emission from emission point A</b>
Description of where any release into the environment took place	<b>No known release above permitted levels</b>
Substances(s) potentially released	<b>SOx from Emission point A, Cupola stack after oxidiser</b>
Best estimate of the quantity or rate of release of substances	<b>Plant is operating normally. Emissions should be at normal levels</b>
Measures taken, or intended to be taken, to stop any emission	<b>Enviro Tec engineer carried out further remote communication testing Knauf engineer testing I/O signals. Ongoing.</b>
Description of the failure or accident.	<b>SO2 levels are being measured and displayed in uncorrected form. Data is not reaching plant systems for averaging and reporting of corrected SO2 levels at emission point A</b>

<b>(b) Notification requirements for the breach of a limit</b>	
<b>To be notified within 24 hours of detection unless otherwise specified below</b>	
Emission point reference/ source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

<b>Time periods for notification following detection of a breach of a limit</b>	
<b>Parameter</b>	<b>Notification period</b>

<b>(c) Notification requirements for the detection of any significant adverse environmental effect</b>	
<b>To be notified within 24 hours of detection</b>	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

<b>Name*</b>	G A Jones
<b>Post</b>	Process and Energy Manager
<b>Signature</b>	
<b>Date</b>	17 <sup>th</sup> October 2018

\* authorised to sign on behalf of Knauf Insulation Ltd