Form Number : A1 Schedule 1 – Notification of Abnormal Emissions

Part A

Permit Number	BX2782IS
Name of Operator	InBev UK Ltd
Location of the Installation	Magor
Location of the Emission	Magor Brewery – Water treatment
Time and Date of Emission	Tuesday 23rd June 2015 (approx. 45 mins)

Substance(s) emitted	Media	Best estimate of the quantity or rate of Emission	Time during which the emission took place
32% HCl	Ground (soil and potentially ground water)	Exact quantity unknown. Still to be determined during excavations	Tuesday 23rd June 2015 (approx. 45 mins)

Measures taken or intended to be taken to stop the emission	The incident was well managed, contained, and a specialist contractor employed (within the hr) to gulp the remaining liquid from the bund. A specialist tanker is required for this type of waste. The tanks have been removed, the area decontaminated, and currently civil works are underway to remove the bund wall and hard stand (works started Monday 13th July). An excavator will be present, and any contaminated soil will be removed. A new double skinned tank is being sourced, and is currently awaiting sign off by our procurement team. A full site bund survey was completed on the 13th and 14th July, by a specialist firm (Amec). The report has not been issued yet.

Part B

Any more accurate information on the matters for notification under	.

- 2 JUL 2015

Part A	
Measures taken or intended to be taken to prevent a recurrence of the incident	
Meaures taken or intended to be taken to rectify limit or prevent any pollution to the environment or harm which has been or may be caused by the emission	
The dates of any unauthorised emissions from the installation in the preceding 24 months	

Name*	Kathryn fowler
Post	ES Manager
Signature	
Date	17/6/2015

*Authorised to sign on behalf of InBev UK Ltd.