

## Schedule 1 - Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

### Part A


Permit Number	BX72821S
Name of Operator	AB-InBev
Location of Installation	Magor, Caldicot NP26 3RA
Location of the emission	BTS
Time and date of the emission	14/15 <sup>TH</sup> September 2017

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
WATER	PH 9.9	3407 M <sup>3</sup> DAY	08:00
WATER	SUSPENDED SOLIDS	3407 M <sup>3</sup> DAY	08:00

Measures taken, or intended to be taken, to stop the emission	REPLACE THE UPS BATTERY BACK UP TO THE PLC.
---	---

### Part B

Any more accurate information on the matters for notification under Part A.	ATTACHED REPORTS
Measures taken, or intended to be taken, to prevent a recurrence of the incident	REPLACE UPS
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	REVIEW OF MANAGEMENT SYSTEM CONTROLS.
The dates of any unauthorised emissions from the installation in the preceding 24 months.	2.

Name*	CARL ROGERS
Post	ES MANAGER
Signature	
Date	27/9/17

\* authorised to sign on behalf of Interbrew UK Ltd

ESTIMATED FLOW VALUE BECAUSE PLANT WAS SHUTDOWN, MINIMAL FLOW

