

Form Number: A1

Reporting of Emissions to Air for the period from 1st January 2017 – 31st December 2017

Emission Point	Substance / Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method ⁽²⁾	Sample Date and Times ⁽³⁾	Accreditation/ Certification ⁽⁴⁾	Uncertainty ⁽⁵⁾
A1	Oxides of nitrogen as NO ₂	220mg/m ³ ⁽⁶⁾	174	BS EN 14792	15 th June 13.50-14.50	Meerts MC 050056/00	22
A1	Carbon monoxide	None	80	BS EN 15068	15 th June 13.50-14.50	Meerts MC 050056/00	12
A1	Oxygen	None	2.9	BS EN 14789	15 th June 13.50-14.50		
A1	Temperature	None	-	-			
A2	Oxides of nitrogen as NO ₂	220mg/m ³ ⁽⁶⁾	201	BS EN 14792	15 th June 10.10-11.10	Meerts MC 050056/00	26
A2	Carbon monoxide	None	3.2	BS EN 15068	15 th June 10.10-11.10	Meerts MC 050056/00	11.6
A2	Oxygen	None	5.3	BS EN 14789	15 th June 10.10-11.10		
A2	Temperature	None	-	-			
A3	Oxides of nitrogen as NO ₂	220mg/m ³ ⁽⁶⁾	79	BS EN 14792	15 th June 12.25-13.25	Meerts MC 050056/00	23
A3	Carbon monoxide	None	22	BS EN 15068	15 th June 12.25-13.25	Meerts MC 050056/00	14
A3	Oxygen	None	5.1	BS EN 14789	15 th June 12.25-13.25		
A3	Temperature	None	-	-			
A4	Oxides of nitrogen as NO ₂	220mg/m ³ ⁽⁶⁾	94	BS EN 14792	15 th June 11.15-12.15	Meerts MC 050056/00	24
A4	Carbon monoxide	None	1.9	BS EN 15068	15 th June 11.15-12.15	Meerts MC 050056/00	11.6
A4	Oxygen	None	3.1	BS EN 14789	15 th June 11.15-12.15		
A4	Temperature	None	-	-			
A1	Oxides of nitrogen as NO ₂	220mg/m ³ ⁽⁶⁾	216	BS EN 14792	13 th December 12.25-13.25	Meerts MC 050056/00	31
A1	Carbon monoxide	None	>5770	BS EN 15068	13 th December 12.25-13.25	Meerts MC 050056/00	245
A1	Oxygen	None	1	BS EN 14789	13 th December 12.25-13.25		
A1	Temperature	None					
A2	Oxides of nitrogen as NO ₂	220mg/m ³ ⁽⁶⁾	204	BS EN 14792	13 th December 10.04-11.04	Meerts MC 050056/00	30
A2	Carbon monoxide	None	3.1	BS EN 15068	13 th December 10.04-11.04	Meerts MC 050056/00	.7
A2	Oxygen	None	3.7	BS EN 14789	13 th December 10.04-11.04		
A2	Temperature	None	-	-			
A3	Oxides of nitrogen as NO ₂	220mg/m ³ ⁽⁶⁾	99	BS EN 14792	13 th December 11.15-12.15	Meerts MC 050056/00	17
A3	Carbon monoxide	None	1.9	BS EN 15068	13 th December 11.15-12.15	Meerts MC 050056/00	.4
A3	Oxygen	None	2	BS EN 14789	13 th December 11.15-12.15		
A3	Temperature	None					
A4	Oxides of nitrogen as NO ₂	140mg/m ³ ⁽⁶⁾	Not running	BS EN 14792	Not running	Meerts MC 050056/00	
A4	Carbon monoxide	None	Not running	BS EN 15068	Not running	Meerts MC 050056/00	
A4	Oxygen	None	Not Running	BS EN 14789	Not Running		
A4	Temperature	None	-	-			
A5	Oxides of nitrogen as NO ₂	350mg/m ³ ⁽⁷⁾	No longer operational	No longer operational	No longer operational	No longer operational	No longer operational
A5	Carbon monoxide	500mg/m ³ ⁽⁷⁾	No longer operational	No longer operational	No longer operational	No longer operational	No longer operational
A5	Oxygen	None	No longer operational	No longer operational	No longer operational	No longer operational	No longer operational

A5	Temperature	None	No longer operational	No longer operational	No longer operational	No longer operational
A6	Oxides of nitrogen as NO ₂	350mg/m ³ [7]	No longer operational	No longer operational	No longer operational	No longer operational
A6	Carbon monoxide	500mg/m ³ [7]	No longer operational	No longer operational	No longer operational	No longer operational
A6	Oxygen	None	No longer operational	No longer operational	No longer operational	No longer operational
A6	Temperature	None	No longer operational	No longer operational	No longer operational	No longer operational
A5	Oxides of nitrogen as NO ₂	350mg/m ³ [7]	No longer operational	No longer operational	No longer operational	No longer operational
A5	Carbon monoxide	500mg/m ³ [7]	No longer operational	No longer operational	No longer operational	No longer operational
A5	Oxygen	None	No longer operational	No longer operational	No longer operational	No longer operational
A5	Temperature	None	No longer operational	No longer operational	No longer operational	No longer operational
A6	Oxides of nitrogen as NO ₂	350mg/m ³ [7]	No longer operational	No longer operational	No longer operational	No longer operational
A6	Carbon monoxide	500mg/m ³ [7]	No longer operational	No longer operational	No longer operational	No longer operational
A6	Oxygen	None	No longer operational	No longer operational	No longer operational	No longer operational
A6	Temperature	None	No longer operational	No longer operational	No longer operational	No longer operational

Form Number: A1

- [1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.
- [2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
- [4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.
- [5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated. The following uncertainties are quoted on a different basis (basis as stated) – {The basis of any other uncertainty figure needs to be stated. Where no figure is available the Agency will need to agree an appropriate uncertainty value.}
- [6] Corrected to 273K, 101.3kPa, 5% oxygen, dry
- [7] Corrected to 273K, 101.3kPa, 15% oxygen, dry

Signed Carl Rogers.....
(authorised to sign as representative of the Operator)

Date.....30/01/18.....