

Schedule 1 - Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number

BX7282IS

Name of Operator

AB - WBEV

Location of Installation

MAGOR

Location of the emission

OFFSITE BTS

Time and date of the emission

5/1/2018

Substance(s) emitted Media

STORMWATER WATER

Best estimate of the quantity or the rate of emission

N/K

Time during which the emission took place

4-5TH JAN 2018

Measures taken, or intended to be taken, to stop the emission

INFORMED WELSH WATER OF THE PUMP STATION OVERFLOW.
INFORMED NRW

Part B

Any more accurate information on the matters for notification under Part A.

RISER BURST IN SUDBROOK, PART OF THE WATER NETWORK

Measures taken, or intended to be taken, to prevent a recurrence of the incident

WAITING FEEDBACK FROM WELSH WATER

Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission

ABI/SUEZ ATTEMPTED TO PREVENT ENTRY INTO THE STORMWATER DRAIN AND REENS.

The dates of any unauthorised emissions from the installation in the preceding 24 months.

N/K

Name*

CARL ROGERS
ES MANAGER

Post

Signature



Date

5/1/18

* authorised to sign on behalf of Interbrew UK Ltd