

Schedule 6 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/FP3232KG
Name of operator	Dwr Cymru Cyfyngedig
Location of Facility	Cardiff
Time and date of the detection	6/7/15

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution

To be notified within 24 hours of detection	
Date and time of the event	6/7/15
Reference or description of the location of the event	Area 3 Camby CHP Plant
Description of where any release into the environment took place	As above
Substances(s) potentially released	Steam
Best estimate of the quantity or rate of release of substances	N/A
Measures taken, or intended to be taken, to stop any emission	Improved maintenance + screening of incoming sludge
Description of the failure or accident.	Blocked reactor (CHP Plant). Need to vent to drop steam pressure from 2.7 Bar to Atmospheric

(b) Notification requirements for the breach of a limit

To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	N/A
Measures taken, or intended to be taken, to prevent a recurrence of the incident	N/A
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	N/A
The dates of any unauthorised emissions from the facility in the preceding 24 months.	N/A

Name*	Mathew Griffiths
Post	Env Permitting Specialist
Signature	M. Griffiths
Date	16/7/15

* authorised to sign on behalf of Dwr Cymru Cyfyngedig