

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR / FP 32 32 K G
Name of operator	Dŵr Cymru Cyfyngedig
Location of Facility	CARDIFF CHP FACILITY
Time and date of the detection	09/02/2017

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution	
To be notified within 24 hours of detection	
Date and time of the event	09/02/2017
Reference or description of the location of the event	CHP ENGINE BREAKDOWN OF ALTERNATORS.
Description of where any release into the environment took place	AIR RELEASE POINT B, FLARE STACK OPERATING FREQUENTLY.
Substances(s) potentially released	CARBON MONOXIDE, NO _x , SO _x .
Best estimate of the quantity or rate of release of substances	INTERMITTENT RELEASE UNDER COMBUSTION IN FLARE STACK.
Measures taken, or intended to be taken, to stop any emission	INCIDENT DECLARED TO PROMPTLY INVESTIGATE CHP ALTERNATOR ISSUE.
Description of the failure or accident.	ELECTRICAL FAULT WITH ALTERNATORS 1&2 - ENGINE 3 OFF AS PRECAUTION.

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	AIR RELEASE POINT B
Parameter(s)	TESTING PLANNED FOR 15/02/17.
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

Permit number
EPR/FP3232KG/V002

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	
Post	
Signature	
Date	

* authorised to sign on behalf of the operator

Permit number
EPR/FP3232KG/V002